

NI NI 9253

8-Channel Simultaneous Analog Input Module



© Artisan Technology Group

In Stock

Used and in Excellent Condition

Open Web Page

<https://www.artisanng.com/84234-1>

All trademarks, brandnames, and brands appearing herein are the property of their respective owners.



Your **definitive** source
for quality pre-owned
equipment.

Artisan Technology Group

(217) 352-9330 | sales@artisanng.com | artisanng.com

- Critical and expedited services
- In stock / Ready-to-ship


- We buy your excess, underutilized, and idle equipment
- Full-service, independent repair center

Artisan Scientific Corporation dba Artisan Technology Group is not an affiliate, representative, or authorized distributor for any manufacturer listed herein.

GETTING STARTED GUIDE

NI 9253

8 AI, ± 20 mA, 24 bit, 50 kS/s/ch Simultaneous



This document explains how to connect to the NI 9253.



Note Before you begin, complete the software and hardware installation procedures in your chassis documentation.



Note The guidelines in this document are specific to the NI 9253. The other components in the system might not meet the same safety ratings. Refer to the documentation for each component in the system to determine the safety and EMC ratings for the entire system.

NI 9253 Pinout




Table 1. Signal Descriptions

Signal	Description
AI	Analog input signal connection
V _{sup}	Voltage supply connection
COM	Common reference connection to isolated ground
NC	No connection

NI 9253 LEDs

Status	Color	Indication
ON	Green	- Channel is operational with input limits detection enabled V_{sup} is in range if field side power fault detection is enabled
	Red	- Channel is in fault condition¹ V_{sup} is in range if field side power fault detection is enabled

¹ The channel is in the over-current state and/or the data has exceeded user-defined input limits.

Status	Color	Indication
OFF	None	- Channel is operational without input limits detection enabled V_{sup} is in range if field side power detection is enabled
		Master timebase is absent
Flashing	Green	- Channel is operational V_{sup} is out of range if field side power detection is enabled
	Red	- Channel is in fault condition¹ V_{sup} is out of range if field side power detection is enabled
Alternating flashing rows	Green	- Module is powered on - First acquisition is not initiated

Connecting an External Power Supply

You can connect an external power supply to the NI 9253. This power supply provides the current for the devices you connect to the module. Connect the positive lead of the power supply to a V_{sup} pin and the negative lead of the power supply to COM. Install a 2 A maximum, fast-acting fuse between the external power supply and the V_{sup} pin.



Note The V_{sup} pins are internally connected to each other. You can connect only one external voltage supply to the device.




Caution Do not remove or insert modules if the external power supply connected to the V_{sup} and COM pins is powered on.




Attention Ne retirez ou n'insérez pas de modules si l'alimentation externe connectée aux broches V_{sup} et COM est sous tension.

Connecting a Loop-Powered Current Transducer



Connecting a Three-Wire Current Transducer



NI 9253 Connection Guidelines

- Make sure that devices you connect to the NI 9253 are compatible with the module specifications.
- You must use 2-wire ferrules to create a secure connection when connecting more than one wire to a single terminal on the NI 9253 with spring terminal.
- Push the wire into the terminal when using a solid wire or a stranded wire with a ferrule.
- Open the terminal by pressing the push button when using stranded wire without a ferrule.

High-Vibration Application Connections

If your application is subject to high vibration, NI recommends that you use the NI 9963 backshell kit to protect connections to the NI 9253 with spring terminal.

You must follow these guidelines to meet the shock and vibration performance specifications stated in the device datasheet on ni.com/manuals.

- Panel mount the system.
- Provide strain relief for the module by securing the cabling to a supporting fixture no more than 8 cm (3 in.) away from the opening of the connector backshell.
- Ensure that the supporting fixture for strain relief is stiff and rigidly coupled to the chassis mounting surface.
- Ensure that you do not directionally bias the module when applying strain relief.


Overvoltage Protection

The NI 9253 provides overvoltage protection for each channel.



Note Refer to the device datasheet on ni.com/manuals for more information about overvoltage protection.

Where to Go Next



Located at ni.com/manuals



Installs with the software

Worldwide Support and Services

The NI website is your complete resource for technical support. At ni.com/support, you have access to everything from troubleshooting and application development self-help resources to email and phone assistance from NI Application Engineers.

Visit ni.com/services for information about the services NI offers.

Visit ni.com/register to register your NI product. Product registration facilitates technical support and ensures that you receive important information updates from NI.

NI corporate headquarters is located at 11500 North Mopac Expressway, Austin, Texas, 78759-3504. NI also has offices located around the world. For support in the United States, create your service request at ni.com/support or dial 1 866 ASK MYNI (275 6964). For support outside the United States, visit the *Worldwide Offices* section of ni.com/niglobal to access the branch office websites, which provide up-to-date contact information.

Information is subject to change without notice. Refer to the *NI Trademarks and Logo Guidelines* at ni.com/trademarks for information on NI trademarks. Other product and company names mentioned herein are trademarks or trade names of their respective companies. For patents covering NI products/technology, refer to the appropriate location: **Help»Patents** in your software, the `patents.txt` file on your media, or the *National Instruments Patent Notice* at ni.com/patents. You can find information about end-user license agreements (EULAs) and third-party legal notices in the readme file for your NI product. Refer to the *Export Compliance Information* at ni.com/legal/export-compliance for the NI global trade compliance policy and how to obtain relevant HTS codes, ECCNs, and other import/export data. NI MAKES NO EXPRESS OR IMPLIED WARRANTIES AS TO THE ACCURACY OF THE INFORMATION CONTAINED HEREIN AND SHALL NOT BE LIABLE FOR ANY ERRORS. U.S. Government Customers: The data contained in this manual was developed at private expense and is subject to the applicable limited rights and restricted data rights as set forth in FAR 52.227-14, DFAR 252.227-7014, and DFAR 252.227-7015.

© 2019 National Instruments. All rights reserved.

378060A-01 May 8, 2019

Artisan Technology Group is an independent supplier of quality pre-owned equipment

Gold-standard solutions

Extend the life of your critical industrial, commercial, and military systems with our superior service and support.

We buy equipment

Planning to upgrade your current equipment? Have surplus equipment taking up shelf space? We'll give it a new home.

Learn more!

Visit us at [artisanng.com](https://www.artisanng.com) for more info on price quotes, drivers, technical specifications, manuals, and documentation.

Artisan Scientific Corporation dba Artisan Technology Group is not an affiliate, representative, or authorized distributor for any manufacturer listed herein.

We're here to make your life easier. How can we help you today?

(217) 352-9330 | sales@artisanng.com | [artisanng.com](https://www.artisanng.com)

