ARTISAN®
TECHNOLOGY GROUP

Your **definitive** source for quality pre-owned equipment.

Artisan Technology Group
(217) 352-9330 | sales@artisantg.com | artisantg.com

Full-service, independent repair center
with experienced engineers and technicians on staff.

We buy your excess, underutilized, and idle equipment
along with credit for buybacks and trade-ins.

Custom engineering
so your equipment works exactly as you specify.

- Critical and expedited services
- In stock / Ready-to-ship
- Leasing / Rentals / Demos
- ITAR-certified secure asset solutions

Expert team | Trust guarantee | 100% satisfaction

All trademarks, brand names, and brands appearing herein are the property of their respective owners.

Find the *Rockwell / Allen-Bradley 1784-PCC B* at our website: *Click HERE*



Allen-Bradley

ControlNet Communication Card

1784-PCC

Installation Instructions

Rockwell Automation

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Important User Information

Because of the variety of uses for the products described in this publication, those responsible for the application and use of these products must satisfy themselves that all necessary steps have been taken to assure that each application and use meets all performance and safety requirements, including any applicable laws, regulations, codes and standards. In no event will Rockwell Automation be responsible or liable for indirect or consequential damage resulting from the use or application of these products.

Any illustrations, charts, sample programs, and layout examples shown in this publication are intended solely for purposes of example. Since there are many variables and requirements associated with any particular installation, Rockwell Automation does not assume responsibility or liability (to include intellectual property liability) for actual use based upon the examples shown in this publication.

Allen-Bradley publication SGI-1.1, *Safety Guidelines for the Application, Installation and Maintenance of Solid-State Control* (available from your local Rockwell Automation office), describes some important differences between solid-state equipment and electromechanical devices that should be taken into consideration when applying products such as those described in this publication.

Reproduction of the contents of this copyrighted publication, in whole or part, without written permission of Rockwell Automation, is prohibited.

Throughout this publication, notes may be used to make you aware of safety considerations. The following annotations and their accompanying statements help you to identify a potential hazard, avoid a potential hazard, and recognize the consequences of a potential hazard:

WARNING 	Identifies information about practices or circumstances that can cause an explosion in a hazardous environment, which may lead to personal injury or death, property damage, or economic loss.
ATTENTION 	Identifies information about practices or circumstances that can lead to personal injury or death, property damage, or economic loss.
IMPORTANT	Identifies information that is critical for successful application and understanding of the product.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Rockwell Automation Support

Before you contact Rockwell Automation for technical assistance, we suggest you please review the troubleshooting information contained in this publication first.

If the problem persists, call your local distributor or contact Rockwell Automation in one of the following ways:

Phone	United States/Canada	1.440.646.5800
	Outside United States/Canada	You can access the phone number for your country via the Internet: 1. Go to http://www.ab.com 2. Click on *Product Support* (http://support.automation.rockwell.com) 3. Under *Support Centers,* click on *Contact Information*
Internet	⇒	1. Go to http://www.ab.com 2. Click on *Product Support* (http://support.automation.rockwell.com)

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

ATTENTION



Environment and Enclosure

This equipment is intended for use in a Pollution Degree 2 industrial environment, in overvoltage Category II applications (as defined in IEC publication 60664-1), at altitudes up to 2000 meters without derating.

This equipment is considered Group 1, Class A industrial equipment according to IEC/CISPR Publication 11. Without appropriate precautions, there may be potential difficulties ensuring electromagnetic compatibility in other environments due to conducted as well as radiated disturbance.

This equipment is supplied as "open type" equipment. It must be mounted within an enclosure that is suitably designed for those specific environmental conditions that will be present and appropriately designed to prevent personal injury resulting from accessibility to live parts. The interior of the enclosure must be accessible only by the use of a tool. Subsequent sections of this publication may contain additional information regarding specific enclosure type ratings that are required to comply with certain product safety certifications.

See NEMA Standards publication 250 and IEC publication 60529, as applicable, for explanations of the degrees of protection provided by different types of enclosure. Also, see the appropriate sections in this publication, as well as the Allen-Bradley publication 1770-4.1 ("Industrial Automation Wiring and Grounding Guidelines"), for additional installation requirements pertaining to this equipment.

ATTENTION



Preventing Electrostatic Discharge

This equipment is sensitive to electrostatic discharge, which can cause internal damage and affect normal operation. Follow these guidelines when you handle this equipment:

- Touch a grounded object to discharge potential static.
- Wear an approved grounding wriststrap.
- Do not touch connectors or pins on component boards.
- Do not touch circuit components inside the equipment.
- If available, use a static-safe workstation.
- When not in use, store the equipment in appropriate static-safe packaging.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Summary of Changes

With this release of the 1784-PCC card, the Windows 2000 driver has been updated from version 1.0 to 1.6. The driver now supports the Windows XP Professional operating system. Throughout this document, references to Windows XP will describe the Windows XP Professional operating system.

To upgrade your driver from version 1.0 to 1.6, refer to Chapter 3 of this manual.

This document also includes updated RSLinx version requirements, as follows:

operating system	version of RSLinx
Windows XP/2000 with ControlNet Traffic Analyzer, v. 1.4	2.31 or later
Windows XP	2.30.01 or later (build 48 or later)
Windows 2000	2.20.01 or later

You will see change bars, as shown to the left of this paragraph, throughout this manual to help you quickly identify revisions.

Other information was revised extensively. For those chapters that contain all new information, or extensively revised information, you will find a change bar in the margin of the chapters.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Notes:

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Important User Information 2
Rockwell Automation Support. 3

Preface

About the Manual. 1
Audience 1
Conventions 1
Abbreviations 2

Chapter 1
About the 1784-PCC Card

What is in This Chapter? 1-1
What is PCMCIA? 1-1
What is a PC Card? 1-1
Architecture 1-2
What is the PCC Card? 1-3

Chapter 2
Pre-Installation Procedures

What is in This Chapter? 2-1
Verify Your Package Contents. 2-1
System Requirements 2-2
Find the 1784-PCC Driver 2-3

Chapter 3
Install and Use the 1784-PCC Card in Windows 2000/XP

What is in This Chapter? 3-1
Verify the RSLinx Version Number 3-2
Locate the 1784-PCC Windows 2000/XP Driver 3-2
Install the Driver 3-3
Hearing Multiple Tones. 3-3
1784-PCC Hardware Properties 3-8
Stop and Eject the 1784-PCC Card. 3-8
Unsafe Removal of Card 3-10
Remove the 1784-PCC Plug-and-Play Driver 3-11

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Troubleshoot the Card Installation 3-13
If ControlNet Traffic Analyzer is not working 3-16
Navigate to Device Manager 3-19
Update the 1784-PCC Plug-and-Play Driver Version 1.0 to Version 1.6 or Later 3-21
Show the Card Unplug/Eject Icon on the Taskbar 3-28

Chapter 4
Install and Use the 1784-PCC Card in Windows NT

What is in This Chapter? 4-1
Before You Begin. 4-1
Do You Have Any of the Following Third-Party Plug-and-Play PC Card Controller Software Installed? 4-3
Locate the 1784-PCC Driver for Windows NT. 4-5
Install the 1784-PCC Driver 4-5
Troubleshoot the Card Installation 4-11
Check for Resource Conflicts. 4-11
Run the 1784-PCC Configuration Utility for Windows NT . . 4-14
Remove the 1784-PCC Driver. 4-17

Chapter 5
Install and Use the 1784-PCC Card in Windows 95/98/Me

What is in This Chapter? 5-1
Locate the 1784-PCC Windows 95/98/Me Driver 5-2
Install the 1784-PCC Driver 5-2
Stop the Card 5-6
Remove and Uninstall the 1784-PCC Driver 5-6
Enable the PC Card Icon on the Taskbar 5-8
Troubleshoot the Card Installation 5-9

Chapter 6
Run the 1784-PCC Test Utility in Windows 2000/XP, NT 4.0, and 95/98/Me

What is in This Chapter? 6-1
Run the 1784-PCC Installation Test Utility 6-1

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Chapter 7
Insert and Remove the 1784-PCC Card

What is in This Chapter? 7-1
Insert the Card 7-1
Multiple Tones 7-3
Remove the Card 7-3

Chapter 8
Connect the 1784-PCC Card to the Network

What is in This Chapter? 8-1
Connect the Card to the ControlNet Network. 8-1
Communicate with the Card on the ControlNet Network 8-2

Appendix A
Specifications

Pin Assignments A-2

Glossary
Index

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Publication 1784-IN034D-EN-P - June 2002

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

About the Manual

Use this manual to install and use the ControlNet® PC card (PCMCIA interface), catalog number 1784-PCC. This interface enables a system to communicate on a ControlNet network.

Audience

The information in this manual is intended for users who are:

- familiar with Windows® XP, Windows® 2000, Windows NT™, Windows® Me, Windows 98®, Windows 95®
- experienced with one or more of these Allen-Bradley products: PLC-5®, ControlLogix, or SLC-500™ family of programmable controllers, or any other products that communicate with the PCC card
- experienced with ControlNet configuration software and the ControlNet network

Conventions

In this manual, anything that you can select, click on, or type on a screen is shown in **bold** type.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Abbreviations

Throughout this manual, we abbreviate some terms. Use the following table to become familiar with our terminology.

This abbreviation	Means
PCMCIA	Personal Computer Memory Card International Association.
IRQ	Interrupt Request
PC	Personal Computer.

IMPORTANT Driver and firmware versions that appear in the screen captures in this manual are not necessarily the latest version available. The version you use should be the version that appears in the screen capture or a later version.

In this document, we refer to the ControlNet PC card as the 1784-PCC card.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Chapter 1

About the 1784-PCC Card

What is in This Chapter?

Read this section to familiarize yourself with PC card technology and the 1784-PCC card. The following table describes what this chapter contains and where to find specific information.

For information about this topic:	See page:
What is PCMCIA?	1-1
What is a PC Card?	1-1
What is the PCC Card?	1-3

What is PCMCIA?

The Personal Computer Memory Card International Association (PCMCIA) developed a standard for credit-card size personal computer (PC) cards. The PCMCIA standard defines an architecture and communication method for these PC cards.

PC cards developed under Release 1.0 of the PCMCIA standard are used for data storage. PC cards developed under Release 2.0 of the PCMCIA standard can be used for both I/O and data storage.

What is a PC Card?


Since personal computers have become smaller, a need for smaller storage media developed. The PC card is a small form-factor adapter that can add memory, storage, and I/O capabilities to these smaller computers.

All PC cards measure the same length and width (54 mm x 85.6 mm), but differ in thickness at the center. The thickness at the connector end and along the rails is the same for all types of PC cards.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com


Architecture

Currently there are three types of PC cards:




Type I
3.3 mm thick

data storage, such as Flash memory cards



Type II
5.0 mm thick

I/O such as modem, LAN, and host communications (the Allen-Bradley 1784-PCD, -PCMK, and -PCC cards are Type II cards)




Type III
10.5 mm thick

data storage or I/O capabilities that require more space, such as rotating media and wireless communication devices

19911

IMPORTANT If the PCMCIA slot in your computer is thick enough to accommodate a Type III card, then it can also accommodate a Type I or II card.

All three types of PC cards use the same 68–pin connector. The pins are in two parallel rows of 34 pins. When inserted into the PCMCIA slot on your computer, the connector mates with a single molded socket.




19873

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

What is the PCC Card?

The ControlNet communication card (1784-PCC) allows you to connect a programming device to any intelligent device (i.e., workstation, PLC®, processor, scanner, or adapter) on a ControlNet network through the Network Access Port ( ).



IMPORTANT Your computer must be PCMCIA 2.1 compliant to support the 1784-PCC card. To verify that your computer is PCMCIA 2.1 compliant, see your computer's user manual.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Notes:

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Chapter 2

Pre-Installation Procedures

What is in This Chapter?

The following table describes what this chapter contains and where to find specific information.

Table 2.A


For information about this topic:	See page:
Verify Your Package Contents	2-1
System Requirements	2-2
Find the 1784-PCC Driver	2-3

Verify Your Package Contents


Be certain that you have these items before you discard any packing material. If an item is missing or incorrect, contact your local sales representative.




1784-PCC card



1784-PCC installation utility disk



1784-PCC1 cable



installation manual
(publication 1784-IN034)

30185-M

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

System Requirements

Refer to the following table for system requirements for using the 1784-PCC card.

operating system	Microsoft® Windows 2000/XP, NT 4.0, or 95/98/Me[1]
memory for computer resources	at least 8 MB
memory for card resources	4KB
IRQ	1 available IRQ
diskette drive	One 3.5" diskette drive
hard disk space	300K
PCMCIA slot	one Type II slot

[1] The listed versions of Microsoft Windows Operating Systems are the versions Rockwell Automation offically supports.

Refer to the following table for the version of RSLinx you will need for your operating system.

Operating System	Version of RSLinx
Windows XP/2000 with ControlNet Traffic Analyzer, v. 1.4	2.31 or later
Windows XP	2.30.01 (build 48) or later
Windows 2000	2.20.01 or later
Windows NT 4.0	2.00.97.30 or later
Windows 95/98/Me	2.00.97.30 or later

ATTENTION



Windows NT users: If you have a 1784-PCC series A interface card, you will need to perform a flash upgrade to upgrade to series B. Refer to Publication 1784-PCC-RN1 for details. To access this information, visit www.ab.com\support. Click on the PC Cards link and download the PCC_Upgrade.exe file. This file contains both the upgrade utility and the publication (1784-PCC-RN1) containing the instructions for completing the upgrade.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Find the 1784-PCC Driver

When you install drivers for your operating systems, you must be certain to install the correct files. Windows 95/98/Me systems require a Virtual Device Driver (VxD), which contains .inf and .vxd files. Windows NT requires an NT driver, which uses setup.exe, Unpccnt.exe and pcc_config.exe files. Windows 2000/XP requires a Windows Driver Model (WDM), which contains .inf and .sys files. Refer to the table below to be sure you are installing the correct driver files.

ATTENTION



Failure to install the correct driver files could result in unpredictable system operation.

Table 2.B

Source (where the driver is loaded from)	Driver location (for each operating system)		
	Windows 2000/XP	**Windows NT 4.0**	**Windows 95/98/Me**
installation disk, version 1.6[1] or later (shipped with the 1784-PCC card)	A:\Win2K\PccWdm.inf A:\Win2K\PccWdm.sys where A:\ is the floppy drive letter	A:\setup.exe A:\Unpccnt.exe A:\pcc_config.exe where A:\ is the floppy drive letter	A:\Rsipcc.inf A:\Rsipcc.vxd where A:\ is the floppy drive letter
RS-Linx product CD	E:\PnP_Drivers\Win2K\PccWdm.inf E:\PnP_Drivers\Win2K\PccWdm.sys where E:\ is the CD-ROM drive letter	Not distributed on RSLinx product CD	E:\PnP_Drivers\Win9x\Rsipcc.inf E:\PnP_Drivers\Win9x\Rsipcc.vxd where E:\ is the CD-ROM drive letter
internet	www.ab.com/support/products/pccards.html You can also access Rockwell Automation Knowledge documents at this site.		

[1] If your installation disk is earlier than version 1.6, we recommend downloading the latest version from www.ab.com/support/products/pccards.html.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Notes:

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Install and Use the 1784-PCC Card in Windows 2000/XP

What is in This Chapter?

Read this chapter to learn how to operate the 1784-PCC card on Windows 2000/XP. The following table describes what this chapter contains and where to find specific information.

Table 3.A

For information about this topic:	See page:
Verify the RSLinx Version Number	3-2
Locate the 1784-PCC Windows 2000/XP Driver	3-2
Install the Driver	3-3
1784-PCC Hardware Properties	3-8
Stop and Eject the 1784-PCC Card	3-8
Remove the 1784-PCC Plug-and-Play Driver	3-11
Troubleshoot the Card Installation	3-13
Update the 1784-PCC Plug-and-Play Driver Version 1.0 to Version 1.6 or Later	3-21
Show the Card Unplug/Eject Icon on the Taskbar	3-28

In order to follow the instructions in this chapter, you must:

- have Windows 2000/XP loaded
- have the Windows 2000/XP driver for the PCC card

IMPORTANT You can have one 1784-PCC card configured in Windows 2000/XP. If you insert more than one 1784-PCC card into your PC, only one of the cards will be available for use.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

TIP



In this chapter, we show Windows 2000 screens. If you are installing Windows XP, the installation screens you see will be substantially similar.

Verify the RSLinx Version Number

Refer to the following table for the correct version number of RSLinx for your operating system.

Operating System	Version of RSLinx
Windows XP	2.30.01 (build 48) or later
Windows XP/2000 with ControlNet Traffic Analyzer, v. 1.4	2.31 or later
Windows 2000	2.20.01 or later

Locate the 1784-PCC Windows 2000/XP Driver

When you install drivers for your operating systems, you must be certain to install the correct files. Windows 2000/XP systems require a Windows Driver Model (WDM), which contains .inf and .sys files. Refer to the table below to be sure you are installing the correct driver files.

ATTENTION



Failure to install the correct driver files could result in unpredictable system operation.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Table 3.B

Source (where the driver is loaded from)	Driver location (for Windows 2000/XP operating systems)
installation disk, version 1.6[1] or later (shipped with the 1784-PCC card)	A:\Win2K\PccWdm.inf A:\Win2K\PccWdm.sys where A:\ is the floppy drive letter
RSLinx product CD	E:\PnP_Drivers\Win2K\PccWdm.inf E:\PnP_Drivers\Win2K\PccWdm.sys where E:\ is the CD-ROM drive letter
internet	www.ab.com/support/products/pccards.html You can also access Rockwell Automation Knowledge documents at this site.

[1] If your installation disk is earlier than version 1.6, we recommend downloading the latest version from www.ab.com/support/products/pccards.html.

Install the Driver

Follow the instructions in Chapter 7 to insert your card in your laptop.


IMPORTANT Before you can install the driver for the 1784-PCC card, you must be logged in as an administrator of the machine. Being an administrator gives you permission to install or make changes to the machine software. If you try to install the driver without being an administrator, you will get error messages and the driver will not install.

Hearing Multiple Tones

If you insert multiple PC Cards, you may hear more than one tonal notification per card. Windows 2000/XP detects devices during the power up process, and adjusts the device resources accordingly. This results in sounding multiple tones. When the system changes settings (for example, when removing a card), the tones will sound again for each change.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

1. After you insert the PCC card, the system detects the hardware and begins to build the driver information needed to run the hardware. Because the driver has not been loaded, Windows 2000/XP displays a new hardware dialog box and the following message:



Windows 2000/XP displays:




2. Click **Next**.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Windows 2000/XP displays:



3. Select the **Search for a suitable driver for my device** radio button and click **Next**.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

At this point you need to select where the file is located.

4. Select one of the following checkboxes:

   •**Floppy disk drives** if you are going to use the floppy that ships with the 1784-PCC card


   •**CD-ROM drives** if you are going to get the file from the RSLinx CD-ROM

   •**Specify a location** if you downloaded the driver file from www.ab.com.

Table 3.C

If you select:	Then:
Floppy disk drives	insert the PnP drivers disk into the drive and click **Next**. Windows 2000/XP will search for the appropriate driver. Continue with Step 6.
CD-ROM drives	insert the RSLinx CD into the drive and click **Next**. Windows 2000/XP will search for the appropriate driver. Continue with Step 6.
Specify a location	use this selection if you have downloaded the driver from www.ab.com. You will be prompted for the location path of the driver. Click **Next** and Continue with Step 5.


5. If you select the **Specify a location** radio button in Step 4, Windows 2000/XP will prompt you to provide a location for the driver, as shown below:




   Type the location of the Windows 2000/XP driver and click **Ok**.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

6. Click **Next**.



7. Once Windows 2000/XP installs the driver, the following displays.



8. Click **Finish**.
   You may be prompted to restart you computer for the driver to take effect.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

9. Run the 1784-PCC test utility as described in Chapter 6 to verify the installation. If the test utility fails, refer to Troubleshoot the Card Installation on page 3-13.

1784-PCC Hardware Properties

Windows 2000/XP provides properties dialog boxes for removable devices. The properties dialog boxes provide the following:

- general information such as device status, manufacturer and card location
- device driver information such as driver version and buttons for you to uninstall and update the driver
- resource information such as interrupt request settings and memory range settings

We recommend you verify that the card is running properly after you install the 1784-PCC card and the driver. Refer to Troubleshoot the Card Installation on page 3-13.

Stop and Eject the 1784-PCC Card

Before you remove the PCC card from its slot, you need to stop the communication to the card. To stop the card:

1. Double-click on the **Unplug/eject Hardware icon** on your taskbar.




.

TIP

If you don't have the icon on your taskbar, refer to Show the Card Unplug/Eject Icon on the Taskbar on page 3-28.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2. Click on the PCC card you want to stop.




3. Click **Stop**.
4. When you see the window that states you may safely remove this device, click **Ok**.
5. Remove the card.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Unsafe Removal of Card

If you do not stop the communication to your card before you remove a card from your computer, Windows 2000/XP displays:



1. To stop the card, refer to Stop and Eject the 1784-PCC Card on page 3-8.

IMPORTANT Use the Unplug/eject icon on the taskbar to insure you do not damage your card.

2. Once you have stopped the card, use the Unplug/eject icon on the taskbar to remove the card.


Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Remove the 1784-PCC Plug-and-Play Driver

Follow this procedure to remove the 1784-PCC driver.

1. Double-click on the **Unplug/eject hardware** icon  in the taskbar.


TIP If you don't have the icon on your taskbar, refer to Show the Card Unplug/Eject Icon on the Taskbar on page 3-28.



2. Select the card.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3. Click **Properties**.



4. Click the **Drivers** tab.

5. Click **Uninstall**.

6. Press **Enter** or click **Ok**. You see this screen:



7. Press **Enter** or click **Ok** to confirm device removal.

8. Remove the 1784-PCC card from your system.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com


Troubleshoot the Card Installation

To access Hardware Properties and verify that the 1784-PCC card is working properly, follow the steps below.

1. Double-click on the Unplug/eject hardware icon  in the taskbar.

TIP

If you don't have the icon on your taskbar, refer to Show the Card Unplug/Eject Icon on the Taskbar on page 3-28.



2. Select the card.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3. Click **Properties**.





Table 3.D

If:	Then:
the Device status field says "This device is not present, not working properly, or does not have all drivers installed."	click on the **Resources** tab and check the Conflicting Device list for possible hardware conflicts, or you may want to try disabling the **Automatic Settings** option. Refer to Click on the Resources tab. on page 3-15.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4. Click on the **Resources** tab.



TIP

The majority of the time, we recommend that you use the automatic settings. The card will assign an interrupt (memory location) for you. An interrupt must be assigned to the 1784-PCC card. Verify that there is an interrupt assigned and no resource conflicts display in the Conflicting Device list.

5. In the unlikely event that you have a resource conflict, you may need to assign a specific interrupt to free the resource for another device. To manually assign an interrupt:
   a. Deselect (uncheck) the **Use automatic settings** checkbox.
   b. Click on **Interrupt Request**.
   c. Click **Change Setting**... and select an interrupt location.

TIP

Most systems have 15 interrupt locations available for you to assign. If you have more than 15 devices that need an interrupt location, you may need to disable another device, such as an unused serial or parallel port to make an interrupt available for the PCC card.

   d. In some cases, a device other than the 1784-PCC card may be determined to use the interrupt that the PCC card wants. If this happens, let the other device have the interrupt and assign the 1784-PCC card another interrupt location.


Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

If ControlNet Traffic Analyzer is not working

Follow this procedure to ensure the ControlNet Traffic Analyzer is working properly.

1. Double-click on the Unplug/eject hardware icon  in the taskbar.


TIP If you don't have the icon on your taskbar, refer to Show the Card Unplug/Eject Icon on the Taskbar on page 3-28.



2. Select the card.


Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3. Click **Properties**.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4. Click on the Driver tab.




5. If the driver is at Version 1.0, update to Version 1.6. Refer to Update the 1784-PCC Plug-and-Play Driver Version 1.0 to Version 1.6 or Later on page 3-21.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com


Navigate to Device Manager

Here is a second way to find your way to the hardware properties so you can verify that your card is working properly.

1. Right-click on **My Computer**.
2. Select **Manage**.




3. On the Computer Management window that appears, select **Device Manager**.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4. Click on the **+** next to **Allen-Bradley PCMCIA** to display the available Allen-Bradley cards.

IMPORTANT If you insert two PCC cards, only one of the cards that you insert is available for use. The Device Manager windows looks like this:




The card that displays this icon

! Allen-Bradley 1784-PCC Series B is unavailable for use. We do not recommend that you have more than one 1784-PCC card installed in your system.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com


5. Double-click on **1784-PCC Series B**.



Update the 1784-PCC Plug-and-Play Driver Version 1.0 to Version 1.6 or Later


Perform these steps if you need to update the driver.

1. Right-click on **My Computer**.
2. Select **Properties**.
3. Select **Hardware**.
4. Select **Device Manager**.
5. Select **Allen-Bradley PCMCIA Family** to expand it.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

6. Double-click **Allen-Bradley 1784-PCC Series B** to bring up its Properties screen. Select the **Driver** tab.




7. Click **Update Driver**.




Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

8. Click **Next**. Select **Display a list of the known drivers for this device...** and click **Next**.




9. Click **Have Disk...**




Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

10. Insert the 1784-PCC driver installation diskette into your floppy disk drive You see the **Install From Disk** dialog box.



11. Click **Browse**. You see the **Locate File** screen.




IMPORTANT If you are installing from anything other than a floppy diskette, browse to the **Win2K** directory and select the driver.

12. Select the **PccWdm.ini** file.


13. Click **Open**.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

14. On the **Install From Disk** dialog box, click **OK**.




15. Click **Next.**




Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

16. Click **Next.**




17. Click Next.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com


18. Click **Finish**.

19. On the **Allen-Bradley 1784-PCC Series B Properties** screen, verify that the driver version is at 1.6.0.0.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

20. Click **Driver Details**. Verify the Driver file is at version 1.6.



Show the Card Unplug/Eject Icon on the Taskbar

If you frequently need to unplug the device, be sure to check the Show Unplug/Eject icon on the taskbar checkbox on the Completing the Add/Remove Hardware wizard screen. You can check the box the first time you install the card. The next time you want to unplug or eject the device, you can use the icon on the taskbar instead of the Add/Remove Hardware wizard.

If the icon is not on your taskbar, you can find the checkbox in the Add/Remove Hardware Wizard. You must finish the process of removing the card from the slot in order for the checkbox to take effect. You are not given the opportunity to back out of the hardware Wizard once you get to the location of the checkbox.

1. Double-click **My Computer**.
2. Double-click **Control Panel**.
3. Double-click **Add/Remove Hardware**.
4. Click **Next**.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

5. Check **Uninstall/Unplug a device** and click **Next**.
6. Check **Unplug/Eject a device** and click **Next**.
7. Select the **1784-PCC card** and click **Next**.
8. Confirm the device and click **Next**.
9. Check the **Show Unplug/Eject icon** on the taskbar.
10. Click **Finish**.
11. Remove your card.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Notes:

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Install and Use the 1784-PCC Card in Windows NT

What is in This Chapter?

Read this chapter to learn how to operate the 1784-PCC card on Windows NT. The following table describes what this chapter contains and where to find specific information.

Table 4.A

For information about this topic:	See page:
Locate the 1784-PCC Driver for Windows NT	4-5
Install the 1784-PCC Driver	4-5
Troubleshoot the Card Installation	4-11
Remove the 1784-PCC Driver	4-17

Before You Begin

Read the following **before** you install your 1784-PCC card, Series B or later.

ATTENTION



If you have a 1784-PCC series A interface card, you will need to perform a flash upgrade to upgrade to series B. Refer to Publication 1784-PCC-RN1 for details. To access this information, visit www.ab.com\support. Click on the PC Cards link and download the PCC_Upgrade.exe file. This file contains both the upgrade utility and the publication (1784-PCC-RN1) containing the instructions for completing the upgrade.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

ATTENTION



The 1784-PCC series B interface card and NT Driver are designed for use in notebook PCs equipped with NT 4.0 from the original manufacturer and certified by Microsoft.

If your PC is not certified, it may not be compatible for use with the 1784-PCC series B card under NT 4.0.

.

IMPORTANT

Before you can install the driver for the 1784-PCC/B card, you must be logged in as an administrator of the machine. Being an administrator gives you permission to install or make changes to the machine software. If you try to install the driver without being an administrator, you will get error messages and the driver will not install.

- You must be running Windows NT 4.0 with Service Pack 3 or later.
- You can use only one 1784-PCC card at a time in Windows NT.
- You must have RSLinx 2.00.97 or greater.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Do You Have Any of the Following Third-Party Plug-and-Play PC Card Controller Software Installed?

If	Then
you do have third-party plug-and-play PC card controller software	a PC card icon (circled in this illustration) will appear on the Windows task bar 
you do not have third-party plug-and-play PC card controller software	go to page 4-5 and continue with the driver installation.

TIP

To find the version of your third-party plug-and-play software, you can usually do the following:

1. Double-click on the PC card icon in the taskbar.
2. When a dialog box appears, click **Help** ⇒**About**.

SystemSoft's CardWizard

The 1784-PCC Windows NT driver does not work with SystemSoft's CardWizard versions prior to 5.10.06.

If you have SystemSoft's CardWizard, you must upgrade the PC Card Controller Software to version 5.10.06 or later for the 1784-PCC driver to function.

For more information on obtaining the CardWizard upgrade for use with the 1784-PCC card, contact your computer manufacturer or SystemSoft:

- Internet: www.systemsoft.com
- Phone: 1.800.796.0088 or 508.651.0088 (ask for sales)

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Phoenix/Softex's Card Executive

If you have Phoenix/Softex's Card Executive, you must upgrade the PC Card Controller Software to version 2.35 or later for the 1784-PCC Driver to function.

For more information on obtaining the Card Executive upgrade for use with the 1784-PCC card, contact your computer manufacturer or Phoenix/Softex:

- Internet: www.phoenix.com
- Phone: 1.800.677.7305



If you have a version of Card Executive between 2.24 and 2.35, contact Rockwell Automation Technical Support at 440.646.5800 for a free patch.

IMPORTANT When using Card Executive, do not access the Windows Control Panel (**Start ⇒Settings ⇒Control Panel**; double-click the **PC card icon**). Instead, access the Phoenix/Softex Control Panel by double-clicking the **PC card icon** in the taskbar.

Touchstone/Unicore's CardWare

Contact your computer manufacturer for the recommended version.

For more information, contact Unicore:

- Internet: www.unicore.com/products/CardWare/CardWarent.cfm
- Phone: 978.686.6468

IMPORTANT The PCC_Config utility (described on page 4-11) does not work with CardWare. If you have an unresolved resource conflict, contact your computer manufacturer.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Locate the 1784-PCC Driver for Windows NT

When you install drivers for your operating systems, you must be certain to install the correct files. Windows NT systems require an NT Driver. Refer to the table below to be sure you are installing the correct driver files.

ATTENTION



Failure to install the correct driver files could result in unpredictable system operation.

Table 4.B

Source (where the driver is loaded from)	Driver location (for Windows NT operating systems)
installation disk, version 1.6[1] or later (shipped with the 1784-PCC card)	A:\setup.exe A:\Unpccnt.exe A:\pcc_config.exe where A:\ is the floppy drive letter
internet	www.ab.com/support/products/pccards.html You can also access Rockwell Automation Knowledge documents at this site.

[1] If your installation disk is earlier than version 1.6, we recommend downloading the latest version from www.ab.com/support/products/pccards.html.

Install the 1784-PCC Driver

Follow the procedure below to install the Windows NT driver for the 1784-PCC/B card.

IMPORTANT

You are required to insert the 1784-PCC card in order for the installation to work properly. We recommend that you insert the 1784-PCC card only when your system is not powered. Once you have installed the driver and you insert the 1784-PCC card into the slot, we do not recommend that you remove the 1784-PCC card while Windows NT is running.

1. Start the install process with your machine off.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2. Insert the 1784-PCC/B card.
3. Turn your machine on and log on with administrative rights.


IMPORTANT Remember, in order for the installation process to run correctly, you must have administrator privileges to install the software.

We strongly recommend that you exit all Windows programs before running this utility. We cannot guarantee that data will not be lost.

If	Then
you do have third-party plug-and-play PC card controller software	go to Step 4 on page 4-6
you do not have third-party plug-and-play PC card controller software	go to Step 5 on page 4-8

4. If you have third-party plug-and-play PC card controller software, do the following. otherwise, skip to Step 5 on page 4-8.

- If you have Phoenix/Softex's Card Executive on your system, you may see the following message:



If you get this message, do the following:


a. Choose the **Do not install any driver for this card** radio button.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

b. Check the **Do not display this dialog for the PC card again** checkbox.


c. Press **Enter** or click **Ok**. You still need to install the driver. Continue on with this procedure.

- If you have SystemSoft's CardWizard, you may get the following message. Click **Exit**.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

- If you have Unicore's CardWare, you may get the following message. Click **Done**.




TIP

Be sure to click **Done** at this screen. If you do not, you will see this screen every time you reboot your pc.

5. Insert the installation diskette into the floppy disk drive.
6. Access the Run window by selecting **Start** ⇒**Run**.
7. In the Run dialog box, type the path

   A:\setup.exe.


   where A:\ is the drive letter of your floppy disk drive.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

8. Press **Enter** or click **Ok**.

   You see:



IMPORTANT If you have programs running, click **Cancel** to exit the installation process and exit the programs. After you exit the programs, re-start the install process.


9. If you have CardWare installed, you may see the following screen. Press **Enter** or click **Ok** to continue with the installation.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

10. Click **Ok**.

When this portion of the installation is complete, you see:




11. Remove the driver installation diskette from your floppy drive.

12. Select **Yes** or click **Ok** to reboot your system.

IMPORTANT Wait for the logon screen to appear. Do not log on. Depending on the speed of your machine, your wait could be 5 minutes or more.

13. Ignore any third-party plug-and-play software messages that may appear here.

14. Click **Ok**. Your system will automatically reboot. The driver installation is complete.



IMPORTANT If you have Touchstone/Unicore's CardWare, you may see a screen that tells you the driver has not been started. Click Yes to start the driver.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

15. Run the 1784-PCC test utility as described in Chapter 6 to verify the installation.

    If installation fails, refer to Troubleshoot the Card Installation on page 4-11.

Troubleshoot the Card Installation

Use the following sections to determine why the test utility failed.

Check for Resource Conflicts

When you run the PCC setup utility in Windows NT, the utility tries to assign free resources to the PCC card. If your card used to work, and has now stopped working, it is probably because the resources originally assigned to the card are now being used by another device you recently added, such as an Ethernet card. Try re-running the card's setup utility. Refer to Locate the 1784-PCC Driver for Windows NT on page 4-5. The utility may be able to automatically find other resources to assign to the card.

If you do this, and the test utility still fails, you will need to check for resource conflicts. Possible conflicts include IRQ, memory, or I/O conflicts. To view and change your resource locations, you will need to view all of your resource allocations to determine which resouces are free.

To access and change resouce locations:


1. Do one of the following:

   - access Windows NT diagnostics (**Start ⇒Programs ⇒Administrative Tools ⇒Windows NT Diagnostics**), or
   - Select **Start ⇒Run** and type **WINMSD** in the Run dialog box. Press **Enter** or click **Ok**.

2. To determine if you have an IRQ conflict, click on the **Resources** tab.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

You see:




3. View your resource assignments.

If you have any devices that have the same IRQ location, run the PCC Configuration Utility described on page 4-14 and change the IRQ location of the PCC card.

If there are no IRQ conflicts, you might have a Memory or an I/O conflict.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4. To determine if you have a memory conflict, click the **Memory** button.




5. View your resource assignments.

If you have any devices that have the same memory location, run the PCC Configuration Utility described on page 4-14 and change the memory location of the PCC card.

If there are no memory conflicts, you might have an I/O conflict.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

6. To determine if you have an I/O conflict, click the I/O port button.



7. View your I/O assignments.

   If you have any devices that have the same I/O location, run the 1784-PCC configuration utility described on page 4-14 and change the I/O location of the 1784-PCC card.


Run the 1784-PCC Configuration Utility for Windows NT

To view and change your PCC card resource configurations, run the configuration utility that we provide on the installation utility disk.

IMPORTANT The PCC_Config utility does not work with CardWare. If you have an unresolved resource conflict, contact your computer manufacturer.


Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

1. Select **Start** ⇒**Run**.



2. In the window that appears, type **pcc_config.exe** and press **Enter** or click **Ok**. The utility runs.

   The configuration utility displays:



At this point you can view your card's current settings. You can change the card's memory address and interrupt request.

TIP

We recommend that you only make the changes if you have another device that needs a dedicated address and/or the interrupt is the same as the PCC card's installation default. We do not recommend that you change these settings unless absolutely necessary. Simply use the defaults that the system assigns to the card.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Figure 4.1 Example of new interrupt request drop down selections






Figure 4.2 Example of new memory address drop down selections




Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Figure 4.3 Example of new I/O drop-down selections



If you change the settings and click **Ok**, you need to restart your computer for the new settings to take effect.



Remove the 1784-PCC Driver

You can access the uninstaller through the Windows NT Add/Remove programs applet to remove the card's drivers from your system.


TIP

In addition to the following procedure, you can also use the unpccnt.exe utility provided with the 1784-PCC driver to uninstall the 1784-PCC card.

1. Access the Control Panel by selecting **Start ⇒Settings ⇒Control Panel**.
2. Double-click the **Add/Remove Programs** icon.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3. Select **Allen-Bradley 1784 PCC Driver**.



4. Click the **Add/Remove** button.

   You see:



   You do not have to remove the card. The system gives you the opportunity to cancel the operation before deleting any files.

5. Click **Ok** to uninstall the driver.

6. Close the Control Panel.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Chapter 5

Install and Use the 1784-PCC Card in Windows 95/98/Me

What is in This Chapter?

Read this chapter to learn how to operate the 1784-PCC card on Windows 95/98/Me. The following table describes what this chapter contains and where to find specific information.

Table 5.A

For information about this topic:	See page:
Locate the 1784-PCC Windows 95/98/Me Driver	5-2
Install the 1784-PCC Driver	5-2
Stop the Card	5-6
Remove and Uninstall the 1784-PCC Driver	5-6
Enable the PC Card Icon on the Taskbar	5-8
Troubleshoot the Card Installation	5-9

IMPORTANT The screen captures in this chapter are taken from Windows 95/B. If you are using another version of Windows 95,98, or Me, your screens may be different.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Locate the 1784-PCC Windows 95/98/Me Driver

When you install drivers for your operating systems, you must be certain to install the correct files. Windows 95/98/Me systems require a Virtual Device Driver (VxD), which contains .inf and .vxd files. Refer to the table below to be sure you are installing the correct driver files.

ATTENTION



Failure to install the correct driver files could result in unpredictable system operation.

Table 5.B

Source (where the driver is loaded from)	Driver location (for Windows 95/98/Me operating systems)
installation disk version 1.6[1] (shipped with the 1784-PCC card)	A:\Rsipcc.inf A:\Rsipcc.vxd where A:\ is the floppy drive letter
RS-Linx 2.20.01 or later product CD	E:\PnP_Drivers\Win9x\Rsipcc.inf E:\PnP_Drivers\Win9x\Rsipcc.vxd where E:\ is the CD-ROM drive letter
internet	www.ab.com/support/products/pccards.html You can also access Rockwell Automation Knowledge documents at this site.

[1] If your installation disk is earlier than version 1.6, we recommend downloading the latest version from www.ab.com/support/products/pccards.html.


Install the 1784-PCC Driver

Follow the procedures below to install the Windows 95/98/Me driver for the 1784-PCC Series A or B card.

1. In Windows 95/98/Me, insert the card into the PCMCIA slot by following the directions in Chapter 7.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

After you insert the PCC card, the system detects the hardware and begins to build the driver information needed to run the hardware. Because the driver has not been loaded, Windows 95/98/Me displays a new hardware dialog box and the following message:



You see:



2. Insert the installation disk into the floppy disk drive.

3. Click **Next** to begin the install.

   You see a message telling you that the system is searching for a driver for the new device.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Once Windows 95/98/Me finds the driver, you should see:



ATTENTION



If you do not see the message that Windows has found a driver (as shown in the screen above), click the **Other Locations** button on the screen and select the appropriate 95/98/Me driver. Refer to the table on page 5-2 for the correct driver file to install.

4. Click **Finish** to install/upgrade the driver.


   You may see the following message:



   a. If you have not already done so, insert the diskette into the floppy disk drive and press **Enter** or click **Ok**.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

You see:



2. In the Copy files from box, specify the drive (usually **A:**\) that corresponds to your floppy disk drive.
3. Press **Enter** or click **Ok**.


After the system has finished copying files, you should hear two upward tones that indicate the card is ready to use. If you do not hear these tones, check to see that your speakers/sound are enabled.

5. Run the 1784-PCC test utility as described in Chapter 6 to verify your installation. If the test fails, refer to the section entitled Troubleshoot the Card Installation on page 5-9 of this manual.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Stop the Card

In Windows 95/98/Me, before you remove the 1784-PCC card from its sockets, you should stop the communication to it. To do this:



1. Click with your right mouse button on the PC Card icon in the taskbar. If the icon is not there, refer to the section entitled Enable the PC Card Icon on the Taskbar on page 5-8 of this manual.

2. Select **Adjust PC Card Properties**.
3. In the list of PC cards, click on the 1784-PCC card you want to stop.
4. Click **Stop**.
5. When you see the window that states that you may safely remove this device, press **Enter** or click **Ok**.
6. Remove the 1784-PCC card from the PCMCIA slot.

Alternately, to stop the card, you can do the following:

1. Click with your left mouse button on the PC Card icon in the taskbar.
2. Click on the 1784-PCC card you want to stop in the list of PC cards.
3. Click **Stop**.
4. When you see the window that states that you may safely remove this device, press **Enter** or click **Ok**.

Remove and Uninstall the 1784-PCC Driver

You can access the uninstaller through the Windows 95/98/Me Add/Remove programs applet to remove the card's driver from your system.


1. Stop the PCC card as described on page 5-6.
2. Access the Control Panel by selecting **Start ⇒Settings ⇒Control Panel**.
3. Double-click on the **Add/Remove Programs** icon.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4. Select **Allen-Bradley 1784-PCC Driver**.



5. Click the **Add/Remove** button.
   You see:



6. Remove the 1784-PCC card before continuing. The system gives you the opportunity to cancel the operation before deleting any files.

7. Press **Enter** or click **Ok** to remove the driver.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Enable the PC Card Icon on the Taskbar

The PC card icon in the Taskbar lets you know the status of your PC card, and lets you stop processing before you remove or change PC cards. You can display this icon within the Taskbar on your Windows 95/98/Me desktop. You will see this icon only when there is one or more PC card(s) installed in the computer.

To set up the PC card icon within the Taskbar:

1. Access the Control Panel by selecting **Start ⇒Settings ⇒Control Panel**.
2. Double-click the **PC card (PCMCIA)** icon.

TIP

If you find no PC card icon in the Control Panel, this could be an indication that the PCMCIA socket hardware or drivers were not installed properly. This situation prevents Windows 95/98/Me from locating the PC card. To resolve this problem, contact the computer manufacturer.


3. When the PC card Properties dialog box appears, click **Show control on the taskbar**.



If you do not see these dialog boxes, contact the computer manufacturer.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com


4. Press **Enter** or click **Ok**. The PC card icon appears in the Taskbar.



Troubleshoot the Card Installation

To resolve card installation issues:

1. Insert your 1784-PCC card into your system.
2. Click the **My Computer** icon with the right mouse button.
3. Select **Properties** from the menu. The System Properties dialog box appears.



4. Click the **Device Manager** tab.


   All of the devices within the system are displayed.

5. Scroll through the devices and search for the Allen–Bradley PCC Family line.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

If this line has a plus sign, click the plus sign to expand the item.

The Allen-Bradley 1784-PCC card should be listed.




6. Select the **Allen-Bradley Company, Inc. 1784-PCC card**.

7. Click the **Properties** button.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com


You see:



If Code 10 (conflicting memory resources) is reported in the Device status dialog box, continue with the following steps.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

8. In the Properties dialog box, click the **Resources** tab.



Verify that there are no resource conflicts listed in the Conflicting Device list. You also should verify that you have assigned an interrupt to the 1784-PCC card. If you have not, then you need to do so. You may have to disable a device to make an interrupt available.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

9. If there are conflicts, you may need to alter the settings of devices involved in the conflict to get the 1784-PCC card to function properly.

   Try unchecking the **Use automatic settings** box and then changing the conflicting I/O, interrupt, or memory resources.

IMPORTANT The option of unchecking the **Use automatic settings** box is Not always available in Windows 98. It depends on how the operating system was installed and configured.

If there are no conflicts, continue with the following steps.

10. Return to the Device Manager and scroll through the list to find PCMCIA sockets.

11. Double-click **PCMCIA sockets** to expand it.

12. Click on the **PCMCIA controller** used by your system.

13. Click **Properties**. Verify that the socket controller is enabled in the hardware profile you are using.

If	Then
the device status says, "This device is not present, not working properly, or does not have all drivers installed, code 10."	• click the **Resources** tab and check the Conflicting Device list for possible hardware conflicts; or you may want to verify that the **Use Automatic Settings** option is enabled. • you may have a general PCMCIA problem. You should contact your computer manufacturer for a resolution.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Notes:

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Chapter 6

Run the 1784-PCC Test Utility in Windows 2000/XP, NT 4.0, and 95/98/Me

What is in This Chapter?

Read this chapter to learn how to run the 1784-PCC test utility. The following table describes what this chapter contains and where to find specific information.

Table 6.A

For information about this topic:	See page:
Run the 1784-PCC Installation Test Utility	6-1

In order to follow the instructions in this chapter, you must:


- have Windows 95/98/Me, NT 4.0, or 2000/XP loaded.
- have the appropriate drivers loaded for the PCC card

Run the 1784-PCC Installation Test Utility

The installation test utility is compatible with Windows 95/98/Me, NT 4.0, and 2000/XP. To test your installation, run the utility that we provide on the installation utility disk.


Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

1. Select **Start** ⇒**Run**.



2. In the window that appears, type **A:\Pcc_test.exe** and press **Enter** or click **Ok**.


   a. If you choose **Browse** on the A:\ drive, you will see:




   b. Double-click on the **Pcc_test.exe** file to start the PCC test utility.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

The utility runs through a series of tests.





The 1784-PCC installation test utility automatically looks for your card and begins the tests. As the tests are completed, a green check mark appears, illustrating that the particular test was successful.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

If there is an error, you will see a red X and an explanation.






.

Table 6.B

If you:	Then:
do not see six green check marks or you do not see the message stating that the 1784-PCC completed all tests successfully	• In Windows NT 4.0, run the setup utility again and restart your computer. • In Windows 95/98/Me and 2000/XP, go to Device Manager and adjust resources.
are still getting an error	• Review the chapter for your operating system. • Follow the instructions again. If you are still having problems, contact your Rockwell Automation service representative for assistance. • Refer to the Preface of this manual for information on Rockwell Automation Support.


Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3. Once the tests are finished and successful, you see:



4. Click **Yes** or **No**.

When you click Yes and you are properly connected to your network, the test utility will browse your network to find active nodes. You will see a node table with the active nodes checked.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com


5. Click **Ok**.

The utility also provides information about:

- NUT (Network Update Time, in msecs)
- maximum scheduled node
- maximum unscheduled node
- slot time (µsecs)

IMPORTANT Be certain that the address assigned to the PCC card in RSLinx is less than the Maximum Unscheduled Node shown in the PCC test utility.

If you see this screen, check to see if the cable is connected properly to your network.



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Chapter 7

Insert and Remove the 1784-PCC Card

What is in This Chapter?

Read this chapter to understand how to insert and remove the card from your laptop computer. The following table describes what this chapter contains and where to find specific information.

Table 7.A

For information about this topic:	See page:
Insert the Card	7-1
Remove the Card	7-3

Insert the Card

IMPORTANT


Windows 2000/XP: If you are using Windows 2000/XP, you can insert the card while the system is on and use the eject utility to turn off communication to the card before you remove it from your computer.

Windows NT 4.0: If you are using Windows NT 4.0, shut down the computer before inserting or removing the card.


Windows 95/98/Me: If you are using Windows 95/98/Me, you can insert or remove the 1784-PCC card from a powered computer.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

TIP The following diagrams show a PCMCIA 2.1 compliant system. If you are using another computer, your installation may be slightly different.




1. Open the door to the PCMCIA slot. Some slots do not have doors.



2. Grasp the card by the edges with the logo facing upward and the 68-pin connector facing into the PCMCIA slot.

IMPORTANT If you have more than one slot in your computer, you can insert the 1784-PCC card into any empty slot. Check your computer's documentation for the slot numbers. You can use the other available slots for other PC cards such as network or modem cards.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com



3. Insert the card into the PCMCIA slot and slide the card in until it is firmly seated in the connector. Some computers have an ejector button that pops out when the card is seated in the connector.

If the computer is configured properly, your sound/speaker is enabled, and you installed the 1784-PCC card successfully, you hear multiple tones when you insert a card or boot the computer.

Multiple Tones

If you insert multiple PC cards, you may hear more than one tonal notification per card. Windows 95/98/Me and 2000/XP detect devices during the power-up process, and adjusts the device resources accordingly. This results in sounding multiple tones. When the system changes settings, for example, when a card is removed, the tones will sound again for each change.

Remove the Card

IMPORTANT You should stop any software communicating with the card before removing the PC card. If you do not do this, the stray processes may halt the system's performance.

On most computers, you press the release button and remove the card from the slot. If this is not applicable to your computer, follow the instructions specified in your computer user manual.

You hear multiple tones for each card that you remove if your system is configured properly. These tones indicate the card is now disabled.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Notes:

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Chapter 8

Connect the 1784-PCC Card to the Network

What is in This Chapter?

Read this chapter to connect the 1784-PCC card to the network and to understand network communication. The following table describes what this chapter contains and where to find specific information.

Table 8.A

For information about this topic:	See page:
Connect the Card to the ControlNet Network	8-1
Communicate with the Card on the ControlNet Network	8-2


Connect the Card to the ControlNet Network

These instructions assume that you have:

- installed your application software
- inserted the card
- installed the 1784-PCC drivers
  Chapter 3: Windows 2000/XP
  Chapter 4: Windows NT 4.0
  Chapter 5: Windows 95/98/Me

The following diagrams show a PCMCIA 2.1 compliant system. If you are using another computer, your installation may appear slightlydifferent.


Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com



1. Attach the smaller end of the 1784-PCC1 cable to the 1784-PCC card.



The silver side should face upward as you connect the cable to the 1784-PCC card.



2. Attach the other end of the 1784-PCC1 cable to any intelligent device (i.e., workstation, PLC processor, scanner, or adapter) on ControlNet through its Network Access Port. Total cable length should be less than 10 meters.

Communicate with the Card on the ControlNet Network

The 1784-PCC card communicates on the ControlNet network through a standard application programming interface (API) known as RSLinx™ from Rockwell Software, Inc. If you need additional information about this software package or about communicating on the ControlNet network, refer to the ControlNet Coax Media Planning and Installation Manual, publication number CNET-IN002A-EN-P, or contact your Rockwell Automation representative.


IMPORTANT Do not accidently plug the end of the 1784-PCC cable into the Ethernet port. This type of connection will generate noise on Ethernet and it will not work.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Specifications

1784-PCC Communication Card	
PCMCIA Type	Type II form-factor network adapter card
PCMCIA Standard	Compliant to PCMCIA Standard, release 2.1
Power Requirements	5V dc @ 225 mA maximum Class 2
Conductor	Category 2[1]
Operating Temperature[2]	IEC 60068-2-1 (Test Ad, Operating Cold), IEC 60068-2-2 (Test Bd, Operating Dry Heat), IEC 60068-2-14 (Test Nb, Operating Thermal Shock): 0 to 50°C (32 to 122°F)
Storage Temperature	IEC 60068-2-1 (Test Ab, Un-packaged Non-operating Cold), IEC 60068-2-2 (Test Bb, Un-packaged Non-operating Dry Heat), IEC 60068-2-14 (Test Na, Un-packaged Non-operating Thermal Shock): -40 to 85° C (-40 to 185° F)
Relative Humidity	IEC 60068-2-30 (Test Db, Un-packaged Non-operating Damp Heat): 5-95% non-condensing
Vibration	IEC60068-2-6 (Test Fc, Operating): 2g @ 10-500Hz
Shock	IEC60068-2-27 (Test Ea, Unpackaged shock): Operating 30g Non-operating 50g
Emissions	CISPR 11: Group 1, Class A
Radiated RF Immunity	10V/m with 1kHz sine-wave 80%AM from 30MHz to 1000MHz
Certifications: (when product is marked)	**UR** UL Recognized Component Industrial Control Equipment **CE**[3] European Union 89/336/EEC EMC Directive, compliant with: EN 50082-2; Industrial Immunity EN 61326; Meas./Control/Lab., Industrial Requirements EN 61000-6-2; Industrial Immunity EN 61000-6-4; Industrial Emissions **C-Tick**[3] Australian Radiocommunications Act, compliant with: AS/NZS 2064; Industrial Emissions
1784-PCC1 Cable Specifications	
Total length of cable	120 cm

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Pin Assignments	PC card Plug ControlNet Plug 

[1]Refer to the ControlNet Cable System Planning and Installation Manual, publication CNET-IN002A-EN-P, when wiring your network. Refer to Industrial Automation Wiring and Grounding Guidelines, publication 1770-4.1, for information about Category 2 wiring.

[2]The operating parameters describe the environment within the PCMCIA slot. Refer to the documentation for your computer for environmental requirements. The 1784-PCC card should not exceed those specifications.

[3] See the Product Certification link at www.ab.com for Declarations of Conformity, Certificates, and other certification details.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

adapter

The hardware that connects the computer bus to the 68-pin PC card sockets in the PCMCIA slot. *See also* socket.

application programming interface (API)

The set of services that an operating system makes available to programs that run under it.

ControlNet network

A communication architecture that allows the exchange of messages between Allen-Bradley Company, Inc. products and certified third-party products.

connection

An opened communication path between two nodes on a ControlNet network.

ControlNet status indicators

Channel A and channel B indicators on your node indicating status on the ControlNet link.

enabler

Software used to control PC cards. There are three types of enablers: generic (which can control many different types of cards), specific (which is designed for a specific manufacturer's PC card), and point enabler (which is designed for a specific manufacturer's PC card but does not require Card and Socket Services).

drop cable

A cable that connects a node to the trunk cable. This is an integral part of Allen-Bradley 1786 taps.

link

A collection of nodes with unique addresses (in the range of 1-99). Segments connected by repeaters make up a link; links connected by bridges make up a network.

maximum scheduled node

The node with highest network address that can use *scheduled* time on a ControlNet link.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

maximum unscheduled node

The node with highest network address that can be *unscheduled* time on a ControlNet link.

Network Access Port (NAP)

In a ControlNet network, NAP is a physical layer variant that allows a temporary node to be connected to the link by connection to the NAP of permanent node. It is an RJ45 connection between two cnet devices that is typically temporary between a programming device and the network.

network

A series of nodes connected by some type of communication medium. The connection paths between any pair of nodes can include repeaters, routers, bridges, and gateways.

network address

A node's address on the network.

node

The port of a physical device connected to the network that requires a network address to function on the network. A link may contain a maximum of 99 nodes.

NUI (Network Update Interval)

A single occurrence of the network update time (NUT).

NUT (Network Update Time)

Repetitive time interval in which data can be sent on the ControlNet network.

PC card

Credit-card size, 68-pin add-in cards that were designed to meet PCMCIA standards.

redundant media

A dual cable system that lets you receive the best signal over a network.

repeater

A two-part active physical-layer device that reconstructs and retransmits all traffic it hears on one segment to another segment.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

segment

Trunk-cable sections connected via taps with terminators at each end; a segment does not include repeaters.

socket

The 68-pin physical connection in the PCMCIA slot in your computer that connects to the 68-pins on the PC card.

Socket Services

The software interface that manipulates the PC cards, sockets, and adapters. *See also* PC cards, sockets, adapters.

tap

A component that connects products to the ControlNet trunk cable. A tap is required for each node and for both sides of each repeater.

terminator

A 75-Ω resistor (mounted in a BNC plug) placed on the ends of segments to prevent reflections from occurring at the ends of cables.

trunk cable

The bus or central part of the ControlNet cable system.

trunk cable section

The length of trunk cable between any two taps.

type

Refers to the physical size of the PC card. There are three types of cards that have the same length and width (54 mm x 85.6 mm). The cards differ in thickness in the center, but have identical thickness at the connector end and long the rails. This lets you use all three types in the same PCMCIA slot, if the slot is thick enough in the center.

Type I

A 3.3 mm thick PC card that is used for memory enhancements, such as Flash memory cards. *See also* PC card.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Type II

A 5 mm thick PC card that is used for I/O features such as modem, LAN, and host communications. *See also* PC card.

Type III

A 10.5 mm thick PC card that is used for memory enhancements or I/O capabilities that require more space, such as rotating media and wireless communication devices. *See also* PC card.

Virtual Device Driver (VxD)

A Windows device driver that processes interrupts and carries out I/O operations for a given application without disrupting the execution of other applications. Used in 1784-PCC Windows 95/98/Me applications.

Windows Driver Model (WDM)

A Windows device drivers that use I/O Request Packets (IRPs) as a means for messaging and data transfer. Used in 1784-PCC Windows 2000/XP applications.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Numerics

1784-PCC card
- inserting into PCMCIA slot 7-1
- package material 2-1
- purpose 1-3
- support services 7-1
- system requirements 2-2

A

abbreviations used in this manual 2
assign interrupt 3-15, 4-15, 5-12
assign interrupts 5-12
audience 1

C

communicating with the card on the ControlNet network 8-2
configuration utility
- run 4-11

connect the card to the ControlNet network 8-1
ControlNet Traffic Analyzer 3-16
conventions used in this manual 1

D

driver
- install in Windows 2000/XP 3-1
- install in Windows 95/98/Me 5-1
- install in Windows NT 4-1
- remove in Windows 95/98/Me 5-6
- remove in Windows NT 4-17

Driver Properties 3-15

G

General Properties 3-14, 3-17

H

Hardware Properties 3-8

I

installing the card's driver
- in Windows 2000/XP 3-3
- in Windows 95/98/Me 5-2
- in Windows NT 4-5

N

nodes 6-5

P

package material contents 2-1
PC card 1-1
- types 1-2
- what is it 1-1

PCMCIA
- card type (Type I, II, or III) 1-2
- definition 1-1
- what is it 1-1

R

removing the card's driver
- in Windows 2000/XP 3-11
- in Windows 95/98/Me 5-6
- in Windows NT 4-17

Resources Properties 3-15
RSLinx
- maximum unscheduled node 6-6

run the configuration utility for Windows NT 4-11
run the test utility 6-1

S

stopping the card in Windows 2000/XP 3-8
support services 7-1
system requirements 2-2

T

test utility
- card error 6-4
- run 6-1

troubleshooting the card's installation
- in Windows 2000/XP 3-13
- in Windows 95/98 5-9
- in Windows 95/98/Me 5-9

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

in Windows NT 4-11
two cards inserted 3-20
types of PC cards 1-2

U

Unplug/Eject icon 3-10, 3-11, 3-13, 3-16, 3-28
Unplug/Eject the card 3-8

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

www.rockwellautomation.com

Corporate Headquarters
Rockwell Automation, 777 East Wisconsin Avenue, Suite 1400, Milwaukee, WI, 53202-5302 USA, Tel: (1) 414.212.5200, Fax: (1) 414.212.5201

Headquarters for Allen-Bradley Products, Rockwell Software Products and Global Manufacturing Solutions
Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204-2496 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444
Europe/Middle East/Africa: Rockwell Automation SA/NV, Vorstlaan/Boulevard du Souverain 36, 1170 Brussels, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640
Asia Pacific: Rockwell Automation, 27/F Citicorp Centre, 18 Whitfield Road, Causeway Bay, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846

Headquarters for Dodge and Reliance Electric Products
Americas: Rockwell Automation, 6040 Ponders Court, Greenville, SC 29615-4617 USA, Tel: (1) 864.297.4800, Fax: (1) 864.281.2433
Europe/Middle East/Africa: Rockwell Automation, Brühlstraße 22, D-74834 Elztal-Dallau, Germany, Tel: (49) 6261 9410, Fax: (49) 6261 17741
Asia Pacific: Rockwell Automation, 55 Newton Road, #11-01/02 Revenue House, Singapore 307987, Tel: (65) 6356-9077, Fax: (65) 6356-9011

Publication 1784-IN034D-EN-P - June 2002 PN 957678-61

Supersedes Publication 1784-IN034C-EN-P - December 2000

Copyright © 2002 Rockwell Automation. All rights reserved. Printed in USA

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group is an independent supplier of quality pre-owned equipment

Gold-standard solutions

Extend the life of your critical industrial, commercial, and military systems with our superior service and support.

We buy equipment

Planning to upgrade your current equipment? Have surplus equipment taking up shelf space? We'll give it a new home.

Learn more!

Visit us at **artisantg.com** for more info on price quotes, drivers, technical specifications, manuals, and documentation.

Artisan Scientific Corporation dba Artisan Technology Group is not an affiliate, representative, or authorized distributor for any manufacturer listed herein.

We're here to make your life easier. How can we help you today?

(217) 352-9330 | sales@artisantg.com | artisantg.com

ARTISAN® TECHNOLOGY GROUP