ARTISAN®
TECHNOLOGY GROUP

Your **definitive** source for quality pre-owned equipment.

Artisan Technology Group
(217) 352-9330 | sales@artisantg.com | artisantg.com

Full-service, independent repair center
with experienced engineers and technicians on staff.

We buy your excess, underutilized, and idle equipment
along with credit for buybacks and trade-ins.

Custom engineering
so your equipment works exactly as you specify.

- Critical and expedited services
- In stock / Ready-to-ship
- Leasing / Rentals / Demos
- ITAR-certified secure asset solutions

Expert team | Trust guarantee | 100% satisfaction

All trademarks, brand names, and brands appearing herein are the property of their respective owners.

Find the *ABB 1TGE120011R2000* at our website: *Click HERE*

MNS *i*S Motor Control Center
M*Control* Interface Manual Profibus Direct
System Release V5.4/0



Power and productivity
for a better world™

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

MNS is a registered trademark.

Emax, Tmax are registered trademarks of ABB SACE Spa.

Microsoft, Windows and Windows XP are registered trademarks of Microsoft Corporation.

JAVA is a registered trademark from Sun Microsystems.

Product names of other products are registered trademarks of their manufacturers or owners.

This document relates to the MNS *i*S System Release 5.4/0.

The information in this document is subject to change without notice and should not be construed as a commitment by ABB. ABB assumes no responsibility for any errors that may appear in this document.

In no event shall ABB be liable for direct, indirect, special, incidental, or consequential damages of any nature or kind arising from the use of this document, nor shall ABB be liable for incidental or consequential damages arising from use of any software or hardware described in this document.

This document and parts thereof must not be reproduced or copied without ABB's written permission, and the contents thereof must not be imparted to a third party nor be used for any unauthorized purpose. The software described in this document is furnished under a license and may be used, copied, or disclosed only in accordance with the terms of such license.

All rights reserved.

Copyright © 2009 ABB Automation Products GmbH, Ladenburg, Germany

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Table of content

General **4**
Target Group 4
Use of Warning, Caution, Information and Tip icon 4
Terminology 5
Related Documentation 9
Related System Version 9
Document Revision History 9

Introduction **10**
Profibus Standard 10
MNS iS Hardware Requirements 10
MNS iS Software Requirements 10

Basics **11**
PROFIBUS DP-V0 11
Cyclic Data Communication 11
Diagnostics 11
PROFIBUS DP-V1 13
Acyclic Data Communication 13

Interfaces **14**
MControl Profibus connector 14
Connection 14
Termination 15

Getting Started **17**
Configuration parameters 17
Parameters 17
Addressing 18
Failsafe 19
Control Access 20

PROFIBUS Data Mapping **21**
General 21
Monitoring data 22
QualityCode 28
MControl status 31
Starter dependent information 32
Command format 33

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

General

Target Group

This document describes communication and control interfaces used in MNS *i*S.

The manual is primarily intended for those requiring information on accessing information and data provided from MNS *i*S. Furthermore the document provides information for integration of MNS *i*S as fieldbus component into PLC or higher level Process Control Systems to control system and application engineers.

It is assumed that the reader of this manual is familiar with basic terms of fieldbus and control communication (e.g. basic knowledge about PROFIBUS, Modbus etc.).

Use of Warning, Caution, Information and Tip icon

This publication includes **Warning**, **Caution**, and **Information** icons where appropriate to point out safety related or other important information. It also includes **Tip** icons to point out useful hints to the reader. The corresponding symbols should be interpreted as follows:



The electrical warning icon indicates the presence of a hazard that could result in *electrical shock.*



The warning icon indicates the presence of a hazard that could result in *personal injury.*



The caution icon indicates important information or warnings related to the concept discussed in the text. It might indicate the presence of a hazard that could result in *corruption of software or damage to equipment/property.*



The information icon alerts the reader to pertinent facts and conditions.



The tip icon indicates advice on, for example, how to design your project or how to use a certain function

Although **Warning** notices are related to personal injury, and **Caution** notices are associated with equipment or property damage, it should be understood that the operation of damaged equipment could, under certain operational conditions, result in impaired process performance leading to personal injury or death. It is, therefore, imperative that you comply fully with all **Warning** and **Caution** notices.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Terminology

List of the terms, acronyms, abbreviations and definitions that the document uses.

Abbreviation	Term	Description
	Aspect Object	ABB technology. An Aspect Object is a computer representation of a real object such as a pump, a valve, an order or a virtual object such as a service or an object type. An Aspect Object is described by its aspects and is organized in structures.
	Alarm	Alarm is defined as status transition from any state to abnormal state. Status transition to abnormal state can be data crossing over the pre-defined alarm limit.
	Bus Local	A Control Access term describing that the M*Control* accepts its commands from a device on the switchgear control network, e.g. the Web Interface, M*View*.
COTS	Commercial off the shelf	Commercial off the shelf product, term to describe products available on the market, ready to use
DCS	Distributed Control System	See also PCS
DTM	Device Type Manager	Software module used to manage devices via fieldbus (e.g. PROFIBUS) using frame application environment (e.g. PactWare, ABB Fieldbus Builder etc.)
Eth.	Ethernet	Ethernet is a local area network (LAN) technology. The Ethernet standard specifies the physical medium, access control rules and the message frames.
	Event	An event is a status transition from one state to another. It can be defined as alarm, if the state is defined as abnormal or as warning as a pre-alarm state.
FD	Field Device	Term for devices connected to the fieldbus (e.g. motor control units or circuit breaker protection)
GSD file	Geräte Stamm Datei (German abbreviation)	A hardware description file for a PROFIBUS-DP or PROFIBUS-DP/V1 slave type
GPS	Global Positioning System	System to detect local position, universal time and time zone, GPS technology provides accurate time to a system

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Abbreviation	Term	Description
	Hardware Local	A Control Access term describing that the M*Control* accepts its commands from the Hardwired inputs, when the respective Local control input is set to true.
HMI	Human Machine Interface	Generic expression
LVS	Low voltage switchgear	A factory built assembly built to conform with IEC 60439-1
MCC	Motor Control Centre	Common term for switchgear used for motor control and protection.
MNS		Modular Low Voltage Switchgear family from ABB
MNS *i*S		The integrated intelligent switchgear solution from ABB
	M*Start* M*Feed* M*Control* M*Link* M*View* M*Navigate*	MNS *i*S components integrated in the switchgear, see the MNS *i*S System Guide for technical details
	MODBUS	Fieldbus communication protocol
	MODBUS RTU	Fieldbus communication protocol
	Motor Starter	Consists of motor controller and electrical components to control and protect a motor, part of Motor Control Center
NLS	Native Language Support	Providing the ability to change the language of software tools in order to support native languages (English is basis, others are optional)
OPC		OLE for Process Control, an industrial standard for exchange of information between components and process control application
PCS	Process Control System	High level process control system
PLC	Programmable Local Controller	Low level control unit

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Abbreviation	Term	Description
	PROFIBUS-DP	Fieldbus communication protocol with cyclic data transfer (V0).
	PROFIBUS-DP/V1	Fieldbus communication protocol, extension of PROFIBUS- DP allowing acyclic data transfer and multi master (V1).
	PROFIBUS-DP/V2	Fieldbus communication protocol, extension of PROFIBUS- DP allowing time stamp and communication between master and slave (V2).
RCU	Remote Control Unit	Local control unit with pushbutton and indicator to operate a device (e.g. motor) from field level.
RS232		Standard No. 232 for PC communication, established by EIA (Electronics Industries Association, USA)
RS485		Communication interface standard from EIA (Electronics Industries Association, USA), operating on voltages between 0V and +5V. RS-485 is more noise resistant than RS-232C, handles data transmission over longer distances, and can drive more receivers.
RTC	Real Time Clock	Integrated clock function in devices used to generate time and date information if a remote clock system is not present
	Software Local	A Control Access term describing that the M*Control* accepts its commands from the hardwired inputs as a result of either the PCS or M*View* passing the Control Access Authority to Soft-Local. Note: Does not require the hardwired local input to be set to true.
SNTP	Simple Network Time Protocol	a protocol used for time synchronization in Control Network through Ethernet
	Switchgear Bus Network	Term used to describe the internal switchgear communication network, between M*Link* and M*Control*.
TCP/IP	Transmission Control Protocol / Internet Protocol	TCP/IP is a high-level connection oriented, reliable, full duplex communication protocol developed for integration of the heterogenous systems.
	Trip	A consequence of an alarm activated or an external trip command from another device to stop the motor or trip the circuit breaker.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Abbreviation	Term	Description
UTC	Coordinated Universal Time	Coordinated Universal Time is the international time standard. It is the current term for what was commonly referred to as Greenwich Meridian Time (GMT). Zero (0) hours UTC is midnight in Greenwich England, which lies on the zero longitudinal meridian. Universal time is based on a 24 hour clock.
	Warning	A warning is defined as status transition from any state to pre-alarm state to inform in advance before an alarm level is reached.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Related Documentation

MNS *i*S

1TGC910127 M0201 MNS *i*S Interface Manual M*Link*, Release 5.4

1TGC910137 M0201 MNS *i*S Interface Manual M*View*, Release 5.4

1TGC910157 M0201 MNS *i*S Interface Manual Profibus, Release 5.4

1TGC910167 M0201 MNS *i*S Interface Manual Modbus, Release 5.4

1TGC910001 B0204 MNS *i*S System Guide

1TGC910609 M0201 MNS *iS* Quick Guide Installation and System Setup, Release 5.4

1TGC910069 M0201 M*Navigate* Help file V5.4

1TGC910018 M0202 MNS *i*S ATEX – Enhancements for Safety

Profibus

[1] PROFIBUS Installation Guideline, Rev 4, Nov 2002,
Profibus Competence Center Manchester, UK

[2] PROFIBUS Profiles for Low Voltage Switchgear Devices (LVSG),
3.122 Version 1.2 July 2006, PNO Karlsruhe, Germany

[3] PROFIBUS Installation Guideline for Cabling and Assembly,
8.022 Version 1.0.6 May 2006, PNO Karlsruhe, Germany

[4] PROFIBUS Installation Guideline for Commissioning
8.032 Version 1.0.2 November 2006 PNO Karlsruhe, Germany

[5] PROFIBUS Technology Description
4.002 Version October 2002 PNO Karlsruhe, Germany

Related System Version

The content of this document is related to MNS *i*S System Release 5.4/0.

Document Revision History

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Introduction

Profibus Standard

PROFIBUS is a manufacturer-independent fieldbus standard for applications in manufacturing, process and building automation. PROFIBUS technology is described in fixed terms in DIN 19245 as a German standard and in EN 50170 / IEC 61158 as an international standard. The PROFIBUS standard is thus available to every provider of automation product.

The PROFIBUS family is composed of three types of protocol, each of which is used for different tasks. Of course, devices with all three protocols can communicate with each other in a complex system by means of a PROFIBUS network.

The three types of protocols are: PROFIBUS FMS, DP and PA. Only the two protocol types DP and PA are important for process automation, whereas only DP is used in MNS *i*S. See also reference document [5].

PROFIBUS DP: the **pro**cess **fi**eld**bus** for the **d**ecentralized **p**eriphery

The PROFIBUS DP (RS 485) is responsible for communication between the Controller level of a process automation system and the decentralized periphery in the field. One feature of PROFIBUS DP is its high speed of transmission up to 12 Mbit/s.

MNS iS Hardware Requirements

MControl with Profibus Direct communications interface	1TGE120011R2xxx

MNS iS Software Requirements

For full support of the MNS *i*S V5.4/0 functionality the Profibus interface requires

- M*Control* base version 5.4 or higher
- GSD file version : **ABB_0C43.GSD**

  (file available via local ABB Low Voltage Systems unit)

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Basics

PROFIBUS DP-V0

Cyclic Data Communication

The data communication between the DPM1 (DP Master Class 1) and its assigned slaves is automatically handled by the DPM1 in a defined, recurring sequence. With each user data transfer, the master can write up to 244 bytes of output data to the slave and read up to 244 bytes of input data from the slave. The Data is read and written synchronously in one procedure.




Fig. 1 Cyclic User Data Transmission in DP

The data communication between the DPM1 and the slaves is divided into three phases: parameterization, configuration and data transfer. Before the master includes a DP slave in the data transfer phase, a check is run during the parameterization and configuration phase to ensure that the configured set point configuration matches the actual device configuration. During this check, the device type, format and length information and the number of inputs and outputs must also correspond. This provides you with reliable protection against parameterization errors.

Diagnostics

In addition to the cyclic data the PROFIBUS slave unit provides diagnostic data. With this diagnostic data the slave can indicate errors or warnings on the slave unit, the I/O-units or the I/O-channels. Some diagnostic data is generic and defined by the PNO. But most of the diagnostic data is manufacturer specific.

An example for generic diagnosis is: Slave not ready, Parameter fault and Watchdog monitoring.

M*Control* supports only generic diagnostic. Extended (manufacturer specific) diagnostic is not supported at the moment.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Sync and Freeze Mode

In addition to the normal cyclic communication between the DPM1 (DP Master Class 1) and the assigned slaves, a master can send the control commands sync and freeze via multicast to a group of slaves.

With the sync-command the addressed slaves will freeze the outputs in their current state. New output values received by the master will be stored while the output states remain unchanged. The stored output data are not sent to the outputs until the next sync command is received. The Sync mode is terminated with the “unsync” command.

In the same way, a freeze command causes the addressed slaves to enter freeze mode. In this mode, the states of the inputs are frozen at their current value. The input data are not updated again until the master sends the next freeze command. Freeze mode is terminated with the “unfreeze” command



M*Control* does not support Sync Mode and Freeze Mode.

DP Master Class 1 (DPM1) and Class 2 (DPM2)

The DP master class 1 is the master that is in cyclic data transmission with the assigned slaves. To get into the cyclic communication the DPM1 has to configure the slave before.

The DP master class 2 is used for engineering and configuration. It does not have cyclic data transmission with the slave devices. Normally a DPM2 is only connected temporarily to the bus. A DPM2 can have class 2 communication to the slave devices before the slaves are configured via DPM1 and cyclic communication is active.



M*Control* does support communication with DPM1.

Monitoring the DP-V0 Communication

The cyclic communication between the DPM1 and the slaves is monitored by the master and the slaves itself. If the DPM master unit detects a failure in the communication with a slave, it will indicate the corresponding slave as disturbed.

On slave side the communication with the master is controlled via the watchdog. If no data communication with the master occurs within the watchdog control interval, the slave automatically switches its outputs to the fail-safe state.



PROFIBUS watchdog must be enabled in the Master (DCS Controller) and failsafe functionality must be parameterized for M*Control*.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

PROFIBUS DP-V1

Acyclic Data Communication

The key feature of version DP-V1 is the extended function for acyclic data communication. The acyclic data communication is mainly used for configuration and parameterization purpose. With the acyclic DP-V1 read and write services the master can read or write any desired data to and from the slave. The data is addressed by slot, index and length. Each data block can be up to 244 bytes.




Fig. 2 Acyclic Communication in DP-V1: Read Service

The transmission of acyclic data is executed in parallel to the cyclic data communication, but with lower priority. Acyclic services are operated in the remaining time at the end of the DP-V0 cycle.

M*Control* Profibus Direct Interface supports DPV1 communication. However, currently only cyclic data exchange is available.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Interfaces

MControl Profibus connector

Each M*Control* can be connected to the Profibus via a connector on the front side of the M*Control*. M*Control* acts as a standard PROFIBUS Slave device.




Fig. 3 M*Control* front view with PROFIBUS connector

Connection

The physical medium for PROFIBUS-DP is RS-485, which allows 32 nodes in a single segment and 125 nodes in a network using 4 segments. Segments must be separated by using Repeater.

The PROFIBUS interface checks input signal for poll requests from master and detects the baud rate automatically (max Baud Rate = 12MBit).

Cable length may vary from 80-1200 m depending on transmission speed and repeater type in use. Cable length can be extended using fiber optic modems (yielding a more robust network). See reference document [4] for more details on cable connections and wiring.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com




Fig. 4 PROFIBUS network principles (M – Master, S –Slave)

The connection on M*Control* is done via PROFIBUS Standard Sub-D plugs. This provides a T-Junction with up to 12 MBaud communication speed. At both ends of a segment a termination must be activated. This termination can either be part of the PROFIBUS connector or a separate type.

In a mixed network, the maximum cable length of drop lines must be considered. This is very important especially for higher communication Baud rates !

See reference documents [1] & [3] for more information.

Termination

The M*Control* does not provide PROFIBUS Termination in-built. Therefore correct measures have to be taken to connect termination to both ends of the PROFIBUS segment.

It is recommended to use PROFIBUS standard plugs with Termination inbuilt.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Connection and termination examples




Fig. 5 M*Control* PROFIBUS connection and termination example




Fig. 6 M*Link* PROFIBUS connection and termination example with Repeater

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Getting Started

M*Control* requires Profibus module to be selected when editing the firmware. For the Profibus module there are few parameters to be set:

Configuration parameters

Parameter	Default Value	Range	Remarks
Profibus Address	99	3 …125	PROFIBUS station address (0,1,2 reserved for DP Master 126, 127 reserved)
GPI1, GPI2, GPI3, GPI4	False	Binary inputs	The values of these binary inputs can be monitored via Profibus

Parameters

Parameter	Default Value	Range	Remarks
Control Access Owner	Restore	Restore Soft Local Bus Local Remote	This selects the Control Access (CA) owner, when the AutoMode Bit is cleared or Profibus communication stops. "**Restore**" means that the CA owner returns to previous latest selected CA state

Table 1 PROFIBUS parameter and initial values

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Addressing

PROFIBUS DP allows the address range of 0 to 127. Following reservations apply:

0, 1, 2 - used for PROFIBUS Master

126, 127 - reserved

The remaining address numbers are available. It must be ensured that the number selected is unique for the PROFIBUS Master where the M*Control* is connected to. Using a number more than once will cause communication error on PROFIBUS.

M*Control* does not support address setting / changing from PROFIBUS Master. The address must be defined with the configuration parameter above and loaded into MControl.

If more than 32 devices are connected to a segment, repeater devices have to be used. Such repeater counts as one Slave within a segment without using an address number. Thus only 30 Slaves are possible within a segment.




Fig. 7 Example of max address range and slave numbers on one PROFIBUS Master

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Failsafe

In case of a disturbed PROFIBUS communication an option is available to transfer all M*Control* modules into a safe state. This M*Start* specific failsafe state has to be defined as a M*Control* starter parameter (utilizing M*Navigate*).

The DCS / PLC has to set the “Activate Failsafe” bit and “AutoMode” bit if Failsafe shall be generated whenever the Profibus communication to M*Control* stops or fails.

Profibus telegram bit		**Action when Profibus communication to M*Control* stops or fails**
“Activate Failsafe”	**“AutoMode”**	
Cleared (0)		No failsafe generated and failsafe action will not be executed
	Cleared (0)	No failsafe generated and failsafe action will not be executed
Set (1)	Set (1)	If no second Failsafe Master (e.g. MLink connected to DCS acting as second Failsafe Master) for that MControl is available then MControl will exectute configured Failsafe action (configured in MNavigate) in case of communication loss to connected DCS/PLC.



To disconnect without activating Failsafe the PLC must clear “Activate Failsafe” or “Auto Mode” before stopping the communication.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Control Access

To request control via Profibus Direct the AutoMode bit must be set in the control structure:

- If the hardware local input is active the control will stay with the local inputs and the AutoMode bit inside the monitoring data will not be set.
- If the hardware local input is not active the MControl will accept the request and set the AutoMode bit in the monitoring data. Also the “CA MControl Fieldbus Interface” bit in the CA section of the MControl status is set. Then the MControl will follow the Profibus requests.

When clearing the AutoMode bit the control access owner will be set as specified in the setting of the parameter “Control Access Owner” of the direct Profibus interface.



To enable the control via M*View*, Gateways, RCU, etc. the AutoMode bit of the Profibus Direct interface must be cleared.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

PROFIBUS Data Mapping

General

M*Control* supports

- the 2 PNO Standard Profibus profiles for Low Voltage Switchgear (Motor Management Starter Profile)
- a M*Control* proprietary full information profile

Profile type	**Monitoring data format**	**Command format**	**Remark**
4read – 2write	0	0	Standard PNO profile Low Voltage Switchgear
4read – 4write	0	1	Standard PNO profile Low Voltage Switchgear
4read – 13write	0	2	Monitoring: Standard PNO profile Low Voltage Switchgear Commands: M*Control* proprietary
244 read – 13 write	2	2	Monitoring: M*Control* proprietary Commands: M*Control* proprietary

The standard profiles are based on the technical specification “Profiles for Low Voltage Switchgear, Version 1.2, July 2006).

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Monitoring data

Monitoring data based on PROFIBUS Profile for Low Voltage Switchgear/ Motor Management Starter Profile

Format 0

Byte	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
0	Warning	Fault	Auto Mode	Lock-Out Time	Overload Warning	Status		
1	Failsafe	Ready	Test	Trip reset possible	Reserved (GPI4)	Reserved (GPI3)	Reserved (GPI2)	Reserved (GPI1)
2	Motor current highest phase – high [% / In]							
3	Motor current highest phase – low [% / In]							

The reserved Bits of Byte 1 may be used for some GPI, which can be connected to the Profibus interface. This enables the user to pick some status information beyond the three starter dependent status bits. The different bits are handled as follows.

Description of Information available from profiles

Profibus Byte/Bit	Function		
Byte 0 Bit 7	Warning	0 = no warning	1 = any warning of the available protection and supervision functions
Byte 0 Bit 6	Fault	0 = no trip condition	1 = any trip condition of the available protection and supervision functions
Byte 0 Bit 5	Auto Mode	0 = not in AutoMode the *Control* bits are ignored	1 = AutoMode, the M*Control* follows the Profibus requests
Byte 0 Bit 4	Lock-Out	0 = M*Control* can be started	1 = M*Control* start is locked out by Thermal overload, start inhibit, etc.
Byte 0 Bit 3	Overload Warning	0 = no Thermal Overload Warning (TOL) pending	1 = Thermal Overload Warning; set level for TOL is reached .
Byte 0 Bit 2	Status	Starter dependent information	
Byte 0 Bit 1			
Byte 0 Bit 0			
Byte 1 Bit 7	Failsafe	0 = M*Control* is in normal state	1 = Failsafe condition happened

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Profibus Byte/Bit	Function		
Byte 1 Bit 6	Ready	0 = not ready to start	1 = ready to start = M*Start* connected & main switch on & no trip & no start inhibit
Byte 1 Bit 5	Test	0 = M*Start* not in test position	1 = M*Start* in test position; Main switch off but contactor control possible
Byte 1 Bit 4	Trip Reset possible	0 = Trip reset not possible	1 = Trip reset possible
Byte 1 Bit 3	GPI4	0 = GPI 4 not active	1 = GPI 4 is active
Byte 1 Bit 2	GPI3	0 = GPI 3 not active	1 = GPI 3 is active
Byte 1 Bit 1	GPI2	0 = GPI 2 not active	1 = GPI 2 is active
Byte 1 Bit 0	GPI1	0 = GPI 1 not active	1 = GPI 1 is active

Starter dependent status bits description:

Starter type	Bit 2	Bit 1	Bit 0
NR-DOL NR-DOL-RCU	Runs	Off	Reserved (=0)
REV-DOL REV-DOL-RCU	Runs forward	Off	Runs reverse
NR-DOL StarDelta(1)	Runs	Off	Reserved (=0)
NoStarter	Runs forward	Off	Runs reverse
NR-DOL Softstarter(2)	Runs	Off	Reserved (=0)
Transparent	K3	K2	K1
Transparent with Control	Reserved (=0)	Reserved (=0)	K1 (Open/Close)
Transparent without Control	Reserved (=0)	Reserved (=0)	Reserved (=0)
Actuator(3)	Opening	Stopped	Closing
Feeder	Closed	Opened	Reserved (=0)
C-Feeder	Closed	Opened	Reserved (=0)
C-Feeder RCU	Closed	Opened	Reserved (=0)

(1) Star/Delta information has to be read via GPI if required

(2) Softstart/Softstop information has to be read via GPI if required.

(3) Actuator opened/closed has to be read via GPI if required

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Format 2

This format delivers the full information as displayed on the M*View*.

Note : This layout is only valid for MControl Base Version 5.4 !

Profibus Byte offset	Bit offset	Data type	Description
0	0	Unsigned32	QualityCode: Bit field with bits indicating whether measurement values are valid. *See tables below !*
4	0	Unsigned32	QualityCode2: Bit field with bits indicating whether measurement values are valid. *See tables below !*
8	0	Unsigned32	M*Control* status *See tables below !*
12	0	Floating point	Current phase 1 [A]
16	0	Floating point	Current phase 2 [A]
20	0	Floating point	Current phase 3 [A]
24	0	Unsigned16	Current phase 1 [%]
26	0	Unsigned16	Current phase 2 [%]
28	0	Unsigned16	Current phase 3 [%]
30	0	Floating point	Earth fault current [A].
34	0	Floating point	Phase 1-2 Voltage [V], Phase 1 Voltage [V]
38	0	Floating point	Phase 2-3 Voltage [V]
42	0	Floating point	Phase 3-1 Voltage [V]
46	0	Floating point	Cos Phi (calculated)
50	0	Floating point	Frequency [Hz]
54	0	Floating point	Apparent power [0.1 kVA][5)]
58	0	Floating point	Active power [0.1 kW] [5)]
62	0	Floating point	Reactive power [0.1 kVAR] [5)]
66	0	Floating point	Temperature of contact L1 [°C]
70	0	Floating point	Temperature of contact L2 [°C]
74	0	Floating point	Temperature of contact L3 [°C]
78	0	Unsigned32	K1 switching cycles
82	0	Unsigned32	K2 switching cycles
86	0	Unsigned32	K3 switching cycles
90	0	Unsigned32	M*Start* insertion cycles
94	0	Unsigned32	Operating hours [h]

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Profibus Byte offset	Bit offset	Data type	Description
98	0	Unsigned16	Thermal image [%]
100	0	Unsigned16	Time to reset [s]
102	0	Unsigned16	Time to trip [s]
104	0	Unsigned16	Measured PTC resistance [Ω]
106	0	Integer16	PT100-3Ch Temperature Sensor1 [0.1 °C] [4] *(only if respective HW available)*
108	0	Integer16	PT100-3Ch Temperature Sensor2 [0.1 °C] [4] *(only if respective HW available)*
110	0	Integer16	PT100-3Ch Temperature Sensor3 [0.1 °C] [4] *(only if respective HW available)*
112	0	Unsigned16	GPI: Up to 16 user assigned input signals
114	0	Unsigned16	GPAI: User configurable Analog value (mostly [0.1 %][5])
116	0	Floating point	Motor start time [s]
120	0	Floating point	Current at trip phase 1 [A]
124	0	Floating point	Current at trip phase 2 [A]
128	0	Floating point	Current at trip phase 3 [A]
132	0	Unsigned8	Quality code bit field to indicate whether current at trip is valid: Bit 7: no current at trip stored Bit 2: Current at trip L3 not valid Bit 1: Current at trip L2 not valid Bit 0: Current at trip L1 not valid
133	0	Unsigned8	Always zero
134	0	Integer16	M*Control* Base Version[5]
136	0	Unsigned8	UUID read from *MStart*
142	0	TimeStampT[6]	The timestamp of the last Earo Entry change
150	0	EaroEntryT[1]	TOL/TOL Eexe
151	0	EaroEntryT[1]	PTC supervision
152	0	EaroEntryT[1]	PTC short circuit
153	0	EaroEntryT[1]	PTC open circuit
154	0	EaroEntryT[1]	Underload
155	0	EaroEntryT[1]	Underload CosPhi
156	0	EaroEntryT[1]	Phase failure
157	0	EaroEntryT[1]	-unused-
158	0	EaroEntryT[1]	-unused-

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Profibus Byte offset	Bit offset	Data type	Description
159	0	EaroEntryT[1)]	Phase Unbalance
160	0	EaroEntryT[1)]	UnderVoltage
161	0	EaroEntryT[1)]	ControlVoltage
162	0	EaroEntryT[1)]	Start limitation
163	0	EaroEntryT[1)]	AutorestartInhibit
164	0	EaroEntryT[1)]	-unused-
165	0	EaroEntryT[1)]	EmStop
166	0	EaroEntryT[1)]	MainSwitchSupervision
167	0	EaroEntryT[1)]	FeedbackSupervision (K1)
168	0	EaroEntryT[1)]	FeedbackSupervision (K2)
168	4	EaroEntryT[1)]	Feeder MCB trip
169	0	EaroEntryT[1)]	FeedbackSupervision (K3)
170	0	EaroEntryT[1)]	MotorStillRunning
170	4	EaroEntryT[1)]	Unexpected feeder current
171	0	EaroEntryT[1)]	Motor not running
172	0	EaroEntryT[1)]	Welded
173	0	EaroEntryT[1)]	Testmode failure
174	0	EaroEntryT[1)]	NoLoad
175	0	EaroEntryT[1)]	Stall
176	0	EaroEntryT[1)]	Earth Leakage
177	0	EaroEntryT[1)]	Contact Temperature Unbalance
178	0	EaroEntryT[1)]	External Trip 1
179	0	EaroEntryT[1)]	External Trip 2
180	0	EaroEntryT[1)]	IRF (Hardware)
181	0	EaroEntryT[1)]	Actuator: both end switch active
182	0	EaroEntryT[1)]	Actuator: Torque open
183	0	EaroEntryT[1)]	Actuator: Torque close
184	0	EaroEntryT[1)]	-unused-
185	0	EaroEntryT[1)]	PT100-1Ch Card Failure *(following data only if respective HW available)*
186	0	EaroEntryT[1)]	PT100-1Ch Sensor Low Limit
186	4	EaroEntryT[1)]	PT100-1Ch Sensor Short Circuit
187	0	EaroEntryT[1)]	PT100-1Ch Sensor High Limit
187	4	EaroEntryT[1)]	PT100-1Ch Sensor Open Circuit
188	0	EaroEntryT[1)]	PT100-3Ch Card Failure *(following data only if respective HW available))*
189	0	EaroEntryT[1)]	PT100-3Ch Sensor1 Low Limit
189	4	EaroEntryT[2)]	PT100-3Ch Sensor1 Short Circuit

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Profibus Byte offset	Bit offset	Data type	Description
190	0	EaroEntryT[1)]	PT100-3Ch Sensor1 High Limit
190	4	EaroEntryT[2)]	PT100-3Ch Sensor1 Open Circuit
191	0	EaroEntryT[1)]	PT100-3Ch Sensor2 Low Limit
191	4	EaroEntryT[2)]	PT100-3Ch Sensor2 Short Circuit
192	0	EaroEntryT[1)]	PT100-3Ch Sensor2 High Limit
192	4	EaroEntryT[2)]	PT100-3Ch Sensor2 Open Circuit
193	0	EaroEntryT[1)]	PT100-3Ch Sensor3 Low Limit
193	4	EaroEntryT[2)]	PT100-3Ch Sensor3 Short Circuit
194	0	EaroEntryT[1)]	PT100-3Ch Sensor3 High Limit
194	4	EaroEntryT[2)]	PT100-3Ch Sensor3 Open Circuit
195	0	EaroEntryT[1)]	Fuse Supervision L1
196	0	EaroEntryT[1)]	Fuse Supervision L2
197	0	EaroEntryT[1)]	Fuse Supervision L3
198	0	EaroEntryT[1)]	Contact Temperature (L1A)
199	0	EaroEntryT[1)]	Contact Temperature (L2A)
200	0	EaroEntryT[1)]	Contact Temperature (L3A)
201	0	EaroEntryT[1)]	reserved
202	0	EaroEntryT[1)]	reserved
203	0	EaroEntryT[1)]	reserved
204	0	EaroEntryT[1)]	Switch Cycle Supervision (K1)
205	0	EaroEntryT[1)]	Switch Cycle Supervision (K2)
206	0	EaroEntryT[1)]	Switch Cycle Supervision (K3)
207	0	EaroEntryT[1)]	Operating hours
208	0	EaroEntryT[1)]	Power module Insertion Cycles
209	0	EaroEntryT[1)]	S/D-Transition failed
210	0	EaroEntryT[1)]	MStart Id or range error
211	0	EaroEntryT[1)]	M*Start* communication error
212	0	EaroEntryT[1)]	Location supervision
213	0	EaroEntryT[1)]	IRF (Software)
214	0	Unsigned16	Reserved[3]
220	0	Integer16	PT100-1Ch Temperature [0.1 °C] [4)] *(only if respective HW available)*
222		Unsigned32	Active energy counter [0.1 kWh] [3)]
226	0	Integer16	Analog input value from AI1 of 2Ai0Ao-I/O-module or AI of 1Ai0Ao-I/O-module [0.1 %][5)] *(only if respective HW available)*
228	0	Integer16	Analog input value from AI2 of 2Ai0Ao-I/O-module [0.1 %][5)] *(only if respective HW available)*

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Profibus Byte offset	Bit offset	Data type	Description
232 - 244	0	Unsigned8	Reserved space all filled with 0

[1] Bit field maps to the lower 4 bit (3,2,1,0) of the byte: (0, trip acknowledged, trip new, alarm)

[2] Bit field maps to the higher 4 bit (7,6,5,4) of the byte: (0, trip acknowledged, trip new, alarm)

[3] Transferred value is multiplied by 10 to allow for 1 fractional digit. The value 1234 means 123.4 kWh

[4] Transferred value is multiplied by 10 to allow for 1 fractional digit. The value 1234 means 123.4 °C

[5] Transferred value is multiplied by 10 to allow for 1 fractional digit. The value 1234 means 123.4

[6] TimestampT is a timestamp with this format:

Byte	DataType	Contents
1	Unsigned8	Year: 0(*), 1 … 199
2	Unsigned8	Month: 0(*), 1 … 12
3	Unsigned8	Day: 0(*), 1 … 31
4	Unsigned8	Hour: 0 … 23
5	Unsigned8	Minute: 0 … 59
6	Unsigned8	Second: 0 … 59
7,8	Unsigned8	Millisecond: 0 … 999

(*) If the timestamp is invalid the entries for Year, Month and Day are set to zero!

QualityCode

The quality codes are bit fields indicating whether the measurement values are valid.

- If the bit is cleared data value is valid.
- If the bit is set the data value is invalid

QualityCode1 Bit	Data
31	reserved
30	M*Start* insertion cycles
29	K1, K2, K3 switching cycles
28	reserved
27	reserved
26	reserved
25	reserved

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

QualityCode1 Bit	Data
24	reserved
23	reserved
22	Frequency
21	Reactive power
20	Active power
19	Apparent power
18	Cos Phi
17	reserved
16	reserved
15	reserved
14	Temperature of contact L3
13	Temperature of contact L2
12	Temperature of contact L1
11	reserved
10	reserved
9	reserved
8	Phase 3-1 Voltage
7	Phase 2-3 Voltage
6	Phase 1-2 Voltage, Phase 1 Voltage
5	Earth fault current
4	Current phase 3
3	Current phase 2
2	Current phase 1
1	reserved
0	reserved

QualityCode2 Bit	Data
31	Thermal image
30	Time to reset
29	Time to trip
28	AI2 (2Ai0Ao)
27	AI (1Ai1Ao) / AI1 (2Ai0Ao)
26	PTC resistance (only if respective HW available)

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

QualityCode2 Bit	Data
25	Reserved
24	Motor start time
23	Reserved
22	PT100_3CH_Temperature3 (only if respective HW available)
21	PT100_3CH_Temperature2 (only if respective HW available)
20	PT100_3CH_Temperature1 (only if respective HW available)
19	PT100_1CH_Temperature (only if respective HW available)
18	reserved
17	reserved
16	reserved
15	GPI16
14	GPI15
13	GPI14
12	GPI13
11	GPI12
10	GPI11
9	GPI10
8	GPI9
7	GPI8
6	GPI7
5	GPI6
4	GPI5
3	GPI4
2	GPI3
1	GPI2
0	GPI1

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

MControl status

Section	Bits	Notes
Control Access Owner	31	Remote
	30	MControl Fieldbus Interface
	29	Reserved
	28	Reserved
	27	Reserved
	26	Reserved
	25	HMI Local (MView)
	24	Soft Local
	23	Hardware Local
Various input signals	23	Set if TOL bypass is activated
	22	Set if TOL startup inhibit is active
	21	Set if M*Control* is locked out: The M*Control* can not be started due to TOL startup inhibit or an input signal
	20	Set if M*Start* is in isolated position
	19	Must be 0: Reserved for future use.
	18	Must be 0: Reserved for future use.
	17	Set if main switch is in on position
	16	Set if test switch is in on position
0	15-13	Starter dependent information
Failsafe	12	Starter entered failsafe status
EaroEntryT	11	Reserved
	10	Trip Acknowledged
	9	Trip New
	8	Alarm
State	7-0	Starter dependent information

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Starter dependent information

Bits	NR-DOL	NR-DOL RCU	REV-DOL	REV-DOL RCU	NoStarter	NR-DOl StarDelta	NrDol Softstarter	Actuator	Transparent (with/without Control)	Feeder	C-Feeder	C-Feeder RCU
15	0	0	0	0	1	0	0	1	0	1	1	1
14	0	1	0	1	1	0	1	0	0	1	1	1
13	0	1	0	1	1	1	0	0	0	0	0	0
7	Ready	Ready	Ready	Ready	Ready	Ready	Ready	Ready	Ready	0	Ready	Ready
6	0	0	0	0	(Runs) Star	Softstart	0	Open Position	0	0	0	0
5	0	0	0	0	0	Softstop	0	Close Position	0	0	0	0
4	0	0	(Runs) CCW	(Runs) CCW	0	0	0	0	K3	0	0	0
3	0	0	(Runs) CW	(Runs) CW	0	0	(Runs) CCW	(Runs) open	K2	0	0	0
2	0	0	Runs	Runs	0	0	(Runs) CW	(Runs) close	K1	0	0	0
1	Runs	Runs	Stopped	Stopped	Runs	Runs	Runs	Runs	0	Closed	Closed	Closed
0	Stopped	Stopped	Stopped	Stopped	Stopped	Stopped	Stopped	Stopped	0	Opened	Opened	Opened

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Command format

The command data are available in 3 formats:

- Format 0
- Format 1
- Format 2

Each format extends the range of control.

The control via Profibus depends very much on the “Auto-Mode”-Bit of the control structure. Whenever this Bit is set and “HW-Local” is not active the control is possible via Profibus.



To avoid future incompatibilities all unused and reserved bits in the command structure must be set to 0.

Format 0:

Byte	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
0	Reserved	Trip Reset	Auto-Mode	Unused	Unused	Starter Control		
1	Failsafe activate	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved

Format 1:

Byte	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
0	Reserved	Trip Reset	Auto-Mode	Unused	Unused	Starter Control		
1	Failsafe activate	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved
2	GO7	GO6	GO5	GO4	GO3	GO2	GO1	GO0
3	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Format 2:

Byte	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
0	Reserved	Trip Reset	Auto-Mode	Unused	Unused	Starter Control		
1	Failsafe activate	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved
2	GO7	GO6	GO5	GO4	GO3	GO2	GO1	GO0
3	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved
4	GPO7	GPO6	GPO5	GPO4	GPO3	GPO2	GPO1	GPO0
5	AO1– high[o/oo]*)							
6	AO1– low[o/oo] *)							
7	APO1– high[o/oo] *)							
8	APO1– low[o/oo] *)							
9	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved
10	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved
11	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved
12	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved	Reserved

*) Example: For a AO1/APO1 setpoint of 66,5 % the value 665 has to be written!

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

The starter dependent control bits are encoded as follows:

Starter type	Bit 2	Bit 1	Bit 0
NR-DOL NR-DOL-RCU	Start	Stop	Reserved (=0)
REV-DOL REV-DOL-RCU	Start CW	Stop	Start CCW
NR-DOL StarDelta	Start	Stop	Reserved (=0)
NoStarter	Start CW	Stop	Start CCW
NR-DOL Softstarter	Start	Stop	Reseverd (=0)
Transparent	K3	K2	K1
Transparent with Control	Reserved (=0)	Reserved (=0)	K1 (Open/Close)
Transparent without Control	Reserved (=0)	Reserved (=0)	Reserved (=0)
Actuator	Start open	Stopped	Start close
Feeder	Reserved (=0)	Reserved (=0)	Reserved (=0)
C-Feeder	Close	Open	Reserved (=0)
C-Feeder RCU	Close	Open	Reserved (=0)

If “Stop” is set the starter is stopped and the other bits are invalid.

“Start CW” and “Start CCW” as well as “K1” and “K2” may not be set simultaneously.

If Actuator is open “Start open” command is ignored. If Actuator is closed “Start close” command is ignored.

Profibus Byte/Bit	Function	
Byte 0 Bit 6	Trip Reset	1 = if there are resettable trips the trips are reset
Byte 0 Bit 5	Auto Mode	1 = the control is passed to Profibus if CA=”Hardware Local” is not active.
Byte 0 Bit 2 Byte 0 Bit 1 Byte 0 Bit 0	Starter *Control*	Starter dependent *Control* bits *(see table above)*
Byte 1 Bit 7	Failsafe	1 = Profibus master is failsafe master
Byte 2 Bit 7	GO 7	General purpose out 7 will follow this bit as long as AutoMode is set
Byte 2 Bit 6	GO 6	General purpose out 6 will follow this bit as long as AutoMode is set
Byte 2 Bit 5	GO 5	General purpose out 5 will follow this bit as long as AutoMode is set

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Profibus Byte/Bit	Function	
Byte 2 Bit 4	GO 4	General purpose out 4 will follow this bit as long as AutoMode is set
Byte 2 Bit 3	GO 3	General purpose out 3 will follow this bit as long as AutoMode is set
Byte 2 Bit 2	GO 2	General purpose out 2 will follow this bit as long as AutoMode is set
Byte 2 Bit 1	GO 1	General purpose out 1 will follow this bit as long as AutoMode is set
Byte 2 Bit 0	GO 0	General purpose out 0 will follow this bit as long as AutoMode is set
Byte 3 Bit 7	GPO 7	General purpose out 7 (persistent) will follow this bit as long as AutoMode is set
Byte 3 Bit 6	GPO 6	General purpose out 6 (persistent) will follow this bit as long as AutoMode is set
Byte 3 Bit 5	GPO 5	General purpose out 5 (persistent) will follow this bit as long as AutoMode is set
Byte 3 Bit 4	GPO 4	General purpose out 4 (persistent) will follow this bit as long as AutoMode is set
Byte 3 Bit 3	GPO 3	General purpose out 3 (persistent) will follow this bit as long as AutoMode is set
Byte 3 Bit 2	GPO 2	General purpose out 2 (persistent) will follow this bit as long as AutoMode is set
Byte 3 Bit 1	GPO 1	General purpose out 1 (persistent) will follow this bit as long as AutoMode is set
Byte 3 Bit 0	GPO 0	General purpose out 0 (persistent) will follow this bit as long as AutoMode is set
Byte 4	GAO high	High byte of general purpose analogue out will follow this byte as long as AutoMode is set
Byte 5	GAO low	Low byte of general purpose analogue out will follow this byte as long as AutoMode is set
Byte 7	GPAO high	High byte of general purpose analogue out (persistent) will follow this byte as long as AutoMode is set
Byte 8	GPAO low	Low byte of general purpose analogue out (persistent) will follow this byte as long as AutoMode is set

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Contact us

ABB Low Voltage Systems
Publication Editor:
ABB Automation Products GmbH
Ladenburg, Germany

Copyright© 2009 ABB
All rights reserved.

Publication No.
1TGC910187M0201

Local Contacts on
www.abb.com/mns

Power and productivity
for a better world™



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group is an independent supplier of quality pre-owned equipment

Gold-standard solutions

Extend the life of your critical industrial, commercial, and military systems with our superior service and support.

We buy equipment

Planning to upgrade your current equipment? Have surplus equipment taking up shelf space? We'll give it a new home.

Learn more!

Visit us at **artisantg.com** for more info on price quotes, drivers, technical specifications, manuals, and documentation.

Artisan Scientific Corporation dba Artisan Technology Group is not an affiliate, representative, or authorized distributor for any manufacturer listed herein.

We're here to make your life easier. How can we help you today?

(217) 352-9330 | sales@artisantg.com | artisantg.com

ARTISAN® TECHNOLOGY GROUP