ARTISAN®
TECHNOLOGY GROUP

Your **definitive** source for quality pre-owned equipment.

Artisan Technology Group
(217) 352-9330 | sales@artisantg.com | artisantg.com

Full-service, independent repair center
with experienced engineers and technicians on staff.

We buy your excess, underutilized, and idle equipment
along with credit for buybacks and trade-ins.

Custom engineering
so your equipment works exactly as you specify.

- Critical and expedited services
- In stock / Ready-to-ship
- Leasing / Rentals / Demos
- ITAR-certified secure asset solutions

Expert team | Trust guarantee | 100% satisfaction

All trademarks, brand names, and brands appearing herein are the property of their respective owners.

Find the *Laurel L51001FR* at our website: *Click HERE*

LAUREATE SERIES 2

COUNTER / TIMER / SERIAL INPUT METER
OWNERS MANUAL



Now with Ethernet

Intertek
4006497

LAUREL Electronics Inc.
3183-G Airway Ave, Costa Mesa, CA, 92626, USA
Tel: (714) 434-6131 • Fax: (714) 434-3766 • Website: www.laurels.com

1. ORDERING GUIDE

Configure a model number in this format: **L50200FR**

L.....**Counter / timer / serial input meter**
Includes screw terminal connectors.

Processors & Display Color

5 .....Basic, Green LED
6 ..... Basic, Red LED
7 ..... Extended, green LED
8 ..... Extended, red LED

Note: ”Extended” adds custom curve linearization and other capabilities as indicated.

Power

0 . .....85-264 Vac, 90-300 Vdc
1 ... .10-48 Vdc, 12-30 Vac

Setpoint Output

0 .....None
1…… ..... Two 8A contact relays
2..... .....Two 120 mA solid state relays
3…… .....Four 8A contact relays
4..... ..... Four 120 mA solid state relays

Analog Output

0 .....None
1 .....Single 4-20 mA, 0-10 V, -10 to +10 V
2 ..... Dual 4-20 mA, 0-20 mA, 0-10 V

Digital Interface

0 .....None
1 ..... RS232
2 ..... RS485
4 ..... RS485-Modbus
5 .....USB
6 .....USB-to-RS485 converter
7 ..... Ethernet
8 .....Ethernet-to-RS485 converter

Signal Conditioner

None……...6-Digit Remote Display
FR.....Dual Channel Pulse or AC Input

Basic counter
Frequency (2 channels), rate (2 channels), total (up or down, 2 channels), period (2 channels), stopwatch, time interval, square root of rate, or 6-digit remote display.

Extended counter

Above plus rate and total simultaneously, custom curve linearization, arithmetic functions (A*B, A/B, A+B, A-B, A/B-1), phase angle, duty cycle, up/down counting, batch control.

Process Receiver & Totalizer Signal

VF1 ..... 4-20mA
VF2 ..... 0-1mA
VF3 ..... 0-10V

Basic counter
Rate, square root of rate (use with differential pressure or target type flow meters), process signal totalizer.

Extended counter
Above plus custom curve linearization, batch control, time based on rate.

Quadrature Input

QD ..... Position, length, rate

Basic counter
Position or length from encoders. Accepts differential or single-ended inputs: 1x, 2x or 4x, plus zero index.

Extended counter
Above plus bidirectional rate (rate and position are not simultaneous).

Options

BL……..... Blank lens, no button pads

Accessories

CBL01 .. …… RJ11-to-DB9 RS232 cable
Connects meter to PC com po
CBL02 .....USB-to-DB9adapter for CBL01
CBL05 ..... USB cable to PC USB port

2. TABLE OF CONTENTS

1. ORDERING GUIDE 2
2. TABLE OF CONTENTS 3
3. PRODUCT INTRODUCTION 4
4. RECEIVING & UNPACKING 5
5. SAFETY CONSIDERATIONS 5
6. CONNECTOR WIRING INFORMATION 6
7. MECHANICAL ASSEMBLY 8
8. FRONT PANEL SETUP KEYS 10
9. ENABLING & LOCKING OUT MENU ITEMS 12
10. DUAL CHANNEL PULSE OR AC INPUT SIGNAL CONDITIONER (FR) 13
11. PROCESS RECEIVER & TOTALIZER SIGNAL CONDITIONER (VF) 31
12. QUADRATURE SIGNAL CONDITIONER (QD) 38
13. SERIAL INPUT METER / REMOTE DISPLAY (NO SIGNAL CONDITIONER) 54
14. DUAL & QUAD RELAY OUTPUT OPTIONS 56
15. SINGLE & DUAL ANALOG OUTPUT OPTIONS 59
16. SERIAL COMMUNICATION OPTIONS 61
17. EXCITATION OUTPUT & POWER SUPPLY 66
18. INSTRUMENT SETUP VIA PC 67
19. CUSTOM CURVE LINEARIZATION 70
20. METER CALIBRATION 71
21. SPECIFICATIONS 72
22. GLOSSARY OF TERMS 75
23. WARRANTY 80

3. PRODUCT INTRODUCTION

Our counters are a versatile, cost effective solution to a wide range of monitoring and control applications including frequency, rate, total, period, time, phase, position, and flow. Setup can be via front panel pushbuttons or a PC. Selective lockout of front panel keys protects against accidental or unauthorized setup changes and simplifies meter use.

A dual-channel pulse or AC input signal conditioner board accommodates a wide range of applications including rate/frequency, totalizing, timing, phase angle, power factor, and duty cycle. Frequency and rate are determined by taking the inverse of period. Fast read rate is ideal for peak or valley capture and allows quick response for control applications. Adaptive digital filtering provides stable readings and control outputs while responding rapidly to actual changes of the signal. A high stability quartz crystal and digital calibration assure accurate rate and analog measurements.

A process receiver & totalizer signal conditioner board accepts 4-20 mA, 0-1 mA or 0-10V analog signals for display of rate or position. Square root extraction is selectable for use with differential pressure flow transducers.

A quadrature signal conditioner board provides accurate display of position, angle, or rate.

Ethernet USB, RS232, or RS485 (2-wire half-duplex or 4-wire full-duplex) serial communications options are available with the Modbus protocol or a simpler custom ASCII protocol. Modbus operation includes RTU or ASCII modes, up to 247 digital addresses, and up to 32 devices per RS485 line without a repeater. Ethernet-to-RS485 and USB-to-RS485 converter boards allow a meter to be interfaced to a PC and to multiple meters on an RS485 network

Meter programming can be via the meter's front panel or a PC running Windows based Instrument Setup Software. A serial interface option is required.

A standard switching power supply allows the meters to be powered worldwide from 85 to 264 Vac. An optional power supply operates from batteries or low voltage sources, such as 12-32 Vac.

A built-in isolated excitation supply with jumper-selectable 5, 10 or 24 Vdc output levels is standard and can eliminate the need for an external sensor power supply.

A dual or quad relay board is optional for alarm or control. The relays can be Form C 8A mechanical relays or 2 or 4 Form A 120 mA solid state relays. The setpoints can be latching or non-latching, be energized above or below the setpoint, or operate in a fail-safe mode.

A single or dual isolated analog output board is optional. With dual outputs, one of the outputs can be assigned to the reading (such a rate), while other reading is assigned a non-displayed item (such as total). The outputs can be 0-20 mA, 4-20 mA, 0-10V, or -10V to +10V.

Operation as a 6-digit serial input meter is achieved with a serial interface and no signal conditioner board, allowing the unit to serve as the remote display of a computer, PLC or other meter. With an optional dual or quad relay board, the unit can provide local alarm or On/Off control. With an optional analog output board, it can also serve as a local isolated transmitter.

The meter case meets the 1/8 DIN size standard and is sealed to NEMA-4X (IP65) when panel mounted. Mounting is from the front of the panel and requires less than 110 mm behind the panel. All wiring is via removable plugs conforming to IEC950 safety standards. All output options are isolated from meter and power grounds to 250 Vac.

4. RECEIVING & UPACKING

Your meter was carefully tested and inspected prior to shipment. Should the meter be damaged in shipment, notify the freight carrier immediately. In the event the meter is not configured as ordered or the unit is inoperable, return it to the place of purchase for repair or replacement. Please include a detailed description of the problem.

5. SAFETY CONSIDERATIONS

Warning: Use of this equipment in a manner other than specified may impair the protection of the device and subject the user to a hazard. Visually inspect the unit for signs of damage. If the unit is damaged, do not attempt to operate.

Caution:

- The unit must be connected to a Disconnect switch or a branch-circuit breaker, which must be in a suitable location
- This unit must be powered with AC (mains) from 85-264 Vac with the high voltage power supply option, or 10-48 Vdc (12-32 Vac) with the low voltage power supply option. Verify that the proper power option is installed for the power to be used. This meter has no AC (mains) switch. It will be in operation as soon as power is connected.
- The 85-264 Vac mains connector (P1 Pins 1-3) is colored Green to differentiate it from other input and output connectors. The 12-32 Vac (10-48 Vdc) mains connector is colored Black.
- Do not make signal wiring changes or connections when power is applied to the instrument. Make signal connections before power is applied. If reconnection is required, disconnect the AC (mains) power before such wiring is attempted.
- To prevent electrical or fire hazard, do not expose the instrument to excessive moisture.
- Do not operate the instrument in the presence of flammable gases or fumes; such an environment constitutes a definite safety hazard. This meter is designed to be mounted in a metal panel or a bench or wall mount style case. The spacing around the meter and the ventilation must be sufficient to maintain the ambient temperature at less than 55°C.
- Verify the panel cutout dimensions, and mount according to instructions.

Symbols used

Caution (refer to accompanying documents)

Caution, risk of electric shock.

Equipment protected throughout by double insulation or reinforced insulation.

Earth (ground) terminal.

Both direct and alternating current.


Operating environment:

The meter is Class II (double insulated) equipment designed for use in Pollution degree 2.


6. CONNECTOR WIRING INFORMATION

CONNECTORS

Connectors for signal and power are U/L rated screw-clamp terminal blocks that plug into mating jacks on the circuit board. Communication connectors are a single RJ11 plug for RS232, a type B jack for USB, dual RJ11 or RJ45 plugs for RS485, or RJ45 for Ethernet. The functions of controls inputs 1 and 2 are menu selectable. Control input 2 can be converted to a +5V, 50 mA power output. Please see page 66.



P1 - POWER AND DIGITAL CONTROLS




Warning: Hazardous voltages may be present on pins 4, 5 & 6 of P1 since digital ground is tied to pin 3 of P5 (-Signal Input). Keep pin 3 close to earth ground to minimize common mode voltage or shock hazard at pins 4, 5 & 6 of P1.


P5 - SIGNAL INPUT

VF -- VOLTAGE-TO-FREQUENCY CONVERTER


4-WIRE PROCESS TRANSMITTER



2-WIRE PROCESS TRANSMITTER




FR -- DUAL CHANNEL PULSE INPUT



Ground pins 4 & 6 are internally connected.


QD -- QUADRATURE INPUT (DIFFERENTIAL)



Z input or excitation is jumper selectable. With differential quadrature inputs and an external power supply, connect ground of the external supply to Pin 6 of P1.

QD -- QUADRATURE INPUT (SINGLE-ENDED)

Select 5V or 10V excitation to match encoder.




P2 - SETPOINT CONTROLLER

DUAL MECHANICAL RELAY OUTPUTS




QUAD MECHANICAL RELAY OUTPUTS




P3 - SERIAL OMMUNICATIONS


RS232 INTERFACE




RS485, RJ11, FULL DUPLEX




RS485, RJ45, FULL DUPLEX



DUAL SOLID STATE RELAY OUTPUTS




QUAD SOLID STATE RELAY OUTPUTS




P4 - SINGLE ANALOG OUTPUT

UNIPOLAR CONNECTIONS




BIPOLAR CONNECTIONS




P4 – DUAL ANALOG OUTPUT uses two unipolar connections.

RS485, RJ11, HALF DUPLEX




RS485, RJ45, HALF DUPLEX



7. MECHANICAL ASSEMBLY


REMOVING THE REAR PANEL

First remove any connectors. Use one hand to press in the two sides of the rear of the case, and the other hand to press down the two protruding tab releases at the top of the rear panel (see figure below). This will unhook the rear panel from the case.



Rear Panel

REMOVING THE ELECTRONICS & INSTALLING OPTION BOARDS



With the rear panel removed, the electronic assembly will easily slide out through the rear of the case.

Options boards plug into the main board at the front of the meter. These are plug-and-play and may be installed in the field. New boards will be recognized by the meter software for access to the appropriate menu items. You may need to remove rear panel knock-outs to fit new boards.

Note: When an option board is installed correctly, the top and bottom edges of the main board and option board are aligned. Misaligned boards will burn out the electronics.


Option Board	Main Board Plug	Rear Panel Jack
Power supply	P11	J1
Relay board	P12	J2
Serial interface board	P13	J3
Analog output board	P14	J4
Signal conditioner board	P15	J5

REASSEMBLING YOUR METER

Slide the electronics assembly back into the case until the display board is seated flush against the front of the case. Insert the bottom tabs of the rear panel into the case, and then carefully align the board connectors with the openings in the rear panel. Ensure that all option boards are properly aligned with the molded board retaining pins on the inside of the

rear panel. Once the rear panel is in place, reinstall the input/output screw clamp terminal plugs.

PANEL MOUNTING




Slide the meter into the 45 x 92 mm 1/8 DIN panel cutout. Ensure that the provided gasket is in place between the front of the panel and the back of the meter bezel.

The meter is secured by two pawls, each held by a screw. Turning a screw clockwise extends the pawl outward. Turning the screw clockwise further tightens it against the panel to secure the meter.

Turning a screw counterclockwise loosens the pawl and retracts it into its well. This allows the meter to be inserted into the panel cutout for installation, or to be removed from the panel cutout following installation.

Note: In no case should a screw be removed from its pawl. Doing so would cause the screw and pawl to fall off and likely get lost.



Dimensioned case drawings

8. FRONT PANEL SETUP KEYS



Counter Front Panel

There are four front panel keys, which change function for the **Run Mode** and **Menu Mode**, effectively becoming eight keys. The keys are labeled with alphanumeric captions (MENU, PEAK, RESET, ALARMS) for the Run Mode and with symbols (⮕ right arrow, ▶ right triangle, ▲ up triangle, ⬅ left arrow) for the Menu Mode.

FRONT PANEL LOCKOUT

The Menu Mode will not work with most meters shipped from the factory, since all menu items have been disabled in software and a lockout jumper is in place. This jumper needs to be removed for the Menu Mode to work, and values under **Loc 1** through **Loc 4** need to be set to "0" via the front panel for these menu items to be available. See Section 9. The paragraphs below assume that all lockout features have been removed.

MENU MODE KEY ACTION

In the Menu Mode, pressing a key momentarily advances to the next item. Holding down the key advances through multiple menu items for fast menu navigation**.**

KEYS IN RUN MODE

MENU ⮕

MENU Key. Pressing *MENU* from the Run Mode enters the Menu Mode. Pressing *MENU* repeatedly will step the meter through the various menu items (if these have not been locked out) and then back to the Run Mode.

PEAK ▶

PEAK Key. Pressing *PEAK* causes the peak value of the input signal to be displayed. The peak display blinks to differentiate it from the normal present value display. Pressing *PEAK* again will return the display to the present value.



RESET Key. Pressing *RESET* with *PEAK* resets peak and valley values. Pressing *RESET* with *ALARMS* resets latched alarms. Pressing *RESET* with *MENU* performs a meter reset (same as power on). Pressing and releasing *RESET* without pressing another key changes the displayed item if the mode has multiple items. For Item 1, the V LED is out. For Item 2, the V LED is on. For Item 3, the V LED is flashing.



ALARMS Key. Pressing *ALARMS* once displays the setpoint for Alarm 1. Pressing it again displays the setpoint for Alarm 2. Pressing it again returns to the present value. After 30 seconds, the meter automatically returns to the present value. Timing is automatically reset whenever the *ALARMS* key is pressed.

KEYS IN MENU MODE



Right Arrow Key (MENU). Pressing ↵ steps the meter through all menu items that have been enabled and then back to the Run Mode. With the dual-channel pulse input signal conditioner board and no option boards, available menu items will be **InPut**, **SEtuP**, **ConFiG**, **dSPYno**, etc. Actual menu items will vary depending on the *Input* selection and boards detected in the meter. If a change has been made to a menu item, that change is saved to non-volatile memory when the ↵ key is pressed next, and **StoreE** is displayed briefly.

To return the meter to the run mode after **StoreE** has been displayed, you can press the ↵ key repeatedly to step through all top-level menu selections until *rESEt* is displayed briefly. As a shortcut, to return to the run mode after **StoreE** has been displayed, you can press ▲ then ↵ simultaneously. Again, *rESEt* will be displayed briefly.



Right Triangle Key (Digit Select).

- Pressing ► from the *InPut* menu brings up all meter functions available with the meter's signal conditioner. For the dual-channel pulse input signal conditioner, these are **rAtE**, **PEriod**, **totAL**, **ti Int**, **Stop t**, **PHASE**, **duty C**.
- Pressing ► from most menus selections sequentially selects digit positions 1 - 6, as indicated by a flashing digit: **0**00000, 0**0**0000, 00**0**000, 000**0**00, 0000**0**0, 00000**0**.
- Pressing ► from *dEC.Pt1* brings up a decimal point display of type **11.1111.** Pressing ► from *dEC.Pt2* brings up a decimal point display of type **22.2222**.



Up Triangle Key (Value Select).


- Pressing ▲ from a selected meter function, such as **rAtE**, will select the a specific operating mode within that function, such as **A OnLy**. Always press the MENU key to save your selection. Do not press the ▲ key to the right, or your selection will be lost.
- Pressing ▲ for a flashing digit position or decimal point position will increment that item. Pressing the MENU key will save any changes.



Left Arrow Key (Reverse Menu). Pressing ↵ has the same effect as pressing ↵, except that menu items are brought up in reverse order. Pressing ↵ repeatedly will backtrack to the previous menu items all the way to meter *rESEt* and return to the run mode.

9. ENABLING & LOCKING OUT MENU ITEMS

For security reasons and ease of counter operation, any or all menu items can be disabled or "locked out" so that they are no longer accessible from the front panel. Each function to be disabled can be set to "1" under menu headers *Loc 1-4*, while each function to be enabled can be set to "0." Access to the menu headers *Loc 1-4* can in turn be locked out by installing a hardware jumper on the power supply board. With the jumper installed, the operator only has access to previously enabled menu items, not to the menu headers *Loc 1-4* and hence not to the menu items below. With the jumper removed, the operator has access to menu headers *Loc 1-4* and hence to the menu items below.



SETTING HARDWARE LOCKOUT JUMPER

To access the lockout jumper, remove the rear panel per Section 9 and locate jumper **"a"** in the lower portion of the power supply board next to the input connectors (see figure at right).

The analog output is sourcing. Do not put an external voltage source in series with it. Applying an external 24 Vdc source will burn out the analog output board.

SETTING SOFTWARE LOCKOUTS

When setting up the counter, it may be necessary to enable menu items by setting lockout digits to "0". Following setup, reset the digits to "1" if you do not want the menu item to be changed by an operator.

Loc 1 **Loc 2** **Loc 3** **Loc 4**

Press the ↵ MENU key until *Loc 1, Loc 2, Loc 3* or *Loc 4* is displayed, as desired. **Note:** lockout jumper **"a"** must be removed (see above).

111111

Press ► to display the lockout status, consisting of 0's and 1's. The left digit will flash. Press ► again to step to the next digit, which will flash.

000000
123456

Press ▲ to set the flashing digit to "0" to enable the menu item or to "1" to disable. Press *MENU* to enter. See the table to the right for list of menu items that can be enabled or disabled.

Enabled / Disabled Menu Items

Loc 1
3 - Input type selection
4 - Setup, Config, Dspyno
5 - Gate time, timeout, batch setup
6 - Filter setup


Loc 2
3 - Slope, decimal points
4 - Scale, offset, resolution, 2-coord.
5 - Alarm setup
6 - Alarm setpoint programming

Loc 3
3 - Analog output setup & scaling
4 - Serial communications configuration
5 - Calibration
6 - Change displayed Item #

Loc 4
3 - View peak value
4 - View alarm setpoints
5 - Front panel resets (peak & latched alarms)
6 - Front panel reset (cold reset only)

10. DUAL CHANNEL PULSE OR AC INPUT SIGNAL CONDITIONER

The dual channel signal conditioner board is used for the frequency, rate, period, timing, batch control, phase and duty cycle meter functions. The board needs to be configured via jumpers for the input signal type and level. It is recognized by the meter software, which will bring up the applicable menu items. The dual channel pulse input signal conditioner does not require calibration, since the quartz crystal oscillator used for frequency and timing applications is located on the counter main board.



A3 B3	A2 B2	Hysteresis Limits	
		High Limit	Low Limit
-	a	+12 mV	-12 mV
-	b	+150 mV	-150 mV
-	-	+1.15V	-1.15V
a	a	+60 mV	+30 mV
a	b	+600 mV	+350 mV
a	-	+2.1V	+1.25V
b	a	-30 mV	-60 mV
b	b	-350 mV	-600 mV
b	-	-1.25V	-2.1V

Jumper Settings for Expected Signal Levels

The jumper settings for Channel A (A2 & A3) and Channel B (B2 & B3) need to be set for the expected signal voltage. Jumpers need to be set for both channels even if only one channel is used.

A voltage input is recognized as a pulse when it exceeds a high hysteresis limit, and is unrecognized as a pulse when it falls below a low hysteresis limit. Hysteresis is used to avoid false counts due to electrical noise. The wider the hysteresis band, the better the noise immunity. To count negative pulses, reverse the inputs to the counter.

Built-in pull-up or pull-down resistors are used to provide a +5V or -5V signal bias with open collector devices or dry contact closures. They should not be used for other input types. Debounce circuitry keeps the meter from counting extra pulses due to contact bounce.

High voltages V_{in} can be attenuated by a resistor R in series with the meter's input resistance, which is 100 kΩ for non-biased signals greater than ±3V. This creates a voltage divider, so that the sensed voltage is V_{in} x 100 kΩ / (R + 100 kΩ).

Function	Group	Jumper	Jumper effect	Input Resistance
Frequency Response	A0 & B0	- b a	1 MHz max 30 kHz max 250 Hz max	1 MΩ for V_{in} within ±3V 100 kΩ for V_{in} outside ±3V
Bias Resistor	A1 & B1	- a b	No pull-up or pull-down 10 kΩ pull-up to +5V 10 kΩ pull-down to -5V	 10 kΩ 10 kΩ
Contact Debounce	A4 & B4	b a, c c	No debounce 3 msec 50 msec	No effect on input resistance. One selection is required for the board to be recognized.

Common Jumper Settings

Input Type	Vmax	A0 & B0	A1 & B1	A2 & B2	A3 & B3	A4 & B4
Logic levels	250V	-	-	-	a	b
NPN open collector	+25V	b	a	-	a	b
PNP open collector	-15V	b	b	-	-	b
Contact closures	-15V, +25V	a or b	a	-	a	a, c
Line frequency	250V	b	-	-	-	a, c
Magnetic pickup, 2-wire	250V	b	-	a	-	b

OVERVIEW OF OPERATING MODES

RATE & FREQUENCY MODES

Frequency in Hz is determined by timing an integral number of pulses over a user-specified *gate time* from 0 to 199.99 sec and taking the inverse of average period. The typical display update rate of the meter is gate time + 1 period + 30 ms Selecting a longer gate time produces a more stable reading as more cycles are averaged, but slows down the update rate. At very low frequencies, the update rate is controlled by the period. A *time-out* from 0 to 199.99 sec is also selectable. This is the time the meter waits for a signal to start or end a conversion. While waiting, the counter will display rEAdinG. If a signal is not received before the *time-out* ends, the meter reads zero. The longer the time-out, the lower the minimum frequency the meter can display.

With a *scale factor* of 1 and a *scale multiplier* of 1, frequency is displayed in Hz with no decimal point. Appling a *scale multiplier* from 10 to 100000 (in decade steps) and setting the decimal point increases resolution from 0.1 to 0.00001 Hz. Decreasing the *scale multiplier* from 1 to 0.00001 (in decade steps) and setting the decimal point allows display in kHz or MHz. Note that the same 100 kHz frequency can be displayed as 100000 Hz or 100.000 kHz simply by moving the decimal point.

DISPLAY FREQUENCY IN Hz WITH 1 Hz RESOLUTION

Dig. No.	S	1	2	3	4	5	6						
InPut				r	A	t	E	A		O	n	L	y
SEtuP			0	0	0	0	0						
ConFiG				1	0	0	0						
dSPyno						0	1						
GAtE t			0	0	0.	2	2						
ti Out			0	0	1.	0	0						
FiLtEr			0	0	1	0	5						
SLOPE						0	1						
DecPt1		1	1	1	1	1	1.						
SCALE1		1.	0	0	0	0	0						1
OFFSt1		0	0	0	0	0	0						
CALib	-	Do Not Change Calib											

Application: Display frequency from 1 Hz to 999999 Hz with no decimal, display update rate of 4/sec, and adaptive moving average filter for 6 readings.

Solution: Set Input to “Rate A Only.” Set Config to display to 999999 counts. Set Gate Time to .22 sec so that the display update rate becomes .22 sec +30 ms +1 period. Set Time-out to 1 sec, so that frequencies under 1 Hz are displayed as 0. Set Filter for adaptive moving average with a 1.6 sec time constant. Apply a *scale value* of 1.00000 and a *scale multiplier* of 1 for direct readout in Hz.

DISPLAY 0-50.00 RATE FROM 1-10 kHz INPUT, COORDINATES OF 2 POINTS METHOD

Dig. No.	S	1	2	3	4	5	6						
InPut				r	A	t	E	A		O	n	L	y
SEtuP			0	0	1	0	0						
ConFiG				1	0	0	0						
dSPyno						0	1						
GAtE t			0	0	0.	2	2						
ti Out			0	0	1.	0	0						
FiLtEr			0	0	1	0	5						
SLOPE						0	1						
DecPt1		1	1	1	1.	1	1						
Lo In1		0	0	1	0	0	0						
Lo rd1		0	0	0	0.	0	0						
Hi In1		0	1	0	0	0	0						
Hi rd1		0	0	5	0.	0	0						
CALib	-	Do Not Change Calib											

Application: Display 0-50.00 (with two decimal places) for 1-10 kHz input. Use coordinates of 2 points scaling method.

Solution: Set Input to "Rate A Only." Select "coordinates of 2 points" scaling method under Setup. This is easier than scale and offset. Set DecPt1 to two places. Then enter the low input and desired low reading, and high input and desired high reading, as shown.

DISPLAY RATE IN GPM FROM 36.67 PULSE/GALLON TURBINE FLOW METER

Dig. No.	S	1	2	3	4	5	6						
InPut				r	A	t	E	A		O	n	L	y
SEtuP			0	0	1	0	0						
ConFiG				1	0	0	0						
dSPyno						0	1						
GAtE t			0	0	0.	2	2						
ti Out			0	0	0.	1	0						
FiLtEr			0	0	1	0	5						
SLOPE						0	1						
DecPt1		1	1	1	1.	1	1						
Lo In1		0	0	0	0	0	0						
Lo rd1		0	0	0	0.	0	0						
Hi In1		0	0	3	6.	6	7						
Hi rd1		0	0	6	0.	0	0						
CALib	-	Do Not Change Calib											

Application: Display rate in GPM to two decimal places from flow meter calibrated to 36.67 pulses/gallon.

Solution: Set Input to "Rate A Only. Under Setup, select "coordinates of 2 points" scaling method. Set DecPt1 to two places. Then enter the low input and desired low reading, and high input and desired high reading, as shown. In this example, we want to display 60.00 (GPM) from an input of 36.67 Hz. Note that the meter's native rate measurements are in Hz. There will be 60 times more gallons per minute than per second.

Rate in engineering units is displayed from measured frequency by applying an appropriate *scale factor* and setting the decimal point. The *scale factor* consists of a *scale value* from 0.00000 to 9.99999 (fixed decimal point and settable digits) and a *scale multiplier* from 0.00001 to 100000 (in decade steps). When using the *coordinates of 2 points method* to scale the meter, the low input and high input frequencies are entered in Hz.

- **RATE A ONLY (A_OnLy)** displays rate or frequency for Channel A. The latter utilizes *SCALE1*, *OFFSt1* and *dECPt1*. Channel B is not used.
- **RATE A B (A__b__)** displays rate or frequency for Channel A as Item #1 or for Channel B as Item #2. The latter utilizes *SCALE2*, *OFFSt2* and *dECPt2*.
- **RATE A, TOTAL A (A_Atot)** (Extended counter) displays Rate for Channel A as Item #1 and Total for Channel A as Item #2 since last reset. Total may count down from an offset by entering a negative scale factor. Only used for non-linear inputs.

- **RATE A, TOTAL B (A_btot)** (Extended counter) displays Rate for Channel A as Item #1 and Total for Channel B as Item #2.
- **RATES A+B**, **A-B**, **AxB**, **A/B, A/B-1** (Extended counter) display arithmetic combinations of Rates A and B as Item #1, Rate A as Item #2, and Rate B as Item #3. With rates A and B scaled to produce a ratio close to 1 and an offset of -1, the special combination A/B-1, called "Draw," can display percentage changes, such as elongation of material passing between rollers. Channels A and B use DecPt1. The arithmetic combination uses DecPt2 and can be shifted by factors of 10 using a rESoLN (resolution) entry.

TOTAL MODES

DISPLAY TOTAL IN GALLONS FROM 36.67 PULSE/GALLON TURBINE FLOW METER

Dig. No.	S	1	2	3	4	5	6						
InPut			t	o	t	A	L	A		O	n	L	y
SEtuP			1	0	1	0	0						
ConFiG				1	0	0	0						
dSPyno						0	1						
GAtE t			0	0	0.	0	1						
SLOPE						0	1						
DecPt1		1	1	1	1.	1	1						
Lo In1		0	0	0	0	0	0						
Lo rd1		0	0	0	0.	0	0						
Hi In1		0	0	3	6.	6	7						
Hi rd1		0	0	0	1.	0	0						
CALib	-	Do Not Change Calib											

Application: Display total in gallons with two decimal places for flow meter calibrated to 36.67 pulses/gallon.

Solution: Set Input to "Total A Only." Under Setup, select "Restore totals at power-on" and coordinates of 2 points method. This is the preferred scaling method. Set gate time to its minimum of 0.01 sec for smooth display updates. Set DecPt1 to two places. Then enter low input and desired low reading, and high input and desired high reading for display of 1.00 gallon for 36.67 pulses, as shown.

DISPLAY SIMULTANEOUS RATE & TOTAL FROM 36.67 PULSE/GALLON FLOW METER

Dig. No.	S	1	2	3	4	5	6						
InPut				r	A	t	E	A		b	t	o	t
SEtuP			1	0	1	1	0						
ConFiG				1	1	0	0						
dSPyno						0	1						
GAtE t			0	0	0.	1	0						
ti Out			0	0	1.	0	0						
FiLtEr			0	0	1	0	5						
SLOPE						0	1						
DecPt1		1	1	1	1.	1	1						
DecPt2		2	2	2	2	2	2.						
Lo In1		0	0	0	0	0	0						
Lo rd1		0	0	0	0.	0	0						
Hi In1		0	0	3	6.	6	7						
Hi rd1		0	0	6	0.	0	0						
Lo In2		0	0	0	0	0	0						
Lo rd2		0	0	0	0	0	0						
Hi In2		0	0	3	6	6	7						
Hi rd2		0	0	0	1	0	0						
CALib	-		0	0	0	0	0	Do Not Change Calib					

Application: Display flow rate in GPM with two decimal places and total gallons with no decimal places from the same flow meter signal calibrated to 36.67 pulses/gallon.

Solution: Use an Extended counter, as required for simultaneous rate and total. Apply the signal in parallel to channels A & B. Set Input to Rate A, Total B (A_btot). For flow rate in GPM (Item #1), set DecPt1 to two decimals. Scale the display by entering Lo In1, Lo rd1, Hi In1, Hi rd1 as shown for display of 60.00 GPM for 36.67 pulses/sec. For total in Gallons (Item #2), set DecPt2 to no decimals. Scale the display by entering Lo In2, Lo rd2, Hi In2, Hi rd2 as shown for display of 100 gallons for 3667 pulses. Enter a Gate Time, such as 0.1 sec, which is only used to slow down the display update rate, not the actual totalizing rate.

DISPLAY TOTAL VOLUME BY ADDING TWO TURBINE FLOW METER CHANNELS

Dig. No.	S	1	2	3	4	5	6						
InPut			t	o	t	A	L	A		+		b	
SEtuP			1	0	1	1	0						
ConFiG				1	1	0	0						
dSPyno						0	1						
GAtE t			0	0	0.	0	1						
SLOPE						0	0						
DecPt1		1	1	1	1.	1	1						
DecPt2		2	2	2	2.	2	2						
Lo In1		0	0	0	0	0	0						
Lo rd1		0	0	0	0.	0	0						
Hi In1		0	0	3	6.	6	7						
Hi rd1		0	0	0	1.	0	0						
Lo In2		0	0	0	0	0	0						
Lo rd2		0	0	0	0.	0	0						
Hi In2		0	0	5	8.	1	2						
Hi rd2		0	0	0	1.	0	0						
rESoLn							1						
CALib	-	Do Not Change Calib											

Application: Display total liquid volume in gallons to two decimal places from 2 pipes dispensing liquids into the same tank. Flow meter A is calibrated to 36.67 pulses/gallon, flow meter B to 58.12 pulses/gallon.

Solution: Arithmetic operations require the Extended counter. Apply flow meter output A output to Channel A, flow meter output B to Channel B. Set Input to "Total A+B." Set Gate Time to 0.01 sec for fast display updates. Select a positive trigger slope for A and B. Set DecPt2, which applies to Grand Total, and DecPt1, which applies to Totals A and B, both to two decimal places. Under Setup, select the coordinates of 2 points scaling method for A and B. To scale A, enter 36.67 (pulses) for Hi In1 and 1.00 (gallons) for Hi Rd1. To scale B, enter 58.12 (pulses) for Hi In2 and 1.00 (gallons) for Hi Rd2. The normal display will be Item #1 (Grand Total). Press the ▲ key to view Item #2 (Total A) and Item #3 (Total B).

TOTAL A ONLY (A_OnLy) displays the number of pulses applied to Channel A as Item #1. If scientific notation is not selected, overflows beyond 999,999 are recorded in units of 1,000,000 as Item #2. For example, a total of 17,345,676 would be displayed as 345,675 in Item #1 and 17 in Item #2. This capability gives the counter 12-digit capability. Items #1-2 can also be retrieved via serial communications.

- **TOTAL A B (A__b__)** displays Total A as Item #1 or Total B as Item #2.
- **TOTALS A+B**, **A-B**, **AxB**, **A-B, A/B** (Extended counter) display arithmetic combinations of Totals A and B as Item #1, Total A as Item #2, and Total B as Item #3.
- **TOTAL A-B UD (A-b_Ud)** is the same as TOTAL A-B, except that counts are subtracted on an ongoing basis, instead of subtracting totals. This avoids round-off errors with large totals. Overflows are displayed as #2. (See Total A only)
- **BURST (_burST)** (Extended counter) displays the total number of signal bursts applied to Channel B as Item #1. Gate time must be greater than the period of the lowest signal frequency and less than the minimum time between bursts. Time-out should be set to 0.
- **TOTAL A B U/D (A_bU/d)** (Extended counter) displays Total A as Item #1, where the up or down count direction is determined by an input on Channel B. If the menu item *SLOPE* is set to 0 for Channel B, (digit 6), an input level on B below the jumper set Low Threshold B causes the count to go up, and an input level above the jumper set High Threshold causes the count to go down. If *SLOPE* for Channel B is set to 1, the opposite occurs. The maximum frequency on A that can be counted is 250 kHz, or a minimum of 4 µs between pulses.

- **TOTAL A B INHIBIT (A_bInH)** (Extended counter) displays Total A as Item #1, where counting may be inhibited by a control input on Channel B. If the menu item *SLOPE* is set to 0 for Channel B (digit 6), a low input level on B allows counting, and a high input level inhibits counting. If the *SLOPE* for Channel B is set to 1, the opposite occurs. The maximum frequency on A that can be counted is 1 MHz. Overflows are displayed as #2. (See Total A only)

BATCH CONTROL MODE (_bAtCH)

BATCH CONTROL WITH A 36.67 PULSE/GALLON TURBINE FLOW METER

Dig. No.	S	1	2	3	4	5	6
InPut				r	A	t	E
SEtuP			1	0	0	1	0
ConFiG				1	1	0	0
dSPyno						0	1
GAtE t			0	2	0.	0	0
bAtCH			1	0	0	1	0
FiLtEr			0	0	1	0	5
SLOPE						0	0
DecPt1		1	1	1	1.	1	1
DecPt2		2	2	2	2.	2	2
SCALE1		2.	7	2	7	0	2
OFFSt1		0	0	0	0	0	0
Lo In2		0	0	0	0	0	0
Lo rd2		0	0	0	0.	0	0
Hi In2		0	0	3	6.	6	7
Hi rd2		0	0	6	0.	0	0
rESoLn							1
SourcE				1	1		
AL SEt			0	0	2	4	0
dEUn1b		0	0	0	0.	0	0
dEUn2b		0	0	0	0.	0	0
CALib	-	Do Not Change Calib					

b	A	t	C	H
				1

ALARM KEY	S	1	2	3	4	5	6
SETPT1	0	0	5	5.	0	0	4.
SETPT2	0	0	5	4.	0	0	

Application: Fill 55 gallon tanks, measuring flow with a 36.67 pulses/gallon flow meter. Slow down filling at 54 gallons. Cycle batches automatically with 20 sec between cycles. Display batch total & fill rate to 2 places. Track number of batches.

Solution: Use an Extended counter with a dual relay output board. Apply the flow meter signal to Channels A & B. Set Input to "Rate Batch." Set Batch to count up to Setpoint1. Use Gate Time as delay between batches. Make Item #2 the number of batches. Set Gate Time to 20 sec. Set an adaptive moving average filter, which will apply to rate only, not totals. Set DecPt1 and DecPt2 to two decimal places for Items #1 and #3 (Batch Total and Rate). Scale Item #1 (Batch Total) by entering a Scale1 of 2.72702 (counts per pulse) and a Setpoint1 of 55.00, which will serve as the batch setpoint in gallons. Scale Item #3 (Rate) using the coordinates of 2 points method so that 36.67 pulses/sec will be displayed as 60.00 GPM. Set Setpoint2 to 54.00 to activate Relay 2 to slow the fill rate at 54.00 gallons.

Batch control (Extended counter) uses the meter with a dual relay controller board to control repetitive fill operations. Relay #1 is used as the batch relay. Relay #2 (or Setpoint #2) can be assigned to another limit, such as pre-warn to slow filling near the setpoint, end-of-process, or rate alarm. The same signal is applied to Channels A and B. When digit 6 of *bAtCH* (Action after Meter Reset) is set to zero, the following applies:

- **In batch control mode without external resets,** the meter waits until the *RESET* key is pushed. It then energizes Relay #1 and displays the changing Batch Total. When the preset value is reached, Relay #1 de-energizes for the duration of the gate time setting. Relay #1 then re-energizes, the Batch Total resets, and the fill cycle repeats.

- **In batch control mode with external resets,** pushing the *RESET* key initiates cycling. Grounding an external *Gate* input for a minimum of 3.33 ms then starts each new fill cycle by energizing Relay #1 and resetting the Batch Total. *Gate time* is not used.

Three values are tracked and can be separately displayed by pressing the *RESET* key: Item #1, the Batch Total; Item #2, the Grand Total of all batches or Number of Batches (selectable during setup); and Item #3, the Fill Rate.

- **Item #1, Batch Total,** is the total for that batch. It may be configured to count up from 0 to a preset, or to count down from a preset to 0. The preset value is placed in *SETPT1*. *SCALE1* is positive whether counting up or down.
- **Item #2, Grand Total,** is the sum of previous Batch Totals and the current Batch Total. It can overflow to exponential format.
- **Item #2 (alternate), Number of Batches,** is the current count of batches. *SCALE1* does not apply. *dECPt1* is set to 1.
- **Item #3, Fill Rate,** is calculated with a fixed 20 ms (or 1 cycle min) *gate time*. It may be displayed as Item #3.

PERIOD MODES

- **PERIOD A ONLY (A_OnLy)** displays period of Channel A as Item #1.
- **PERIOD A B (A__b__)** displays period of Ch A as Item #1 and of Ch B as Item #2.
- **PERIODS A+B**, **A-B**, **AxB**, **A-B**, **A/B** (Extended counter) display arithmetic combinations of Periods A and B as Item #1, Period A as Item #2, and Period B as Item #3.

TIMING MODES

STOPWATCH TIMING, "ON" TIME OF A MACHINE WITH 0.00 HOUR RESOLUTION

Dig. No.	S	1	2	3	4	5	6
InPut		S	t	o	P		t
SEtuP			1	0	1	1	0
ConFiG				4	0	0	0
dSPyno						0	1
GAtE t			0	0	0.	0	1
SLOPE						1	0
DecPt1		1	1	1	1.	1	1
DecPt2		2	2	2	2	2	2.
Lo In1		0	0	0	0	0	0
Lo rd1		0	0	0	0.	0	0
Hi In1		0	0	3	6	0	0
Hi rd1		0	0	0	1.	0	0
Lo In2		0	0	0	0	0	0
Lo rd2		0	0	0	0	0	0
Hi In2		0	0	3	6	0	0
Hi rd2		0	0	0	0	0	1
CALib	-	Do Not Change Calib					

A		t	o		b

Application: Display daily "on" time of a machine in hours with 2 decimals. For machine maintenance, also track accumulated hours since last reset.

Solution: Tie a relay across the AC input to the machine so that the relay closes to ground when power is applied. Apply the relay output across both the A & B inputs so that the voltage is 5V when the contacts are open and 0V when they are closed. Set Input to "Stopwatch A to B." Select negative trigger slope for A and positive for B. Under Config, set Display Mode to sec. Set Gate Time to 0.01 sec. Select the coordinates of 2 points scaling method for Item #1 (daily time) and Item #2 (accumulated time). For Item #1, set DecPt1 to 2 places, set Hi In1 to 3600 (sec) and Hi Rd1 to 1.00 (hrs). For Item #2, set DecPt2 to 0 places, set Hi In2 to 3600 and Hi Rd2 to 1 (hr).

STOPWATCH TIMING, CLOSING TIME OF A RELAY TO 0.001 MSEC RESOLUTION

Dig. No.	S	1	2	3	4	5	6
InPut		S	t	o	P		t
SEtuP			1	0	1	1	0
ConFiG				4	0	0	0
dSPyno						0	1
GAtE t			0	0	0.	0	1
SLOPE						0	0
DecPt1		1	1	1.	1	1	1
DecPt2		2	2	2	2	2	2.
Lo In1		0	0	0	0	0	0
Lo rd1		0	0	0.	0	0	0
Hi In1		1.	0	0	0	0	0
Hi rd1		9	9	9.	9	9	9
Lo In2		0	0	0	0	0	0
Lo rd2		0	0	0	0	0	0
Hi In2		0	0	0	0	0	0
Hi rd2		0	0	0	0	0	0
CALib	-	Do Not Change Calib					

A		t	o		b

Application: Measure the closing time of a relay in msec to 0.001 msec resolution.

Solution: To close the relay, apply the same positive voltage to the relay coil and to meter Channel A. Wire the relay so that 0V is applied across Channel B when the contacts are closed. Set Input to "Stop-watch A to B." Select a positive trigger slope for A and a negative trigger slope for B. Under Config, set Display Mode to sec. Set Gate Time to 0.01 sec. Select the coordinates of 2 points scaling method for Item #1. Set DecPt1 to 3 places. Set Hi In1 to 1.00000 (sec) and Hi Rd1 to 999.999 (msec). Ignore Item #2, which is not used.

- **TIME INTERVAL A TO B (A_to_b)** measures time between periodic inputs on Channels A and B. Timing starts when a pulse is applied to Channel A (positive edge if slope A is 0, negative edge if slope A is 1), and ends when a pulse is applied to Channel B (positive edge if slope B is 0, negative edge if slope B is 1). Pulse width may be measured by tying inputs A and B together and selecting a positive or negative edge to start (Slope A) and the opposite polarity edge to stop (Slope B). If multiple start and stop pulses occur during the *gate time*, the displayed value is the average of pulse widths. The value is updated at the end of each *gate time*. With a scale factor of 1, one count is one microsecond. Use Scale Value x Scale Multiplier to set other units of time. The display update rate is set by Gate time.
- **INVERSE TIME INTERVAL (__1/Ab)** (Extended counter)
  Takes the inverse of time interval for a reading in /second. For example, if the average time interval for object to travel from point A to point B is 5 seconds, the inverse time interval would be 0.2/sec. For the average speed of the objects, simply apply a scale factor equal to the distance separating the two points, such as 7 (inches). Speed would then be displayed as 7 x 0.2 = 1.4 (inches/sec). For a 6-digit reading, apply a scale multiplier of 10,000 and move the decimal point.
- **STOPWATCH A TO A (A_to_A)** measures time between the same positive (or negative) edge of start and stop pulses applied to Channel A. Single event times may be displayed as Item #1 in decimal seconds, minutes or hours, or in HH:MM:SS clock format. Time is reset to 0 when a new start pulse occurs. Accumulated total time may be displayed as Item #2. With a scale factor of 1, one count is one microsecond. Use Scale Value x Scale Multiplier to set other units of time. The display update rate is set by Gate time.
- **STOPWATCH A TO B (A_to_B)** measures time between a start pulse on Channel A and a stop pulse on Channel B. Timing is the same as for A to A, except that positive or negative edges may be selected separately for Channels A and B. This allows the pulse width measurement of single pulses by tying Channels A and B together. One slope is selected to start timing, and the opposite slope to stop timing.

- **INVERSE STOPWATCH TIME A TO A & A TO B (__1/AA & 1/AB)** (Extended counter)
  Takes the inverse of stopwatch time for a reading in /second. For example, if the travel time for an object to travel from point A to point B is 5 seconds, the inverse stopwatch time interval would be 0.2/sec. For the speed of that object, simply multiply by a scale factor equal to the distance separating the two points, such as 7 (inches). Speed would then be displayed as 7 x 0.2 = 1.4 (inches/sec). For a 6-digit reading, apply a scale multiplier of 10,000 and move the decimal point.

DUTY CYCLE MODE (duty_C) (Extended counter)

Measures ON or OFF period of periodic square waves as a percentage of total period over a *gate time* which is selectable from 10 ms to 199.99 s. The same signal is applied to Channels A and B. ON or OFF time is measured between positive and negative edges of the signal, with averaging over multiple integral periods over the selected gate time. Apply a scale factor of 1 for readings in percent. Apply a 10 or 100 multiplier and move the decimal point by 1 or 2 positions for 0.1% or 0.01% resolution.

PHASE ANGLE MODE (PHASE) (Extended counter)

Measures the phase relationship in degrees between two signals with the same period over a *gate time* which is selectable from 10 ms to 199.99 s, with averaging over multiple integral periods over the selected gate time. The two signals are applied to Channels A and B. For best accuracy, both signals should have the same amplitude and be larger than 1 Vac. For small amplitudes, use low hysteresis levels like ±12 mV. For larger amplitudes and high expected electrical noise, use higher hysteresis levels like ±150 mV or ±1.15V. If you experience erratic readings due to noise, set jumpers for 250 Hz frequency response and experiment with 3 msec debounce.

PHASE ANGLE MEASUREMENT TO 0.01º RESOLUTION

Dig. No.	S	1	2	3	4	5	6
InPut			P	H	A	S	E
SEtuP			0	0	1	0	0
ConFiG				1	1	0	0
dSPyno						0	1
GAtE t			0	0	0.	2	2
ti Out			0	0	1.	0	0
bAtCH			0	0	0	0	0
FiLtEr			0	0	1	0	5
SLOPE						0	0
DecPt1		1	1	1	1.	1	1
Lo In1		0	0	0	0	0	0
Lo rd1		0	0	0	0.	0	0
Hi In1		1.	0	0	0	0	0
Hi rd1		0	0	0	1.	0	0
CALib	-	Do Not Change Calib					

	-	1	8	0	+

Application: Measure phase angle difference to 0.01º resolution between two AC signals centered around 0º.

Solution: Use an Extended counter, as required for phase angle measurement. Jumper the signal conditioner for maximum sensitivity to catch zero voltage crossings and minimize the effects of amplitude jitter. Apply one AC signal to Channel A and one to Channel B. Set Input to “PHASE +/-180º.” The display will be in degrees. Set a gate time of 0.22 sec for 4 display updates per sec. Set both trigger slopes to positive. Set two decimal places. Select the coordinates of 2 points scaling method. Set Hi In1 to 1.00000 (degrees) and Hi Rd1 to 1.00 (degrees). As an alternative, select the scale and offset scaling method. Then simply select a scale value of 1.00000 and a multiplier of 100.

POWER FACTOR MODE (PHASE) (Extended counter)

The power factor of an AC power system is the ratio of real power in watts (W) divided by apparent power in volt-amperes (VA). For sinusoidal signals differing by a phase angle θ, power factor will be cos(θ), which is how the meter computes power factor.

Power Factor readings can range from 1.000 to 0.000 with three decimal places and an accuracy of 0.1% for sinusoidal signals at 50/60 Hz AC line frequency. Maximum frequency is 1 kHz. While Power Factor is always positive, the meter artificially assigns a minus sign to Power Factor for negative phase angles, and it sets Power Factor to 0 for phase angles greater than 90°.

POWER FACTOR MEASUREMENT TO 0.001 RESOLUTION

Dig. No.	S	1	2	3	4	5	6
InPut			P	H	A	S	E
SEtuP			0	0	0		0
ConFiG				0	2	0	0
dSPyno						0	1
GAtE t			0	0	0.	2	2
ti Out			0	0	1.	0	0
bAtCH			0	0	0	0	0
FiLtEr			0	0	1.	0	5
SLOPE						0	0
DecPt1		1	1	1.	1	1	1
SCALE1		1.	0	0	0	0	0
OFFSt1		0	0	0.	0	0	0
CALib	-	Do Not Change Calib					

	-	1	8	0	+

			1	0	0

Application: Display power factor to 0.001 resolution between two AC voltage waveforms.

Solution: Use an Extended counter, as for phase angle measurement. Jumper the signal conditioner for maximum sensitivity to catch zero voltage crossings and minimize the effects of amplitude jitter. Apply AC signals to channels A and B. Set Input to “PHASE -180+”. Set gate time of 0.22 sec for 4 display updates per sec. Set Config to 0200. SCALE and OFFSt are not used.

Power Factor is stored in the custom curve section of the Extended counter and uses "PHASE -180+" as the input type. Setting ConFiG to X1XX sets up for Phase Angle. Setting ConFiG to X2XX enables Power Factor scaling. First set up the unit as a phase meter and verify that it is working properly. You will need to set the jumpers on the signal input board for the signal level to be applied to the A and B inputs.

The decimal point is set to xxx.xxx . Scale and Offset are disabled.

Power Factor is displayed as a value from -0 to -1 and +1 to +0, with a discontinuity at -1, +1 corresponding to zero phase angle. As the display traverses the range from -0 to -1 and +1 to +0, an Output Control Value (OCV) is created that extends from 0 to +2.000 with a continuous positive slope and no discontinuity at zero phase angle.

The first half of OCV is created by assuming the absolute value of the display value from -0 to -1, and hence becomes 0 to +1.000. The second half of OCV is created by subtracting the displayed value +1 to 0 from 2.000, and hence becomes +1.000 to +2.000. While never displayed, OCV is the source value for determining the analog output, for setpoint comparisons, and for filtering purposes, as it eliminates the discontinuity observed at zero phase angle.

Example of Using OCV of 0 to 2.000 for setting Analog Output

4 mA output is desired for Power Factor of -0.4 (OCV = 0.400).
20 mA output is desired for Power Factor of +0.4 (OCV = 2.000 - 0.4 = 1.600).

Set up as follows: deC.Pt to 111.111, AnSEt to 21, An_Lo to +0.400 (4 mA point), An_Hi to +1.600 (20 mA point), dEC.Pt as desired to 111.111, 1111.11 or 11111.1

Example of Using OCV of 0 to 2.000 for setting the Alarm Setpoints

It is desired to operate Relay1 when the Power Factor falls outside of ±0.75 display range (or outside of 0.750 to 1.250 OCV range).

Set up as follows: ConFig to x1xx to take meter out of Power Factor, dEC.Pt to 111.111, SEtPt1 to 1.000, AL_SEt to 00000, dEUtn1 to 0.250 to activate Relay1 above 1.250 and below 0.750, dEC.Pt as desired to 111.111, 1111.11 or 11111.1 . Return meter to Power Factor mode by setting ConFig to x2xx

DUTY CYCLE MEASUREMENT TO 0.01% RESOLUTION

Dig. No.	S	1	2	3	4	5	6						
InPut		d	u	t	y		C	A		t	o		b
SEtuP			0	0	1	0	0						
ConFiG				1	1	0	0						
dSPyno						0	1						
GAtE t			1	0	0.	0	0						
ti Out			1	9	9.	9	9						
FiLtEr			0	0	1	0	5						
SLOPE						0	1						
DecPt1		1	1	1	1.	1	1						
Lo In1		0	0	0	0	0	0						
Lo rd1		0	0	0	0.	0	0						
Hi In1		1.	0	0	0	0	0						
Hi rd1		0	0	0	1.	0	0						
CALib	-	Do Not Change Calib											

Application: Measure "on" period of periodic pulses as a % of total period with .01% resolution over a time interval of 100 sec.

Solution: Duty cycle requires the Extended counter. Apply the same signal to Channels A & B. Set Input to "Duty Cycle (A to B) / A." The native counts will be in percent. For a positive "on" pulse, set trigger slope to positive for A and negative for B. Select the coordinates of 2 points scaling method. Set Hi In1 to 1.00000 (percent) and Hi Rd1 to 1.00 (percent). As an alternative, select the scale and offset scaling method. Then simply select a scale value of 1.00000 and a multiplier of 100.

1/RATE MODE FOR TIMING (Extended Counter)

An example of 1/Rate is the time it takes an item takes to travel through an oven at a measured rate. Like Rate, 1/Rate can be scaled using Scale1 and Offset1. With no offset and Scale1 set to 1, Rate A for the full analog input range will be displayed as 0-100000, and 1/A will be displayed as 1000000/A. Both the A and 1/A readings are multiplied by Scale1 and offset by Offset1. With Scale1 set to 1, A is displayed as 10000, and 1/A is displayed as 100. With Scale1 set to 2, A is displayed as 20000, and 1/A is displayed as 200. If square root extraction is applied to rate, the rate display A is replaced by $\sqrt{A}$, and 1/A is replaced by $1/\sqrt{A}$. 1/A does not apply to custom curves.

Scaling may also be done by using the coordinates of 2 points method, which automatically calculates scale and offset for the displayed value when the low and high input signals and the corresponding desired low and high displayed values are entered.

SETUP OF COUNTERS WITH DUAL CHANNEL PULSE SIGNAL CONDITIONER

If the *MENU* ↵ key does not work, see Section 9 "Enabling & Locking Out Menu Items." Menus are dynamic. Menu items will only appear if appropriate for previously made menu selections. For example, Batch menu items will only appear if "Batch" was selected under "Rate." Extended counter items will only appear if "Extended" was selected under "Config."

MENU ↵ *Press Menu*	PEAK ▶ *Press Digit Select Key*		RESET ▲ *Press Value Select Key*
InPut Input	**rAtE** Rate modes	Basic	**A b** Rate for Channel A (Item #1). Rate for Channel B (Item #2).
			A_OnLy Rate for Channel A only (Item #1).
		Extended meter only	**bAtCH** Batch control mode. Batch total (Item #1). Grand total or number of batches (Item #2). Fill rate (Item #3).
			A_Atot Rate for Channel A (Item #1). Total for Channel A (Item #2).
			A_btot Rate for Channel A (Item #1). Total for Channel B (Item #2).
			A + b Sum of rates A & B (Item #1). Rate A (Item #2). Rate B (Item #3).
			A – b Difference of rates A and B (Item #1). Rate A (Item #2). Rate B (Item #3).
			A . b Product of rates A and B (Item #1). Rate A (Item #2). Rate B (Item #3).
			A / b Rate A divided by rate B (Item #1). Rate A (Item #2). Rate B (Item #3).
			A/b–1 Draw, rate A / rate B -1 (Item #1). Rate A (Item #2). Rate B (Item #3).
	Period Period modes	Basic	**A b** Period Channel A (Item #1). Period for Channel B (Item #2).
			A_OnLy Period for Channel A only (Item #1).
		Extended meter only	**A + b** Sum of periods A and B (Item #1). Period A (Item #2). Period B (Item #3).
			A - b Difference of periods A and B (Item #1). Period A (Item #2). Period B (Item #3).
			A . b Product of periods A and B (Item #1). Period A (Item #2). Period B (Item #3).
			A / b Ratio, period A divided by period B (Item #1). Period A (Item #2). Period B (Item #3).

MENU Press Menu	PEAK Press Digit Select Key		RESET Press Value Select Key
InPut (continued)	**totAL** Total modes	Basic	**A__b__** Total for Channel A (Item #1). Total for Channel B (Item #2).
			A_OnLy Total for Channel A only (Item #1).
		Extended meter only	**A-b_Ud** Running total (Item #1) of counts on Channel A minus counts on Channel B.
			_burSt Count of bursts (Item #1). Burst frequency (Item #2).
			b_ArAt Total for Channel B (Item #1). Rate for Channel A (Item #2)
			A_bU/d Total for Channel A (Item #1) with up/down control via Channel B.
			A_b_InH Total for Channel A (Item #1) with count inhibit control via Channel B.
			_A_+_b Sum of totals A and B (Item #1). Total A (item #2). Total B (Item #3).
			_A_-_b Difference of totals A and B (Item #1). Total A (item #2). Total B (Item #3).
			_A_._b Product of totals A and B (Item #1). Total A (item #2). Total B (Item #3).
			_A_/_b Ratio of totals A and B (Item #1). Total A (item #2). Total B (Item #3).
	ti__Int Time interval mode	Basic	**A_to_b** Time interval (Item #1) for periodic events with pulse signals applied to Channels A & B.
		Ext.	**__1/Ab** Inverse of time interval (/sec) (Item #1) for periodic events with pulse signals applied to A & B.
	StoP_t Stopwatch modes	Basic	**A_to_A** Single event time (Item #1) between pulses on Channel A, or accumulated total time (Item #2).
			A_to_b Single event time (Item #1) with pulses on Channels A &B, or accumulated total time (Item #2).
		Extended	**__1/AA** Inverse of stopwatch time (/sec) (Item #1) for single events with pulse signals applied to A & A.
			__1/Ab Inverse of stopwatch time (/sec) (Item #1) for single events with pulse signals applied to A & B.

MENU Press Menu	PEAK Press Digit Select Key		RESET Press Value Select Key
InPut (continued)	PHASE Phase angle modes	Extended	0-360 Span from 0° to 360°. Select for phase angles centered around 180° (Item #1).
			-180+ Span from -180° to +180°. Select for phase angles centered around 0° (Item #1).
	duty_C Duty cycle mode	Ext.	A_to_b On or Off period of square waves as a percentage of total period (Item #1).
SEtuP Setup	_00000 Stored totals		0 Zero totals at power-on. 1 Restore totals at power-on.
	_00000 Leading zeros		0 Blank leading zeros. 1 Display leading zeros.
	_00000 Scaling method 1		0 Input scale factor 1 and offset 1. 1 Use coordinates of 2 points method.
	_00000 Scaling method 2		0 Input scale factor 2 and offset 2. 1 Use coordinates of 2 points method.
	_00000 Operation of rear connector control inputs 1 & 2. **True** = 0V or tied to digital ground). **False** = 5V or open).		0 1 = Meter Reset*, 2 = Function Reset* 1 1 = Meter Reset*, 2 = Meter Hold* 2 1 = Meter Reset*, 2 = Peak or Valley Display* 3 1 = Meter Reset*, 2 = External Gate* 4 1 = Function Reset*, 2 = Meter Hold* 5 1 = Valley Only Display**, 2=Peak Only Display** 6 1 = Function Reset*, 2 = External Gate* 7 1 = Meter Hold**, Peak or Valley Display** 8 1 = Reset Total A**, 2 = Reset Total B** 9 1 = Force Alarm1, 2 = Force Alarm2 A 1 = Meter Reset*, 2 = Display Blank* B 1 = Function Reset*, 2 = Display Blank* C 1 = Meter Hold*, 2 = Display Blank* D 1 = Peak or Valley Display**, 2 = Display Blank** E 1 = Display Blank, 2 = External Gate* F 1 = Display Item #2, 2 = Display Item #3 With 1 and 2 at 5V or open, Display Item #1. --- * 1 & 2 both at 0V = Meter Reset (can restore totals). ** 1 & 2 both at 0V for selections 5, 7, 8, D = Function Reset* (erases all totals).

MENU Press Menu	PEAK Press Digit Select Key	RESET Press Value Select Key
ConFiG Configu-ration	**_0**000 Display mode	**0** Normal, overload to exponential format **1** Normal, overload to 999999 **2** 1 right-hand dummy zero **3** 2 right-hand dummy zeros **4** Time display in seconds (not in µsec) **5** Time display in HH.MM.SS format (not in µsec) **6** Remote display (H, K, L commands) **7** Single-value remote display **8** Show 1st string value, slaved to another meter **9** Show 2nd string value, slaved to another meter **A** Show 3rd string value, slaved to another meter **B** Show 4th string value, slaved to another meter **C** Custom Start, Stop, Skip, Show
	__0000 Counter mode	**0** Basic counter **1** Extended counter **2** Extended counter, custom curve linearization. Used for power factor. Requires microcomputer firmware version CTR 2_32, not CTR 2_33.
	__000 Square root	**0** Linear rate input. **1** Square root rate input.
	__000 Not applicable	**0** Set to 0.
dSPyno Display #	**____0**1 PEAK key action	**0** Display Peak **1** Display Valley **2** Peak (1st push), Valley (2nd push)
	____01 Item to display after Meter Reset*	**1** Item #1* **2** Item #2* **3** Item #3*
GAtE_t Gate time*	**_0**00.00 **_0**0.00 **_00**0.00 **_000**.00 **_000**.0 **_000**.00 Select digit to flash.	Select **0** thru **9** for flashing digit to set gate time* in seconds. Decimal point location is fixed for 10 ms resolution.
ti_Out Time-out*	**_0**00.00 **_0**0.00 **_00**0.00 **_000**.00 **_000**.0 **_000**.00 Select digit to flash.	Select **0** thru **9** for flashing digit to set time-out* in seconds. Decimal point location is fixed for 10 ms resolution.
bAtCH Batch setup	**_0**0000 Handling of extra pulses that overshoot beyond batch Preset.	**0** Do not count extra pulses in batch total or grand total. Only add preset values to grand total. **1** Count extra pulses in batch total but not in grand total. **2** Do not count extra pulses in batch total, but do count them in grand total. **3** Count extra pulses in batch total and in grand total.
	_00000 Count direction	**0** Reset batch to 0 and count up to Setpoint 1. **1** Reset batch to Setpoint 1 and count down.
	_00000 Batch triggering	**0** Use internal gate time as delay between batches. **1** Use External Input B to trigger each new batch.

MENU Press Menu	PEAK Press Digit Select Key	RESET Press Value Select Key
bAtCH (continued)	_00000 Definition of Item #2	**0** Make Item #2 the Grand Total of all batches. **1** Make Item #2 the Total Number of batches.
	_00000 Action after Meter Reset	**0** Display "rEAdy." R*ESET* key starts batching. **1** Start batching upon Meter Reset.
FiLtEr Filtering	_00000 Filter type	**0** Adaptive moving average filter. Restarts filter for high actual changes in signal. **1** Conventional moving average filter without reset.
	_00000 Peak & Valley filtering	**0** Peak* or Valley* value from unfiltered signal. **1** Peak* or Valley* value from filtered signal.
	_00000 Display filtering	**0** Display value of unfiltered signal. **1** Display value of filtered signal.
	_00000 Adaptive filter threshold	**0** Set adaptive filter for normal noise. **1** Set adaptive filter for presence of high transients.
	_00000 Filter time constant	**0** No filter **1** 0.1 sec **2** 0.2 sec **3** 0.4 sec **4** 0.8 sec **5** 1.6 sec **6** 3.2 sec **7** 6.4 sec
SLOPE Triggering	____00 Trigger slope, Channel A	**0** Positive slope **1** Negative slope
	____00 Trigger slope, Channel B	**0** Positive slope **1** Negative slope
dEC.Pt1 Decimal pt1	1.11111 Decimal point flashes.	1.11111 11.1111 111.111 1111.11 11111.1 111111. Press ▲ to shift the decimal point.
dEC.Pt2 Decimal pt2	2.22222 Decimal point flashes.	2.22222 22.2222 222.222 2222.22 22222.2 222222. Press ▲ to shift the decimal point.
Scale and Offset scaling method if selected under **SEtuP**		
SCALE1 Scale Factor 1	0.00000 0.00000 0.00000 0.00000 0.00000 0.00000 Select digit to flash for Scale Value. When right digit has been set, press ► one more time for the Scale Multiplier.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. This will set the Scale Value* from -9.99999 to 9.99999 with a fixed decimal point. Then press ▲ to select a value from **0.00001** to **100000** in decade steps to set the Scale Multiplier. Scale Factor = Scale Value x Scale Multiplier
OFFSt1 Offset 1	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Use **dEC.Pt1** to set the decimal point.
SCALE2	Scale Factor 2. Same setup process as for Scale Factor 1.	
OFFSt2	Offset 2. Same setup process as for Offset 1.	

MENU Press Menu	PEAK Press Digit Select Key	RESET Press Value Select Key
Coordinates of 2 points scaling method if selected under **SEtuP**		
Lo_In1 Low signal input 1.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Move decimal point location when flashing.
Lo_rd1 Reading at Lo In1.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Decimal point is fixed by **dEC.Pt1**.
Hi_In1 High signal input 1.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Move decimal point location when flashing.
Hi_rd1 Reading at Hi In1.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Decimal point is fixed by **dEC.Pt1**.
Lo_In2 Low signal input 2.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Move decimal point location when flashing.
Lo_rd2 Reading at Lo In2.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Decimal point is fixed by **dEC.Pt1**.
Hi_In2 High signal input 1.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Move decimal point location when flashing.
Hi_rd2 Reading at Hi In1.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Decimal point is fixed by **dEC.Pt1**.
Preset function. Displayed for Total modes **A-b_Ud** or **A_bU/d**		
PrESEt Preset*	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. **dEC.Pt1** is used. When the meter counts up and reaches the Preset, it reverts to Offset1. When the meter counts down and reaches Offset1, it reverts to Preset. Set to 0 for no Preset.
Special curve offset for square root or custom curve linearization if selected under **ConFiG**		
rd0_In	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Decimal point is fixed by **dEC.Pt1**.

Scale multiplier for combinations of two channels (e.g., AxB, A/B) if selected under **InPut**		
rESoLn Resolution	Flashing 6-digit number in decade steps from **0.00001** to **100000**	Press ▲ to select. This is a multiplier **R** to avoid overflow or underflow of arithmetic combinations of Channels A and B.
Quartz crystal time base calibration		
_CALib	Time base calibration.	Do not change. See Calibration section of manual.
Option dependent menu items		
SourcE AL SEt AL S34 dEUn1H dEUn2H dEUn1b dEUn2b dEUn3H DEUn4H DEUn3b DEUn4b Menu items related to **alarm setup** These will only appear if a relay board is detected. If so, please see Section 14.		
An_SEt An_Lo An_Hi or **An_SEt An_Lo1 An_Hi1 An_Lo2 An_Hi2** Menu items related to **analog output**. These will only appear if a single or dual analog output board is detected. If so, please see Section 15.		
_SEr_1 _SEr_2 SEr_3 _SEr_4 Menu items related to **serial communications**. These will only appear if an RS232 or RS485 I/O board is detected. If so, please see Section 16.		
Menu lockout items		
_Loc_1 _Loc_2 _Loc_3 _Loc_4 Menu items used to enable or lock out (hide) other menu items. **Loc** menu items may be locked out by a hardware jumper. Please see Section 9.		

** See Glossary for explanation of item.*


11. PROCESS RECEIVER & TOTALIZER SIGNAL CONDITIONER

This signal conditioner board converts 0-1 mA, 4-20 mA or 0-10 V analog process signals to a frequency signal, which is then read by the counter main board and processed mathematically for display of rate, total (time x rate), time based on rate, or batch control. The board needs to be configured via jumpers for the input signal range. The meter software recognizes the board and brings up the applicable menu items for it.

Please see further manual pages for the following features: relay output, analog output, serial communications, and transducer excitation output.

JUMPER SETTINGS

Input Range	Jumper Position A1
0-10V	None
0-1 mA	a
4-20 mA	b



OPERATING MODES

RATE FROM A 4-20 mA OUTPUT FLOW METER

Dig. No.	S	1	2	3	4	5	6						
InPut		U	F	4	-	2	0	A		O	n	L	y
SEtuP			0	0	1		0						
ConFiG				1	0	0	0						
dSPyno						0	1						
GAtE t			0	0	0.	2	2						
FiLtEr			0	0	1	0	5						
DecPt1		1	1	1.	1	1	1						
Lo In1		0	4.	0	0	0	0						
Lo rd1		0	0	0.	0	0	0						
Hi In1		2	0.	0	0	0	0						
Hi rd1		0	0	5.	8	2	0						
CALib	-	Do Not Change Calib											

Application: Display rate in GPM to 3 decimal places from a 4-20 mA flow meter where 4 mA = 0 GPM and 20 mA = 5.820 GPM.

Solution: Set Input to "VF420 A only." Under Setup, select the coordinates of 2 points scaling method. Under Config, select a display of 999999 and filtering. Set the decimal point to 3 places. For scaling, set Hi In1 to 20.0000 and Hi Rd1 to 5.820. Set Gate Time to 0.22 sec, which will provide noise averaging at a display update rate of 4/sec. Also set a 1.6 sec adaptive moving average filter to process the equivalent of 6 readings.

RATE MODE (Basic Counter)

Rate A accepts 0-1 mA, 4-20 mA or 0-10 V analog signals, as set by jumpers, for display in engineering units. Scaling is normally done using the coordinates of 2 points method, with entry of low and high input signals, and the low and high values to be displayed. Scaling can also be done by entering scale and offset. With 0-1 mA or 0-10 V, the full analog input range is displayed as 0-100000 with Scale1 at 1 and Offset1 at 0. With 4-20 mA, set an "rd0_in" offset to 04.000. With 1-5V, set the "rd0_in" offset to 01.000

Measurements are averaged over a gate time, which is programmable from 10 ms to 199.99 sec. Selecting a long gate time provides a slower display update rate but superior noise filtering. Moving average filtering is also available. Square root extraction is selectable un ConFiG for use with differential pressure flow transducers. Custom curve linearization is available with the Extended counter.

RATE & TOTAL MODE (Basic Counter)

TOTAL FROM A 4-20 mA OUTPUT FLOW METER

Application: Display Total from a 4-20 mA flow meter where 4 mA = 0 and 20 mA = 5.820 GPM.

Dig. No.	S	1	2	3	4	5	6						
InPut		U	F	4	-	2	0	A		A	t	o	t
SEtuP			0	0	1		0						
ConFiG				1	1	0	0						
dSPyno						0	1						
CutoFF			0	0.	0	1	0						
GAtE t			0	0	0.	1	0						
FiLtEr			0	0	1	0	3						
DecPt1		1	1	1.	1	1	1						
DecPt2		2	2	2	2.	2	2						
Lo In1		0	4.	0	0	0	0						
Lo rd1		0	0	0.	0	0	0						
Hi In1		2	0.	0	0	0	0						
Hi rd1		0	0	5.	8	2	0						
SCALE2		1.	6	6	6	6	7			0.	0	0	1
OFFSt2		0	0	0	0.	0	0						
CALib	-	Do Not Change Calib											

Solution: Set Input to "VF420 A A Total," which displays Rate as Item #1 & Total as Item #2. Under dSPyno, select Item #2 to be displayed after meter reset. Set Gate Time to 0.1 sec to provide fast display updates with noise averaging. Set DecPt1 to 3 places for Rate and DecPt2 to 2 places for Total. Under Setup, select the coordinates of 2 points scaling method for Rate. Set Hi In1 to 20.0000 and Hi Rd1 to 5.820. You will need to use scale & offset to scale Total. Total is calculated as the product of displayed rate and time in seconds. Since our rate is in units per minute, we have to divide by 60, then multiply by 0.1 for two decimal places. Enter 1.66667 for Scale2 and a multiplier of 0.001. You may also enter a Cutoff such as 0.010 GPM, below which zero offset errors and negative values will not be totalized.

Rate A, Total A allows rate to be displayed as Item #1 and total as Item #2. Scale2 and Offset2 apply to total. Total is calculated as the product of displayed rate and time in seconds. Since rate may be displayed in units per second, units per minute, units per hour or other units, the total must be scaled appropriately. If rate is in units per minute, multiply the total by 1/60. This is achieved by setting Scale2 to a scale factor of 1.66666 and a multiplier of 0.01. If rate is in units per hour, multiply the total by 1/3600. This is achieved by setting Scale2 to a scale factor of 2.77778 and a multiplier of 0.0001. If square root extraction or custom curve linearization have been selected, totalizing will be of the linearized rate readings.

BATCH CONTROL MODE (_bAtCH) (Extended Counter)

Batch control uses the meter with a dual relay controller board to control repetitive fill operations. Relay #1 (or Setpoint #1) is used as the batch relay. Relay #2 (or Setpoint #2) can be assigned to another limit, such as pre-warn to slow filling near the setpoint, end-of-process, or rate alarm.

- **In batch control mode the meter displaying "Ready",** the meter waits until the *RESET* key is pushed, it then energizes Relay #1 and displays the changing Batch Total starting at "Offset2". When the setpoint 1 value is reached, Relay #1 de-energizes for the duration of the "time out" setting. Relay #1 then re-energizes, the Batch Total resets, and the fill cycle repeats.

- **In batch control mode with "external gate",** the meter waits a the end of every cycle until an external gate input is grounded for a minimum of 3.33 ms. This starts a new fill cycle by energizing Relay #1 and resetting the Batch Total. *Gate time* is not used.

Three values are tracked and can be separately displayed by pressing the *RESET* key: Item #1, the Batch Total; Item #2, the Grand Total of all batches or Number of Batches (selectable during setup); and Item #3, the Fill Rate.

- **Item #1, Batch Total,** is the total of input pulses for that batch. It may be configured to count up from 0 to a preset, or to count down from a preset to 0. The preset value is placed in *ALARM1*. *SCALE1* is positive whether counting up or down.
- **Item #2, Grand Total,** is the sum of previous Batch Totals and the current Batch Total. It can overflow to exponential format.
- **Item #2 (alternate), Number of Batches,** is the current count of batches. *SCALE1* does not apply. *dECPt1* is set to 1.
- **Item #3, Fill Rate,** is calculated with a fixed 20 ms *gate time*. It may be displayed as Item #3.

BATCH CONTROL WITH A 4-20 mA OUTPUT FLOW METER

Dig. No.	S	1	2	3	4	5	6
InPut				r	A	t	E
SEtuP			1	0	0	1	0
ConFiG				1	1	0	0
dSPyno						0	1
CutoFF	0	0	0	0	0.		
GAtE t			0	2	0.	0	0
bAtCH			1	0	0	1	0
FiLtEr			0	0	1	0	5
SLOPE						0	0
DecPt1		1	1	1	1.	1	1
DecPt2		2	2	2	2.	2	2
SCALE1		1.	6	6	6	6	7
OFFSt1		0	0	5	5.	0	0
Lo In2		0	4.	0	0	0	0
Lo rd2		0	0	0	0.	0	0
Hi In2		2	0.	0	0	0	0
Hi rd2		0	0	3	9.	2	0
rESoLn							1
SourcE				1	1		
AL SEt			0	0	2	4	0
dEUn1b		0	0	0	0.	0	0
dEUn2b		0	0	0	0.	0	0
CALib	-	Do Not Change Calib					

b	A	t	C	H

			0.	0	1

ALARM KEY	S	1	2	3	4	5	6
SETPT2	0	0	5	4.	0	0	

Application: Fill 55 gallon tanks. Use a 4-20 mA flow meter where 4 mA = 0 and 20 mA = 39.20 GPM. Slow down filling at 54 gallons. Cycle batches automatically with 20 sec between cycles. Display batch total & fill rate to 2 places. Also track number of batches.

Solution: Use an Extended counter with a dual relay output board. Set Input to "Rate Batch." Set Batch to count up to ALARM1, to use Gate Time as delay between batches, and to make Item #2 the number of batches. Set Gate Time to 20 sec. Set DecPt1 and DecPt 2 to two decimal places for Items #1 and #3 (Batch Total and Rate). Scale Item #3 (Rate) using the coordinates of 2 points method so that 20.0000 mA will be displayed as 39.20 GPM. Scale Item #1 (Batch Total) by entering a Scale1 of 1.66667 and a multiplier of 0.01. That is because totalizing sums readings in gallons every second. Since our rate is in GPM, we have to divide by 60. Enter an Offset1 of 55.00 to serve as the batch setpoint in gallons. Set Setpoint2 to 54.00 to activate Relay 2 to slow the fill rate.

KEYSTROKES FOR SETUP

If the *MENU* ↵ key does not work, see Section 9 "Enabling & Locking Out Menu Items." Menus are dynamic. Menu items will only appear if appropriate for previously made menu selections. For example, Batch menu items will only appear if "Batch" was selected under "Rate." Extended counter items will only appear if "Extended" was selected under "Config."


MENU ↵ *Press Menu*	PEAK ▶ *Press Digit Select Key*		RESET ▲ *Press Value Select Key*
InPut Input	**VF0-10** 0-10V full-scale input **VF4-20** 4-20 mA full-scale input **VF_0-1** 0-1 mA full-scale input	Basic	**A_OnLy** Rate for Channel A (Item #1).
		Basic	**A_Atot** Rate for Channel A (Item #1). Total for Channel A (Item #2).
		Extended	**_bAtCH** Batch control mode. Batch total (Item #1). Grand total or number of batches (Item #2). Fill rate (Item #3).
		Extended	**__1/A_** 1/Rate for Channel A (Item #1).
SEtuP Setup	**_0̲0̲0_0** Stored totals		**0** Zero totals at power-on. **1** Restore totals at power-on.
	_0̲0̲0_0 Leading zeros		**0** Blank leading zeros. **1** Display leading zeros.
	_0̲0̲0_0 Scale factor 1 setup		**0** Input scale factor 1 and offset 1. **1** Use coordinates of 2 points method.
	_000_0 Operation of rear connector inputs 1 & 2. **True** = logic 1 (0V or tied to digital ground). **False** = 0 (5V or open).		**0** 1 = Meter Reset*, 2 = Function Reset* **1** 1 = Meter Reset*, 2 = Meter Hold* **2** 1 = Meter Reset*, 2 = Peak or Valley Display* **3** 1 = Meter Reset*, 2 = External Gate* **4** 1 = Function Reset*, 2 = Meter Hold* **5** 1 = Valley Only Display**, 2=Peak Only Display** **6** 1 = Function Reset*, 2 = External Gate* **7** 1 = Meter Hold**, Peak or Valley Display** **8** 1 = Reset Total A**, 2 = Reset Total B** **9** 1 = Force Alarm1, 2 = Force Alarm2 **A** 1 = Meter Reset*, 2 = Display Blank* **B** 1 = Function Reset*, 2 = Display Blank* **C** 1 = Meter Hold*, 2 = Display Blank* **D** 1 = Peak or Valley Display**, 2 = Display Blank** **E** 1 = Display Blank, 2 = External Gate* **F** 1 = Display Item #2, 2 = Display Item #3 With 1 and 2 at 5V or open, Display Item #1. --- * 1 & 2 both at 0V = Meter Reset (can restore totals). ** 1 & 2 both at 0V for selections **5**, **7**, **8**, **D** = Function Reset* (erases all totals).

MENU Press Menu	PEAK Press Digit Select Key	RESET Press Value Select Key
ConFiG Configuration	**_0**000 Display mode	**0** Normal, overload to exponential format **1** Normal, overload to 999999 **2** 1 right-hand dummy zero **3** 2 right-hand dummy zeros **4** Time display in seconds **5** Time display in HH.MM.SS format **6** Remote display (H, K, L commands) **7** Single-value remote display **8** Show 1st string value, slaved to another meter **9** Show 2nd string value, slaved to another meter **A** Show 3rd string value, slaved to another meter **B** Show 4th string value, slaved to another meter **C** Custom Start, Stop, Skip, Show
	_0000 Counter mode	**0** Basic counter **1** Extended counter **2** Extended counter, custom curve #1 selected **3** Extended counter, custom curve #2 selected
	_0000 Linearization mode	**0** Linear rate input. **1** Square root rate input.
	_0000 Rate cutoff enable for totalizing	**0** Do not totalize rate values below **CutofFF** value. (avoids totalizing small offsets from 0 rate value or negative rate values). **1** Totalize all rates (required for bidirectional flow).
dSPyno Display #	**____01** PEAK key action	**0** Display Peak **1** Display Valley **2** Peak (1st push), Valley (2nd push)
	____01 Item to display after Meter Reset*	**1** Item #1* **2** Item #2* **3** Item #3*
CutofFF Totalizing cutoff*	**_0**0000 **_00**000 **_000**00 **_0000**0 **_0000**0 Select digit to flash.	Select **0** thru **9** for flashing digits. In A_Atot or Batch modes, meter will not totalize rate values below this cutoff to avoid totalizing small offsets from zero.
GAtE_t Gate time*	**_0**00.00 **_00**0.00 **_000**.00 **_000.0**0 **_000.0**0 Select digit to flash.	Select **0** thru **9** for flashing digit to set gate time* in seconds. Decimal point location is fixed for 10 ms resolution. This is time over which rate is measured.
ti_Out Timeout*	**_0**00.00 **_00**0.00 **_000**.00 **_000.0**0 **_000.0**0 Select digit to flash.	Select **0** thru **9** for flashing digit to set timeout* in seconds. Decimal point location is fixed for 10 ms resolution. This is time during which batch relay is de-energized at the end of a batch cycle.

MENU Press Menu	PEAK Press Digit Select Key	RESET Press Value Select Key
bAtCH Batch setup	**0**0000 & **0**0000	**0** Not used with VF Batch. Set to 0.
	00**0**00 Batch triggering	**0** Use gate time* as delay between batches. **1** Use External Input B to start each new batch.
	00000 Definition of Item #2	**0** Make Item #2 the Grand Total of all batches. **1** Make Item #2 the Total Number of batches.
	00000 Action after Meter Reset	**0** Display "rEAdy." R*ESET* key starts batching. **1** Start batching upon Meter Reset.
FiLtEr Filtering	**0**0000 Signal filtering	**0** Adaptive moving average filter. Restarts filter for high actual changes in signal. **1** Conventional moving average filter without reset.
	00**0**00 Peak & Valley filtering	**0** Peak* or Valley* value from unfiltered signal. **1** Peak* or Valley* value from filtered signal.
	00**0**00 Display filtering	**0** Display value of unfiltered signal. **1** Display value of filtered signal.
	00000 Adaptive filter setup	**0** Set adaptive filter for normal noise. **1** Set adaptive filter for presence of high transients.
	00000 Filter time constant	**0** No filter **1** 0.1 sec **2** 0.2 sec **3** 0.4 sec **4** 0.8 sec **5** 1.6 sec **6** 3.2 sec **7** 6.4 sec
dEC.Pt1 Decimal pt1	**1**.11111 Decimal point flashes.	**1**.11111 **1**1.1111 **1**11.111 **1**111.11 **1**1111.1 **1**11111. Press ▲ to shift the decimal point.
dEC.Pt2 Decimal pt2	**2**.22222 Decimal point flashes.	**2**.22222 **2**2.2222 **2**22.222 **2**222.22 **2**2222.2 **2**22222. Press ▲ to shift the decimal point.
Scale and Offset scaling method if selected under **SEtuP**		
SCALE1 Scale Factor 1	**0**.00000 0.**0**0000 0.0**0**000 0.00**0**00 0.000**0**0 0.0000**0** Select the digit to flash for the Scale Value, then press ► one more time for the Scale Multiplier.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. This will set the Scale Value* from -9.99999 to 9.99999 with a fixed decimal point. Then press ▲ to select a value from **0.00001** to **100000** in decade steps for the Scale Multiplier. Scale Factor = Scale Value x Scale Multiplier.
OFFSt1 Offset 1	**0**00000 0**0**0000 00**0**000 000**0**00 0000**0**0 00000**0** Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Use **dEC.Pt1** to set the decimal point.
SCALE2	Scale Factor 2.	Make the same Scale Factor 1.
OFFSt2	Offset 2.	Make the same as for Offset 1.

MENU Press Menu	PEAK Press Digit Select Key	RESET Press Value Select Key
Coordinates of 2 points scaling method if selected under **SEtuP**		
Lo_In1 Low signal input 1.	000000 00000 00000 000000 00000 00000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Move decimal point location when flashing.
Lo_rd1 Reading at Lo In1.	000000 00000 00000 000000 00000 00000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Decimal point is fixed by **dEC.Pt1**.
Hi_In2 High signal input 2.	000000 00000 00000 000000 00000 00000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Move decimal point location when flashing.
Hi_rd2 Reading at Hi In2.	000000 00000 00000 000000 00000 00000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Decimal point is fixed by **dEC.Pt1**.
Special curve offset for square root or custom curve linearization if selected under **ConFiG**		
rd0_In	000000 00000 00000 000000 00000 00000 Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Decimal point is fixed by **dEC.Pt1**. Enter 04.000 for a 4-20 mA signal, 01.000 for a 1-5V signal.
Scale multiplier		
rESoLn Resolution	Flashing 6-digit number in decade steps from **0.00001** to **100000**	Press ▲ to select. This multiplier **R** appears with the Batch mode and can be applied to Grand Total to set its decimal point.
Quartz crystal time base calibration		
_CALib	Time base calibration.	Do not change. See Calibration section of manual.
Option dependent menu items		
SourcE **AL SEt** **AL S34** **dEUn1H** **dEUn2H** **dEUn1b** **dEUn2b** **dEUn3H** **DEUn4H** **DEUn3b** **DEUn4b** Menu items related to **alarm setup** These will only appear if a relay board is detected. If so, please see Section 14.		
An_SEt **An_Lo** **An_Hi** or **An_SEt** **An_Lo1** **An_Hi1** **An_Lo2** **An_Hi2** Menu items related to **analog output**. These will only appear if a single or dual analog output board is detected. If so, please see Section 15.		
_SEr_1 **_SEr_2** **_SEr_3** **_SEr_4** Menu items related to **serial communications**. These will only appear if an RS232 or RS485 I/O board is detected. If so, please see Section 16.		
Menu lockout items		
_Loc_1 **_Loc_2** **_Loc_3** **_Loc_4** Menu items used to enable or lock out (hide) other menu items. **Loc** menu items may be locked out by a hardware jumper. Please see Section 9.		

12. QUADRATURE SIGNAL CONDITIONER



Our quadrature signal conditioner board can be used with incremental encoders for position (with Basic or Extended counter main board) or for rate (Extended counter main board only). Two quadrature signals, which are 90º out of phase, are applied to the Channel A and B inputs. Their phase relationship determines whether the count is up (+) or down (-).

Position in engineering units is determined by adding or subtracting transitions, as determined by the signal phase relationship, applying a programmable scale factor to the total, and adding programmable OFFSET1 to the scaled total. The display update rate is set by a gate time, which is programmed to 10 ms. When the scaled total reaches a programmable Preset, it is reset to OFFSET1.


Rate in engineering units is determined by measuring Rate A and Rate B in transitions per second for Channels A and B, subtracting Rate B from Rate A, and applying a scale factor. Rate is measured over a gate time, which is programmable from 10 ms to 199.99 sec. Rate is set to 0 if pulses are not received during a timeout, which can be programmed from 10 ms to 199.99 sec. The meter update rate will never be less than every timeout.

A zero index signal may be applied to Channel Z as a position reference to reset the count to the expected count. For example, if 3000 counts is expected after three 1000-count revolutions, but the current count is 2998 when the zero index pulse is detected, the count is reset to 3000. Since a wide zero index pulse could cause a count discrepancy in the region between transitions, the zero index pulse can be shaped by an AND combination with the A or B channels, as set by jumpers. The above diagram shows an AND combination of the zero index channel, Channel A and Channel B. Zero index is not supported with differential and excitation by the meter. To zero the counts at a hard stop, use **Function Reset**.

The meter's excitation output can power single-ended or differential encoders at 5 Vdc, 100 mA, to produce 0-5V square waves. It can also power a differential encoder at 10 Vdc, 120 mA to produce 10V square waves. Note that externally powered 15-30V signals would be too high for the meter. The excitation output cannot be floating. Connect P5-4 (excitation return) to P5-6 (signal ground). If P5-6 is not available, connect P5-4 to P1-6 (also signal ground).

Please see further manual sections for excitation output, relay output, analog output, and serial communications.

Jumper Settings



Input Type	**E2**	**E4**	**E6**	**E5**
Single ended, with excitation, no zero index	a, c	a, c	a, c	a, c
Single ended, with excitation, with zero index	a, c	a, c	a, c	c
Single ended, with external supply, no zero index	c	c	a, c	a, c
Single ended, with external supply, with zero index	c	c	a, c	a, c
Differential, with excitation, no zero index	b	b	a	b, d
Differential, with excitation, with zero index	-	-	-	-
Differential, with external supply, no zero index	b	b	a, c	a, c
Differential, with external supply, with zero index	b	b	b	c

Input Termination (differential inputs only)	**E1**	**E3**	**E5**
For long cable runs (> 1000 ft, > 300 m)	a	a	a

Phase for Up Count	**E7**
A positive, negative B transition (A leads B)	none
A positive, positive B transition (B leads A)	a

Count-by Options	**E9**
X1 = positive edge of A input	none
X2 = positive & negative edges of A input	a
X4 = positive & negative edges of A & B inputs	b


Zero Index Polarity	**E8**
Positive	c
Negative	none

Zero Index ANDing	**E10**	**E8**
Zero Index (no ANDing)	c	-
Zero Index AND /A	a	-
Zero Index AND /B	a	a
Zero Index AND A	a	b
Zero Index AND B	a	a, b
Zero Index AND /A AND /B	b	-
Zero Index AND /A AND B	b	a
Zero Index AND A AND /B	b	b
Zero Index AND A AND B	b	a, b

PRINCIPLE OF OPERATION

The quadrature decoder board generates up (+) and down (-) counts that are arithmetically totalized on the main counter board and are then displayed. The decoder board has input circuitry that may be jumpered for single-ended input signals or balanced line driver signals. It accepts normal A & B quadrature signals and, if present, a zero index signal. The A & B signals are 90º out of phase, and their phase relationship determine whether Up counts are added to the total, or Down counts are subtracted from the total.

Since incremental optical encoders may have a different A & B phase relationship to indicate up and down counting, the board has a jumper E7 (BPOL) on the B signal to allow selection of the desired phase. With the jumper not installed, Up output pulses are created when the B signal has a positive transition while the A signal is at a positive level (A leads B). With the jumper installed, Up output pulses are created when the B signal has a negative transition while the A signal is at a positive level (B leads A). With the opposite phase shown, the effect of E7 reverses.



With E7 open, counts up.
With E7 jumpered, counts down

The board has jumpers that allow counting by 1, 2 or 4 counts per cycle of the A or B signals. The edges that are counted are:

X1 = positive transitions of the A signal.
X2 = positive and negative transitions of the A signal.
X4 = positive and negative transitions of both the A and the B signals.

Digital filtering is provided for the A & B signals to reduce the probability of noise providing false counts.

Some optical encoders create a zero index signal once per revolution that indicates when the encoding wheel is at its zero position. Each time this signal is created, the total count should be a multiple of the number of counts per revolution of the coding wheel. If this feature is enabled in the counter, the counter checks to see if total counts are an exact multiple of the counts per revolution. If so, it does nothing, and if not, it changes the total to the closest exact multiple. The counts per revolution are entered into the counter via the menu item Pulses. From 0 to 59,999 pulses may be entered. If X2 or X4 counting is enabled on the board, the value entered into Pulses should be the counts (or pulses) per revolution of the encoder multiplied by this factor of X2 or X4. If Scale is a factor other than 1, include it as a multiplying factor when determining the value of Pulses to enter. Do <u>not</u> include the value of OFFSET1.

Example:

If the encoder produces 256 cycles per revolution, X2 counting is selected by a jumper on the board and from the front panel Menu of the counter, SCALE1 is set to 3, and OFFSET1 is set to 100, then set PULSES = 256 x 2 x 3 = 1536 from the front panel menu.

The zero index channel has the same digital filtering as the A & B channels. It contains a Polarity jumper that allows selection of either a positive or negative zero index signal. It also contains two Control inputs, C1 and C2 that control the ANDing of the zero index signal with the Channel A and Channel B signals. See “Zero Index Setup” below.

The Item indicator light (center right) may be used to determine the location of the Zero Index. This indicator is lighted while the zero index signal is being received. The zero index signal must be jumpered for the correct polarity. If, during encoder motion, the indicator is on more than it is off, it is likely that the zero index signal is jumpered for the wrong polarity. If so, add a Polarity jumper to switch E8, position C. If it already has a jumper, remove it.

From the menu, a value may be entered for Offset1. As explained below under “Mechanical Zero”, OFFSET1 allows a mechanical zero position different from the zero index position. The displayed value is the sum of the following:

1. The total bidirectional counts from the optical encoder since the last counter reset or function reset.
2. The correction factor from the last zero index correction calculation.
3. OFFSET1

Example:

Suppose that the encoder contains 30 pulses per revolution and that X1 counting is used. Further suppose that when the mechanics are at their 0 position, the zero index is at 10, OFFSET 1 = 10, and the counter is reset when the encoder is at the 5 position.

		Reset					
		v					
Position	0	5	10	20	30	40	50
Index			^			^	
Internal Total →		0	5	15	25	35	45
Correction		0	-5	-5	-5	-5	-5
OFFSET		10	10	10	10	10	10
		-----	----	----	----	----	----
Display		10	10	20	30	40	50

Internal Total ←	-5	0	5	15	25	35	45
Correction	-5	-5	-5	-5	-5	-5	-5
OFFSET	10	10	10	10	10	10	10
	----	----	----	----	----	----	----
Display	0	5	10	20	30	40	50


Once the index point has been passed, the display matches the position. Prior to that, the display is in error.

When the counter is displaying Quadrature Total and the Total is reset using the Reset & Peak buttons (Function Reset), the internal Total is set to zero, but the zero index correction is not affected. This results in a display of the correction value plus OFFSET1. To zero the internal Total and the correction value, the counter must be reset using the Reset & Menu buttons (Meter Reset). This results in a display of OFFSET1.


ZERO INDEX SETUP

The relationship between the zero index correction signal and the Channel A & B signals varies by encoder model and by manufacturer. To accommodate this variation, the Quadrature board has control jumpers and selectable outputs that provide ANDing of the zero index signal with all possible combinations of the Channel A & B signals.

Consider a typical encoder model that produces the waveforms shown below. Assume that X4 counting is selected. The count increases or decreases with each A & B transition and remains steady between transitions. The counts shown below the waveforms represent the effect of the zero index correction ZI if no ANDing is used. Note the difference in count in the regions between transitions when counting up and then counting down. The zero index correction is made on the leading edge transition of the zero index signal. When counting down, the leading edge is the trailing edge of the signal shown below because time is increasing from right to left.



It follows that a wide zero index signal causes a discrepancy in the count in the regions between transitions when counting up and counting down. To correct this situation, AND the zero index signal with the A & B channel signals. Assume for this example the zero index is ANDed with the inverse of A (/A) and the inverse of B (/B) to produce ZIY as shown below.



By ANDing the zero index signal with the A & B channels, there is no regional discrepancy between counting up and counting down.

There are 2 control signals, C1 and C2, and 3 outputs, ZI, ZIX and ZIY. These may be jumpered to provide 8 selections of ANDed signals or the zero index signal without ANDing.

Zero Index Polarity	Jumper Position
	E8
Positive	c
Negative	None

Zero Index ANDing	Jumper Position	
	E10	E8
Zero Index (no ANDing)	C	-
Zero Index AND /A	a	-
Zero Index AND /B	a	a
Zero Index AND A	a	b
Zero Index AND B	a	a, b
Zero Index AND /A AND /B	b	-
Zero Index AND /A AND B	b	a
Zero Index AND A AND /B	b	b
Zero Index AND A AND B	b	a, b

The manufacture's data sheet for the optical encoder will show the position and width of the zero index signal with respect to the A channel and B channel signals. Selection of one of the above combinations depends on that relationship and the polarity of the channel A & B signals when the mechanical position is zero. Be sure to take into account the selected phase relationship determined by the presence of or absence of jumper E7-a (BPOL). Jumper E7-a is selected to cause the display to count in the proper direction. If jumper E7 is in place, the channel B signal will have the opposite polarity from the channel B output of the encoder.

MECHANICAL ZERO

By using the Counter's OFFSET1 value, it is possible to place the mechanical zero (zero counter reading) at some point other than the location of the zero index. The following technique describes how to accomplish this.

1. Set the E8 & E10 jumpers as described above to produce the desired Zero Index signal.
2. Set OFFSET1 = 0.
3. Reset the counter (counter reset).
4. Rotate the optical encoder in the positive direction until the reading jumps to zero at the zero index point (Item indicator lights).
5. Reverse the direction of rotation until the desired zero mechanical position is reached.
6. Note the reading and enter that reading into OFFSET1 using the opposite polarity of the display.
7. Reset the counter, and it will display the OFFSET1 value because the internal total counter = 0 and the correction = 0. The position of the encoder when the counter is reset is not critical.

8. Rotate the optical encoder past the zero index point to set the internal correction.
9. Return to the desired zero mechanical position and verify a zero reading.

This completes the procedure. If the encoder is rotated back to mechanical zero, it should read zero. Note: Any time the counter is powered up or reset, the optical encoder should be rotated past the zero index point one time to set the internal correction

If a zero index signal is not available from the encoder, perform the following procedure:

1. Remove any E10 jumpers to eliminate the Zero Index signal.
2. Set OFFSET1 = 0.
3. Adjust the optical encoder to the mechanical zero position and with it in this position, reset the counter.

SETUP SUMMARY

1. Set the input signal jumpers.

A. For single-ended signals such as TTL or CMOS, use jumpers **c** of E2, E4 and E6 and jumper **a** of E6. Input signals are applied as follows:

Channel A, P5-1X (AH)
Channel B, P5-3Y (BH)
Channel Z, P5-5Z (ZH) Zero Index
Ground, P5-6Z
If an excitation voltage is required, use jumper **a** of E2 and jumper **a** of E4.

B. For differential line driver or balanced input signals, use jumper **b** for E2, E4 and E6. If 120 ohm line termination resistors are desired, place jumpers E1, E3 and E5.

2. Set the correct counting direction by placing or omitting the Channel B polarity jumper E7.

3. Choose X1, X2 or X4 counting and omit **a** and **b** of E9 for X1, place **a** of E9 for X2 or place **b** of E9 for X4. Determine the scale factor to be used by the counter and set SCALE1 to this value using the counter Menu. Most often it will be set to 1.00000 with a multiplier of 1.

4. If the Zero Index is to be used, do the following:


A. Temporarily place jumper **c** of E10 and rotate the encoder while watching the Item indicator of the display. If it is OFF most of the time, the Z polarity is correct. If it is ON most of the time, the Z polarity is incorrect, so add jumper **c** of E8 if it is missing, or remove jumper **c** of E8 if it is in place.

B. From the manufacturer's specifications for the encoder showing the relationship of the Zero Index signal to the Channel A and Channel B signals, determine from the table above the desired positions of jumpers **a** and **b** of E8 and **a**, **b** or **c** of E10. If not used here, remove jumper **c** of E10 that was placed for the test in A. above.


C. From the manufacture's specifications for the encoder, determine the number of cycles per revolution. Multiply this by 1, 2, or 4 depending on the selection of X1, X2 or X4 counting and multiply that result by the counter scale factor. Put the final result in the counter Menu item, PULSES.

5. Follow the procedure outlined above under the heading MECHANICAL ZERO.


WAVESHAPE EXAMPLES BY ENCODER MANUFACTURER




Allen Bradley: current sink, open collector & line driver, CCW rotation .




Allen Bradley: current source, CCW rotation.




BEI: Models H25, L25, E25, MOD5500, MOD5600,CCW rotation




BEI: Models MX-51, MX-21,CCW rotation




BEI: Models E20, E11, E15, CMX216, MOD900, CW rotation




Bourns: EN Series



Computer Optical Products
Models CP-350, CP-360, CP-370, CP-850, CP870,CCW rotation.



Encoder Prod: Models H25, L25, E25, MOD5500, MOD5600,CCW rotation



Grayhill & Oak-Grigsby: CW rotation. No Zero Index.

QUADRATURE RATE

Rate and direction may also be displayed using an extended version of the counter. Using quadrature to determine rate not only has the advantage of displaying direction but also eliminates errors due to vibration and jitter that cause erroneous readings in standard rate meters. The meter uses A-B to display quadrature rate. Scale 1 is used to set A to the proper value and scale 2 is set to identical values. Rate (I1) is the difference between Channel A and Channel B.

PROGRAMMING EXAMPLE FOR QUADRATURE TOTAL:
DISPLAY DISTANCE TO 0.001 FT FROM A 1024 PULSE/REV QUADRATURE ENCODER

Dig. No.	S	1	2	3	4	5	6						
InPut			q	u	A	d	r		t	o	t	A	L
SEtuP			0	0	1	0	0						
ConFiG				1	0	0	0						
dSPyno						0	1						
PULSES	0	1	0	2	4.								
GAtE t			0	0	0.	0	1						
DecPt1		1	1	1.	1	1	1						
Lo In1		0	0	0	0	0	0						
Lo rd1		0	0	0.	0	0	0						
Hi In1		0	1	0	2	4.	0						
Hi rd1		0	0	1.	7	8	2						
CALib	-	Do Not Change Calib											

Application: Display distance in feet with 3 decimal points using a 1024 pulse/revolution quadrature encoder tied to a roller with 1.782 ft circumference.

Solution: Set Input to "Quadrature Total." Set Gate Time to 0.01 sec for fast display updates. Set DecPt1 to 3 places. Under Setup, select coordinates of 2 points scaling method. Set Hi In1 to 1024.0 (pulses) and the desired Hi Rd1 to 1.782 (feet).

KEYSTROKES FOR SETUP OF QUADRATURE TOTAL

If the *MENU* ↵ key does not work, see Section 9 "Enabling & Locking Out Menu Items."

MENU ***Press Menu***	PEAK ***Press Digit Select Key***		RESET ***Press Value Select Key***
InPut Input	**quAdr** Quadrature	Basic meter	**totAL** Quadrature total (select for position)
		Extended	**rAtE** Quadrature rate.
SEtuP Setup	**0**0000 Stored totals		**0** Zero all totals at power-on **1** Restore totals at power-on. Set **PULSES** to 0.
	00000 Leading zeros		**0** Blank leading zeros. **1** Display leading zeros.
	00**0**00 Scaling method		**0** Input scale factor 1 and offset 1 **1** Use coordinates of 2 points method
	00**0**0**0** Not applicable		**0** Set to 0. May be replaced by an underscore "_".
	00000 Operation of rear connector inputs 1 & 2. **True** = logic 1 (0V or tied to digital ground). **False** = 0 (5V or open).		**0** 1 = Meter Reset*, 2 = Function Reset* **1** 1 = Meter Reset*, 2 = Meter Hold* **2** 1 = Meter Reset*, 2 = Peak or Valley Display* **3** 1 = Meter Reset*, 2 = External Gate* **4** 1 = Function Reset*, 2 = Meter Hold* **5** 1 = Valley Only Display**, 2=Peak Only Display** **6** 1 = Function Reset*, 2 = External Gate* **7** 1 = Meter Hold**, Peak or Valley Display** **8** 1 = Reset Total A**, 2 = Reset Total B** **9** 1 = Force Alarm1, 2 = Force Alarm2 **A** 1 = Meter Reset*, 2 = Display Blank* **B** 1 = Function Reset*, 2 = Display Blank* **C** 1 = Meter Hold*, 2 = Display Blank* **D** 1 = Peak or Valley Display**, 2 = Display Blank** **E** 1 = Display Blank, 2 = External Gate*

		F 1 = Display Item #2, 2 = Display Item #3 With 1 and 2 at 5V or open, Display Item #1. --- * 1 & 2 both at 0V = Meter Reset (can restore totals). ** 1 & 2 both at 0V for selections **5**, **7**, **8**, **D** = Function Reset* (erases all totals).
ConFiG Configura-tion	**__0000** Display mode	**0** Normal, overload to exponential format **1** Normal, overload to 999999 Normally select **1**, required for Preset function. See dual signal conditioner for other available modes.
	__0000 Counter type	**0** Basic counter (use for quadrature total) **1** Extended counter
	__0000 Square root	**0** Set to 0.
	__0000 V-to-F batch	**0** Set to 0.
dSPyno Display	**____01** Response to PEAK pushbutton	**0** Peak **1** Valley **2** Peak (1st push), Valley (2nd push)
	____01 Item #	**1** Set to **1** (ignored for Quadrature Total).
PULSES Zero index pulses*	**_00000** **_00000** **_00000** **_00000** **_00000** Select digit to flash.	Select **0** thru **9** for flashing digit to set zero index pulses. This should pulses per revolution x edges per pulse (1, 2 or 4) x scale factor.
GAtE_t Gate time*	**_000.00** **_000.00** **_000.00** **_000.00** **_000.00** Select digit to flash.	Select **0** thru **9** for flashing digit to set the display update rate from 10 ms to 199.99 s.
dEC.Pt1 Decimal pt1	**1.11111** Decimal point flashes.	**1.11111** **11.1111** **111.111** **1111.11** **11111.1** **111111.** Press ▲ to shift decimal point.
Scale and Offset scaling method if selected under **SEtuP**		
SCALE1 Scale Factor 1	**0**.00000 **0.0**0000 **0.00**000 **0.000**00 **0.0000**0 **0.00000** Select the digit to flash for the Scale Value, then press ► one more time for the Scale Multiplier.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. This will set the Scale Value* from -9.99999 to 9.99999 with a fixed decimal point. Then press ▲ to select a value from **0.00001** to **100000** in decade steps for the Scale Multiplier. Scale Factor = Scale Value x Scale Multiplier.
OFFSt1 Offset 1	**0**00000 **0**0000 **00**000 **000**00 **0000**0 **00000** Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. **dEC.Pt1** is used for decimal point.

MENU Press Menu	PEAK Press Digit Select Key	RESET Press Value Select Key
Coordinates of 2 points scaling method if selected under **SEtuP**		
Lo_In1 Low signal input 1.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select -9 thru 9 for flashing first digit and 0 thru 9 for other flashing digits. Move decimal point location when flashing.
Lo_rd1 Reading at Lo In1.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select -9 thru 9 for flashing first digit and 0 thru 9 for other flashing digits. **dEC.Pt1** is used for decimal point.
Hi_In1 High signal input 2.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select -9 thru 9 for flashing first digit and 0 thru 9 for other flashing digits. Move decimal point location when flashing.
Hi_rd1 Reading at Hi In2.	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select -9 thru 9 for flashing first digit and 0 thru 9 for other flashing digits. Decimal point is fixed by **dEC.Pt1**.
PrESEt Preset*	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select -9 thru 9 for flashing first digit and 0 thru 9 for other flashing digits. **dEC.Pt1** is used. When the meter counts up and reaches the Preset, it reverts to Offset1. When the meter counts down and reaches Offset1, it reverts to Preset. Set to 0 for no Preset.
_CALib	Time base calibration	Not applicable to Total. Do not change value!
Option-dependent menu items		
SourcE **AL SEt** **AL S34** **dEUn1H** **dEUn2H** **dEUn1b** **dEUn2b** **dEUn3H** **DEUn4H** **DEUn3b** **DEUn4b** Menu items related to **alarm setup** These will only appear if a relay board is detected. If so, please see Section 14.		
An_SEt **An_Lo** **An_Hi** or **An_SEt** **An_Lo1** **An_Hi1** **An_Lo2** **An_Hi2** Menu items related to **analog output**. These will only appear if a single or dual analog output board is detected. If so, please see Section 15.		
_SEr_1 **_SEr_2** **_SEr_3** **_SEr_4** Menu items related to **serial communications**. These will only appear if an RS232 or RS485 I/O board is detected. If so, please see Section 16.		
Menu lockout items		
_Loc_1 **_Loc_2** **_Loc_3** **_Loc_4** Menu items used to enable or lock out (hide) other menu items. **Loc** menu items may be locked out by a hardware jumper. Please see Section 9.		

** See Glossary for explanation of item.*

PROGRAMMING EXAMPLE FOR QUADRATURE RATE:
DISPLAY RATE TO 0.001 FT/SEC FROM A 1024 PULSE/REV QUADRATURE ENCODER

Dig. No.	S	1	2	3	4	5	6						
InPut			q	u	A	d	r			r	A	t	E
SEtuP			0	0	1	1	0						
ConFiG				1	1	0	0						
dSPyno						0	1						
GAtE t			0	0	0.	2	2						
ti Out			0	0	1.	0	0						
FiLtEr			0	0	0	1	0						
DecPt1		1	1	1.	1	1	1						
DecPt2		2	2	2.	2	2	2						
Lo In1		0	0	0	0	0	0						
Lo rd1		0	0	0.	0	0	0						
Hi In1		0	1	0	2	4.	0						
Hi rd1		0	0	1.	7	8	2						
Lo In2		0	0	0	0	0	0						
Lo rd2		0	0	0.	0	0	0						
Hi In2		0	1	0	2	4.	0						
Hi rd2		0	0	1.	7	8	2						
rESoLn							1						
CALib	-	Do Not Change Calib											

Application: Display rate in feet/sec with 3 decimal points using a 1024 pulse/revolution quadrature encoder tied to a roller with 1.782 ft circumference. Have 4 display updates per second.

Solution: Set Input to “Quadrature Rate.” Set Gate Time to .22 sec so that the display update rate becomes .22 sec +30 ms +1 period. Set Time-out to 1 sec, so that pulse rates under 1 Hz are displayed as 0. Set both DecPt1 and DecPt2 to 3 places. Under Setup, select coordinates of 2 points scaling method. Set both Hi In1 and Hi In2 to 1024.0 (pulses/sec) and both the desired Hi Rd1 and Hi Rd2 to 1.782 (feet/sec). Note: the duplicate entries are required because the quadrature meter subtracts counterclockwise pulses from clockwise pulses.

KEYSTROKES FOR SETUP OF <u>QUADRATURE RATE</u>

If the *MENU* ↵ key does not work, see Section 9 "Enabling & Locking Out Menu Items."

MENU ↵ *Press Menu*	PEAK ▶ *Press Digit Select Key*		RESET ▲ *Press Value Select Key*
InPut Input	**quAdr** Quadrature	Basic meter	**totAL** Quadrature total
		Extended	**rAtE** Quadrature rate
SEtuP Setup	**00000** Not applicable		**0** Set to zero.
	00000 Leading zeros		**0** Blank leading zeros. **1** Display leading zeros.
	00000 Scaling Method 1		**0** Input scale factor 1 and offset 1 **1** Use coordinates of 2 points method
	00000 Scaling Method 2		Make the same as Scaling Method 1
	00000 Operation of rear connector inputs 1 & 2. **True** = logic 1 (0V or tied to digital ground). **False** = 0 (5V or open).		**0** 1 = Meter Reset*, 2 = Function Reset* **1** 1 = Meter Reset*, 2 = Meter Hold* **2** 1 = Meter Reset*, 2 = Peak or Valley Display* **3** 1 = Meter Reset*, 2 = External Gate* **4** 1 = Function Reset*, 2 = Meter Hold* **5** 1 = Valley Only Display**, 2=Peak Only Display** **6** 1 = Function Reset*, 2 = External Gate* **7** 1 = Meter Hold**, Peak or Valley Display** **8** 1 = Reset Total A**, 2 = Reset Total B** **9** 1 = Force Alarm1, 2 = Force Alarm2 **A** 1 = Meter Reset*, 2 = Display Blank* **B** 1 = Function Reset*, 2 = Display Blank* **C** 1 = Meter Hold*, 2 = Display Blank* **D** 1 = Peak or Valley Display**, 2 = Display Blank** **E** 1 = Display Blank, 2 = External Gate* **F** 1 = Display Item #2, 2 = Display Item #3 With 1 and 2 at 5V or open, Display Item #1. --- * 1 & 2 both at 0V = Meter Reset (can restore totals). ** 1 & 2 both at 0V for selections **5**, **7**, **8**, **D** = Function Reset* (erases all totals).
ConFiG Configuration	**00000** Display mode		**0** Normal, overload to exponential format **1** Normal, overload to 999999 Normally select **1**, required for Preset function. See dual signal conditioner for other available modes.
	00000 Counter mode		**0** Basic counter **1** Extended counter (required for Quadrature Rate)
	00000 Not applicable		**0** Set to 0.
	00000 Not applicable		**0** Set to 0.

MENU Press Menu	PEAK Press Digit Select Key	RESET Press Value Select Key
dSPyno Display #	____01 PEAK key action	0 Display Peak 1 Display Valley 2 Peak (1st push), Valley (2nd push)
	____01 Item to display after Meter Reset	1 Item #1* (Quadrature Rate = Rate A - Rate B) 2 Item #2* (Rate A) 3 Item #3* (Rate B)
GAtE_t Gate time*	_000.00 _000.00 _000.00 _000.00 _000.00 Select digit to flash.	Select 0 thru 9 for flashing digit to set gate time* in seconds. Decimal point location is fixed for 10 ms resolution.
ti_Out Time-out*	_000.00 _000.00 _000.00 _000.00 _000.00 Select digit to flash.	Select 0 thru 9 for flashing digit to set time-out* in seconds. Decimal point location is fixed for 10 ms resolution.
FiLtEr Filtering	_00000 Signal filtering	0 Adaptive moving average filter. Restarts filter for high actual changes in signal. 1 Conventional moving average filter without reset.
	_00000 Peak & Valley filtering	0 Peak* or Valley* value from unfiltered signal. 1 Peak* or Valley* value from filtered signal.
	_00000 Display filtering	0 Display value of unfiltered signal. 1 Display value of filtered signal.
	_00000 Adaptive filter setup	0 Set adaptive filter for normal noise. 1 Set adaptive filter for presence of high transients.
	_00000 Filter time constant	0 No filter 1 0.1 sec 2 0.2 sec 3 0.4 sec 4 0.8 sec 5 1.6 sec 6 3.2 sec 7 6.4 sec
dEC.Pt1 Decimal pt1	1.11111 Decimal point flashes.	1.11111 11.1111 111.111 1111.11 11111.1 111111. Press ▲ to shift decimal point of reading.
dEC.Pt2 Decimal pt2	2.22222 Decimal point flashes.	Enter the same value as for **dEC.Pt1**
Scale and Offset scaling method if selected under **SEtuP**		
SCALE1 Scale Factor 1	0.00000 0.00000 0.00000 0.00000 0.00000 0.00000 Select the digit to flash for the Scale Value, then press ▶ one more time for the Scale Multiplier.	Select -9 thru 9 for flashing first digit and 0 thru 9 for other flashing digits. This will set the Scale Value* from -9.99999 to 9.99999 with a fixed decimal point. Then press ▲ to select a value from **0.00001** to **100000** in decade steps for the Scale Multiplier. Scale Factor = Scale Value x Scale Multiplier.
OFFSt1 Offset 1	000000 000000 000000 000000 000000 000000 Select digit to flash.	Select -9 thru 9 for flashing first digit and 0 thru 9 for other flashing digits. Use **dEC.Pt1** to set the decimal point.
SCALE2	Scale Factor 2	Enter the same value as for **SCALE1**.
OFFSt2	Offset 2	Enter the same value as for **OFFSt1**.

Coordinates of 2 points scaling method if selected under **SEtuP**		
Lo_In1 Low signal input 1.	**0**00000 0**0**0000 00**0**000 000**0**00 0000**0**0 00000**0** Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Move decimal point location when flashing.
Lo_rd1 Reading at Lo In1.	**0**00000 0**0**0000 00**0**000 000**0**00 0000**0**0 00000**0** Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Decimal point is fixed by **dEC.Pt1**.
Hi_In1 High signal input 1.	**0**00000 0**0**0000 00**0**000 000**0**00 0000**0**0 00000**0** Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Move decimal point location when flashing.
Hi_rd1 Reading at Hi In1.	**0**00000 0**0**0000 00**0**000 000**0**00 0000**0**0 00000**0** Select digit to flash.	Select **-9** thru **9** for flashing first digit and **0** thru **9** for other flashing digits. Decimal point is fixed by **dEC.Pt1**.
Lo_In2	Low signal input 2.	Make the same as **Lo_In1**
Lo_rd2	Reading at Lo In2	Make the same as **Lo_rd1**
Hi_In2	High signal input 2	Make the same as **Hi_In1**
Hi_rd2	Reading at Hi In2.	Make the same as **Hi_rd1**
Other setup parameters		
rESoLn Reading multiplier	Flashing 6-digit number in decade steps from **0.00001** to **100000**	Press ▲ to select a decade multiplier **R** for the rate reading. Set to **1**.
_CALib	Time base calibration	Do not change. See Calibration section of manual.
Option dependent menu items		
SourcE **AL SEt** **AL S34** **dEUn1H** **dEUn2H** **dEUn1b** **dEUn2b** **dEUn3H** **DEUn4H** **DEUn3b** **DEUn4b** Menu items related to **alarm setup** These will only appear if a relay board is detected. If so, please see Section 15.		
An_SEt **An_Lo** **An_Hi** or **An_SEt** **An_Lo1** **An_Hi1** **An_Lo2** **An_Hi2** Menu items related to **analog output**. These will only appear if a single or dual analog output board is detected. If so, please see Section 15.		
_SEr_1 **_SEr_2** **_SEr_3** **_SEr_4** Menu items related to **serial communications** if a serial board is detected. If so, please see Section 16.		
Menu lockout items		
_Loc_1 **_Loc_2** **_Loc_3** **_Loc_4** Menu items used to enable or lock out (hide) other menu items. **Loc** menu items may be locked out by a hardware jumper. Please see Section 9.		

13. SERIAL INPUT METER / REMOTE DISPLAY OPERATION

With a Basic counter main board and a serial interface board, the counter can operate as a 6-digit serial input meter (or remote display) to display serial data received from a computer or PLC, or act as a slave display to another meter, counter or timer with a serial output. A signal conditioner board is not required, but will not interfere with remote display operation if installed.

The serial I/O interface can be provided by any of the following:

- **RS232 board:** single RJ11 connector for point-to-point communications.
- **USB Board:** Single standard USB connector for point-to-point communications.
- **USB-to-RS485 board:** USB connector for connection to PC plus RJ11 connector for 4-wire (full duplex) RS485 communications to up to 31 meters on an RS485 bus.
- **RS485 board with two RJ11 connectors in parallel** for multipoint communications with 2-wire (half duplex) or 4-wire (full duplex) connection.
- **RS485 board with two RJ45 connectors in parallel** for multipoint communications with 2-wire (half duplex) or 4-wire (full duplex) connection.
- **Ethernet board:** RJ45 connector for standard Ethernet cable to a local area network.
- **Ethernet-to-RS485 board:** RJ45 connector for standard Ethernet cable to a local area network plus RJ11 connector for 2-wire (half duplex) or 4-wire (full duplex) RS485 communications to up to 31 meters on an RS485 bus.

Slave display operation to the RS232 output of another meter requires that the jumper **h** be installed on the RS232 board of the slave meter. Also required is a **reversing phone cable**, where the wire colors of the two connectors are reversed from left to right. For more information, please see the Serial Communications Options Section 16 of this manual or the Jumper Settings sections of the *Custom ASCII Protocol Serial Communications Manual*.

With an optional dual or quad relay output board (contact or solid state relays), the serial input meter can provide remote alarm or control capability. The meter can be programmed so that the relays respond to the displayed reading or to received control characters. For setup information, please see the Dual & Quad Relay Output Options Section 14 of this manual.

With an optional single or dual analog output board, the serial input meter can provide isolated, scalable 4-20 mA, 0-20 mA, 0-10V or -10 to +10V analog outputs which track the displayed reading, thereby serving as a serial-to-analog converter. For setup information, please see the Analog Output Option Section 15 of this manual.

Front panel setup required for serial input meter (or remote display) operation is shown on the next page. Two items require special explanation:

- The first digit under **ConFig** should to be set to a value **6** thru **C**. If no signal conditioner board is detected, the meter defaults to setting **6**, where **H**, **L**, **K** commands are enabled. **H** means display the remote data only. **K** means that the received value is stored as Item #3, to become the source for alarm comparisons and analog output. **L** means both **H** and **K**. In slave mode, the remote meter can display any of up to four data Items (or string values), such as Sum of Rates A & B (Item #1), Rate A (Item #2), or Rate B (Item #3).
- A timeout **ti_Out** can be set to a value from 10 ms to 199.99 sec. This is how long a serial reading will be displayed in the absence of a new serial input. If timeout is set to 0, the display will persist indefinitely in the absence of a new input.

Additional programmable features of the serial input meter are detailed in the "Command Mode for Remote Display Operation of Counter / Timer" and "Data Formats" sections of the *Custom ASCII Protocol Serial Communications Manual*. In particular, Mode 12 (hex C), which is invoked by setting the first digit under *ConFIG* to *C*, allows extraction of data from an ASCII string that contains multiple data values or non-numeric characters. This mode can accommodate selected Start and Stop characters. Any number of characters between the Start character and the data can be masked OFF. Up to 8 display characters (including sign and decimal point) can be masked ON. Any number of characters between the last displayed character and the Stop character can be masked OFF.

Instrument Setup software is required to set up parameters for the Remote Display in Mode 12 (hex C). This software is downloadable from our website.

SELECTED FRONT PANEL SETUP ITEMS FOR SERIAL INPUT METER (not consecutive)

If the *MENU* ↵ key does not work, see Section 9 "Enabling & Locking Out Menu Items."

MENU ↵ *Press Menu*	PEAK ▶ *Press Digit Select Key*	RESET ▲ *Press Value Select Key*
SEtuP Setup	_000_0 Control inputs 1 and 2	**F** 1 = Tare enable, 2 = Tare Control input 1 must be at 0V or grounded for Tare to operate.
ConFiG Configuration	__0000 Display mode	**6** Remote display (H, K, L commands) **7** Single-value remote display **8** Show 1st string value, slaved to another meter **9** Show 2nd string value, slaved to another meter **A** Show 3rd string value, slaved to another meter **B** Show 4th string value, slaved to another meter **C** Custom Start, Stop, Skip, Show characters
ti_Out Time-out	_000.00 _00.00 _00.00 _000.00 _000.00 Select digit to flash.	Select **0** thru **9** for flashing digit to set time-out in seconds. Decimal point location is fixed for 10 ms resolution.
SEr 1	__000 Baud rate Fixed parameters: No parity, 8 data bits, 1 stop bit	**0** 300 baud **1** 600 baud **2** 1200 baud **3** 2400 baud **4** 4800 baud **5** 9600 baud **6** 19200 baud
SEr 2	__0000 Meter address	Select **0** thru **F** for addresses 1 thru 15. Select **0.** thru **F.** (with decimal point) for addresses 16 thru 31.
SEr 3	_00000 RS485	**0** Full duplex **1** Half duplex
SEr 4	___000 Serial protocol	**0** Custom ASCII **1** Modbus RTU **2** Modbus ASCII
	___000 Parity	**0** None **1** Odd **2** Even
Addr	___000 __000 ___000 Modbus address	__158 Select **0** through **9** for flashing digit. Address range is 1 to 247.

14. DUAL & QUAD RELAY OUTPUT OPTIONS



An optional relay board may be installed in the meter main board at plug position P2, adjacent to the power supply board. Four board versions are available: 2 or 4 relays, contact or solid state. Once installed, the relay board is recognized by the meter software or PC-based Instrument Set-up software, which will bring up the appropriate menu items for the type of board. These menu items will not be brought up if a relay board is not detected. Menu selections for relays 3 and 4 will not be brought up if the dual relay board is detected. All relay boards offer a choice of operating modes: normally off or on, latched or non-latched, split hysteresis, deviation band, alarm based on filtered or unfiltered signal, and selectable number of readings in alarm zone for alarm. The source compared to the setpoint may be the displayed item or a non-displayed item. Please see the Glossary at the end of this manual for an explanation of special terms.

VIEWING & CHANGING SETPOINTS

The ↵ (Alarms) key can be used to step through and view setpoints while the meter continues to make conversions and performs setpoint control. If the ▶ (Peak) key is pressed while a setpoint is displayed, conversion stops and the setpoint can be changed. After pressing ↵, you have 30 seconds, or the meter reverts to the normal display. To view setpoints, menu item Loc4, digit 4, must have been set to 0. To change setpoints, menu item Loc2, digit 6, must have been set to 0.

ALARMS ↵ *Press Alarms Key*	PEAK ▶ *Press Digit Select Key*	RESET ▲ *Press Value Select Key*
3950.00 Press ↵ (Alarms) to display Alarm 1 setpoint.	3950.00 Current setpoint 1 value blinks, and Alarm 1 LED indicator lights. Press ▶ to select a digit, which will blink.	3050.00 To change setpoint 1 value, press ▲ to change selected blinking digits.
3950.00 Press ↵ (Alarms) to display Alarm 2 setpoint.	3950.00 Current setpoint 2 value blinks, and Alarm 2 LED indicator lights. Press ▶ to select a digit, which will blink.	3050.00 To change setpoint 2 value, press ▲ to change selected blinking digits.
3950.00 Press ↵ (Alarms) to display Alarm 3 setpoint.	3950.00 Current setpoint 3 value blinks, and Alarm 3 LED indicator lights. Press ▶ to select a digit, which will blink.	3050.00 To change setpoint 3 value, press ▲ to change selected blinking digits.
3950.00 Press ↵ (Alarms) to display Alarm 4 setpoint.	3950.00 Current setpoint 4 value blinks, and Alarm 4 LED indicator lights. Press ▶ to select a digit, which will blink.	3050.00 To change setpoint 4 value, press ▲ to change selected blinking digits.
3000.24 Press ↵ (Alarms) again. Meter will reset and display the current reading.		

KEYSTROKES FOR SETUP

If the *MENU* ↵ key does not work, see Section 9 "Enabling & Locking Out Menu Items."

MENU ↵ *Press Menu*	PEAK ▶ *Press Digit Select Key*	RESET ▲ *Press Value Select Key*	
SourcE Source to compare to setpoint	0000 Setpoint 1 compared to:	**1.** Filtered item **1** Item #1	**2** Item #2 **3** Item #3
	0000 Setpoint 2 compared to:	**1.** Filtered item **1** Item #1	**2** Item #2 **3** Item #3
	0000 Setpoint 3 compared to:	**1.** Filtered item **1** Item #1	**2** Item #2 **3** Item #3
	0000 Setpoint 4 compared to:	**1.** Filtered item **1** Item #1	**2** Item #2 **3** Item #3
AL SEt Alarm Setup for relays 1 & 2 if detected. Press ↵ until *ALSEt* is displayed.	00000 Relay alarm state when alarm is active	**0** Relay 1 active on **1** Relay 1 active off **2** Relay 1 active on **3** Relay 1 active off	Relay 2 active on Relay 2 active on Relay 2 active off Relay 2 active off
	00000 Alarm latching or non-latching (auto reset) (see Glossary)	**0** AL1 non-latching **1** AL1 latching **2** AL1 non-latching **3** AL1 latching	AL2 non-latching AL2 non-latching AL2 latching AL2 latching
	00000 Alarm operates at and above setpoint (active high) or at and below setpoint (active low). (see Glossary)	**0** AL1 active high **1** AL1 active low **2** AL1 disabled **3** AL1 active high **4** AL1 active low **5** AL1 disabled **6** AL1 active high **7** AL1 active low **8** AL1 disabled	AL2 active high AL2 active high AL2 active high AL2 active low AL2 active low AL2active low AL2 disabled AL2 disabled AL2 disabled
	00000 Hysteresis mode or band deviation mode (see Glossary)	**0** AL1 band deviation **1** AL1 split hysteresis **2** AL1 band deviation **3** AL1 split hysteresis **4** No deviation or hysteresis on menu **5** AL1 span hysteresis **6** AL1 span hysteresis **7** AL1 span hysteresis	AL2 band deviation AL2 band deviation AL2 split hysteresis AL2 split hysteresis AL2 band deviation AL2 split hysteresis AL2 span hysteresis
	00000 Number of consecutive readings in alarm zone to cause an alarm	**0** After 1 reading **1** After 2 readings **2** After 4 readings **3** After 8 readings	**4** After 16 readings **5** After 32 readings **6** After 64 readings **7** After 128 readings

MENU Press Menu	PEAK Press Digit Select Key	RESET Press Value Select Key	
ALS 34 Alarm Setup for relays 3 & 4 if detected.	**0**0000 Relay alarm state when alarm is active.	**0** Relay 3 active on **1** Relay 3 active off **2** Relay 3 active on **3** Relay 3 active off	Relay 4 active on Relay 4 active on Relay 4 active off Relay 4 active off
	0**0**000 Alarm latching or non-latching (auto reset). (see Glossary)	**0** AL3 non-latching **1** AL3 latching **2** AL3 non-latching **3** AL3 latching	AL4 non-latching AL4 non-latching AL4 latching AL4 latching
	00**0**00 Alarm operates at and above setpoint (active high) or at and below setpoint (active low). (see Glossary)	**0** AL3 active high **1** AL3 active low **2** AL3 disabled **3** AL3 active high **4** AL3 active low **5** AL3 disabled **6** AL3 active high **7** AL3 active low **8** AL3 disabled	AL4 active high AL4 active high AL4 active high AL4 active low AL4 active low AL4 active low AL4 disabled AL4 disabled AL4 disabled
	000**0**0 Hysteresis mode or band deviation mode (see Glossary)	**0** AL3 band deviation **1** AL3 split hysteresis **2** AL3 band deviation **3** AL3 split hysteresis	AL4 band deviation AL4 band deviation AL4 split hysteresis AL4 split hysteresis
	0000**0** Number of consecutive readings in alarm zone to cause an alarm.	**0** After 1 reading **1** After 2 readings **2** After 4 readings **3** After 8 readings	**4** After 16 readings **5** After 32 readings **6** After 64 readings **7** After 128 readings


MENU Press Menu	PEAK Press Digit Select Key	RESET Press Value Select Key
dEUn1H Alarm 1 split hysteresis	**0**.00000 0.**0**0000 0.0**0**000 0.00**0**00 0.000**0**0 0.0000**0** Select digit to flash	Select **-9** thru **9** for flashing first digit, **0** thru **9** for other flashing digits. Alarms will activate above the setpoint by the value entered and deactivate below the setpoint by the value entered. For span hysteresis, the alarms will activate (deactivate) at the setpoint and deactivate (activate). See Glossary.
DEUn2H Alarm 2 split hysteresis		
DEUn1b Alarm 1 band deviation		
DEUn2b Alarm 2 band deviation		
dEUn1h Alarm 1 span hysteresis		
DEUn2h Alarm 2 span hysteresis		
dEUn3H Alarm 3 split hysteresis		
DEUn4H Alarm 4 split hysteresis		
DEUn3b Alarm 3 band deviation		
DEUn4b Alarm 4 band deviation		

15. SINGLE & DUAL ANALOG OUTPUT OPTIONS


Two versions of an analog board may be installed in the meter at rear panel jack position J4, adjacent to the signal conditioner board. Once installed, this board is recognized by the meter, which will bring up the appropriate menu items for it. These will not be brought up if an analog output board is not installed.

A single analog output version can be configured for unipolar 4-20 mA current, 0-20 mA current or 0-10V voltage, or bipolar -10 to +10V voltage (with a 20V voltage swing). Unipolar or bipolar operation is selected by a jumper.

A dual analog output version can be configured for two unipolar outputs, which can each be 4-20 mA, 0-20 mA or 0-10V. Current or voltage output is selected at each connector.



Unipolar current or voltage: Jumper **a**
Bipolar -10 to +10 voltage: Jumper **b**



No jumpers, only selections at the connectors.

With either board, current or voltage output is selected at the connector and in the Menu. The low analog output (0 mA, 4 mA, 0V, or -10V) may be set to correspond to any low displayed reading **An_Lo**. The high analog output (20 mA, 0V or 10V) may be set to correspond to any high displayed reading **An_Hi**. The meter will then apply a straight line fit between these two end points to provide an analog output scaled to the meter reading. The decimal point location is fixed by the **dEC.Pt1** selection.

The analog outputs are sourcing. Do not put an external voltage source in series with the analog outputs, or you will burn out the analog output board.

KEYSTROKES FOR SETUP OF SINGLE ANALOG OUTPUT BOARD

If the *MENU* ↵ key does not work, see Section 9 "Enabling & Locking Out Menu Items."

MENU ↵ *Press Menu Key*	PEAK ▶ *Press Digit Select Key*	RESET ▲ *Press Value Select Key*
An_SEt Analog Output Setup. Press ↵ until *AnSEt* is displayed.	**00** Calibration output selection.	**0** 0-20 mA current output **1** 0-10V voltage output **2** 4-20 mA current output **3** -10V to+10V voltage output
	00 Analog output source.	**0** Filtered item **2** Item 2 **1** Item 1 **3** Item 3

An_Lo Low displayed value for -10V, 0V, 0 mA, or 4 mA	0.00000 0.00000 0.00000 0.00000 0.00000 0.00000 Select digit to flash	Select 0 thru 9 for flashing digit.
An_Hi High displayed value for 10V or 20 mA output	0.00000 0.00000 0.00000 0.00000 0.00000 0.00000 Select digit to flash	Select 0 thru 9 for flashing digit.

KEYSTROKES FOR SETUP OF DUAL ANALOG OUTPUT BOARD
If the *MENU* ↵ key does not work, see Section 9 "Enabling & Locking Out Menu Items."

MENU ↵ *Press Menu Key*	PEAK ▶ *Press Digit Select Key*	RESET ▲ *Press Value Select Key*
An_SEt Analog Output Setup. Press ↵ until *AnSEt* is displayed.	0000 Scaling of analog output 2	0 0-20 mA current output 1 0-10V voltage output 2 4-20 mA current output
	0000 Source of analog output 2	0 Filtered item 2 Item 2 1 Item 1 3 Item 3
	0000 Scaling of analog output 1	0 0-20 mA current output 1 0-10V voltage output 2 4-20 mA current output
	0000 Source of analog output 1	0 Filtered item 2 Item 2 1 Item 1 3 Item 3
An_Lo1 Low displayed value for 0V, 0 mA, or 4 mA output	0.00000 0.00000 0.00000 0.00000 0.00000 0.00000 Select digit to flash	Select 0 thru 9 for flashing digit.
An_Hi1 High displayed value for 10V or 20 mA output	0.00000 0.00000 0.00000 0.00000 0.00000 0.00000 Select digit to flash	Select 0 thru 9 for flashing digit. **dEC.Pt1** selection.
An_Lo2 Low displayed value for 0V, 0 mA, or 4 mA output	0.00000 0.00000 0.00000 0.00000 0.00000 0.00000 Select digit to flash	Select 0 thru 9 for flashing digit.
An_Hi2 High displayed value for 10V or 20 mA output	0.00000 0.00000 0.00000 0.00000 0.00000 0.00000 Select digit to flash	Select 0 thru 9 for flashing digit.

16. SERIAL COMMUNICATIONS OPTIONS

A serial communications board may be connected to the meter main board at plug position P13 (middle position). Available boards are RS232, RS485 (with dual RJ11 connectors), RS485 Modbus (with dual RJ45 connectors), USB, USB-to-RS485 converter, Ethernet, and Ethernet-to-RS485 converter. The dual connectors of RS485 boards are wired in parallel to allow daisy chaining of addressable meters without use of a hub. Three serial communication protocols are selectable for all serial boards: Custom ASCII, Modbus RTU, and Modbus ASCII.

A USB-to-RS485 converter board or an **Ethernet-to-RS485 converter board** allows a meter to be interfaced to a computer and be the device server for a network of up to 31 other meters on an RS485 bus, while itself retaining all capabilities of a meter. The remote meters need to be equipped with our RS485 digital interface board with dual 6-pin RJ11 jacks, not our RS485 digital interface with dual 8-pin RJ45 jacks. The dual 6-pin RJ11 jacks on the RS485 board are wired in parallel to allow multiple meters to be daisy-chained using 6-wire data cables with no need for hand-wiring or an RS485 hub. The outer two wires are used for ground.

Use 6-wire, straight-through data cables, not 4-wire telephone cables or crossover cables, all the way from the device server to the last device on the RS485 bus. Connect ATX to ATX, BTX to BTX, etc., with no crossover as you go from device to device.

To connect a meter with a USB board to a Windows PC, use a USB cable with Type A and Type B connectors. Upon first connection, your computer may display “Found new Hardware” and automatically download and install the required USB driver from the Internet. If installation is not automatic, download the driver file (with a name like CDM v2.10.00 WHQL Certified.zip) from http://www.ftdichip.com/Drivers/VCP.htm. Unzip it into its own directory, and point to that directory as the location of the driver. You will need to use Device Manager (accessible from Control Panel) to determine the com port. Go down the device list and click on Ports (COM & LPT) and USB serial port (com #). Note the com port # for use with communications to your meter, then exit Control Panel. If you later need to change the Com port, right-click on USB serial port (com #), then on Properties, Port settings, and Advanced. Change port to the desired number, click OK, then exit Control Panel.

To connect a meter with an Ethernet board to a computer, see our separate Ethernet Manual, which covers our Node Manager Software. This Windows-based application runs on a host computer and is used to configure our Ethernet Nodes. It automatically discovers all Nodes on a LAN or WAN, plus any devices connected to Server Nodes via an RS485 bus. It is used to configure each Node, such as setting communication parameters, naming the Node and associated devices, entering email addresses for alarm notification and data requests, selecting the Node's time zone for time-stamping of emails and streaming data, and upgrading firmware. Once configuration data has been stored in flash memory of all Nodes, Node Manager Software can be closed. Node resident web server software is also provided.

BOARD SETUP VIA JUMPERS

USB Board

No jumpers required.



Basic Ethernet Board

No jumpers needed.



RS232 Board

e - Externally enabled RTS (otherwise always enabled)
f - Remote display (or slave) operation.
g - Normal operation (other than remote display).

Note: Board is shipped with jumper **g** installed.




RS485 Board, Dual RJ11 Connectors, Full Duplex

b & d - Installed on last meter in long cable run.

RS485 Board, Dual RJ11 Connectors, Half Duplex

a & c - Installed for half duplex operation.
d - Installed on last meter in line with long cable runs.

Note: Board is shipped with no jumpers installed.




RS485 Board, Dual RJ45 Connectors, Full Duplex

b & e - Bias jumpers should be installed on 1 board.
a & d - Installed on last meter in long cable run.

RS485 Board, Dual RJ45 Connectors, Half Duplex

b & e - bias jumpers installed on 1 board.
c & f - installed for half duplex operation.
a - installed on last meter in line with long cable runs.

Note: Board is shipped with no jumpers installed.




Ethernet-to-RS485 Converter Board
& USB-to-RS485 Converter Board


Full Duplex RS485

No jumpers for short cable runs.
Add **b & d** for long cable runs.


Half Duplex RS485


a + c for short cable runs.
Add **d** for long cable runs.







SERIAL CONNECTION EXAMPLES









KEYSTROKES FOR SETUP

If the *MENU* ↵ key does not work, see Section 9 "Enabling & Locking Out Menu Items."


MENU ***Press Menu Key***	PEAK ***Press Digit Select Key***	RESET ***Press Value Select Key***
Ser 1 Serial Setup 1. Press ↵ until *Ser 1* is displayed. Fixed Parameters No parity 8 data bits 1 stop bit	**0**00 Output filtering	**0** Send unfiltered signal **1** Send filtered signal
	000 Baud rate	**0** 300 baud **1** 600 baud **2** 1200 baud **3** 2400 baud **4** 4800 baud **5** 9600 baud **6** 19200 baud
	000 Digital output rate. rr = read rate. rr depends on gate time and input frequency.	**0** Output at read rate rr **1** Output at rr/2 **2** Output at rr/4 **3** Output at rr/8 **4** Output at rr/16 **5** Output at rr/32 **6** Output at rr/64 **7** Output at rr/128 **8** Output at rr/256
Ser 2 Serial Setup 2	**0**000 Line feed	**0** No LF after carriage return **1** LF after carriage return
	0000 Alarm data with readings	**0** No alarm data **1** Alarm data with reading
	0000 Output mode control	**0** Continuous data output **1** Data output on ASCII command only
	0000 Meter address with Custom ASCII protocol*	Select **0** thru **F** for addresses 1 thru 15. Select **0.** thru **F.** (with decimal point) for addresses 16 thru 31.

MENU *Press Menu Key*	PEAK *Press Digit Select Key*	RESET *Press Value Select Key*
Ser 3 Serial Setup 3	_00000 Half or full duplex	0 Full duplex 1 Half duplex
	_00000 Recognition characters, start & stop characters. Special characters have to be download via Instrument Setup software.	0 * (asterisk) is recognition character. No start & stop characters. 1 Custom recognition character. No start & stop characters. 2 * (asterisk) is recognition character. Special start & stop characters. 3 Custom recognition characters. Special start & stop characters.
	_00000 RTS mode	0 Normal RTS 1 Single transmission
	_00000 CR (LF) termination characters.	0 Only at end of all items 1 At end of each item
	_00000 Data sent in continuous mode	0 All Active Items 1 Item #1 only 2 Item #2 only (if active) 3 Item #3 only (if active) 4 Peak only 5 Displayed Item 6 Valley only 7 All Active Items + Peak + Valley
Ser 4 Serial Setup 4	___000 Modbus* ASCII gap timeout	0 1 sec 1 3 sec 2 5 sec 3 10 sec
	___000 Serial protocol	0 Custom ASCII* 1 Modbus* RTU 2 Modbus* ASCII
	___000 Parity	0 None 1 Odd 2 Even
Addr Modbus Address	___000 ___000 ___000 Select digit to flash.	___158 Select 0 thru 9 for flashing digit. Address range is 1 to 247.

** See Glossary for explanation of item.*

17. EXCITATION OUTPUT & POWER SUPPLY

Three isolated transducer excitation output levels are available from the power supply board. These are selectable via jumpers b, c, d, e, f in the upper right of the board, as illustrated. In addition, the board provides three jumper positions for special features. The same jumper locations apply to the universal power supply (85-264 Vac or 90-300 Vdc) and to the low voltage power supply (12-32 Vac or 10-48 Vdc).



1. Letters indicate jumper position. Jumpers are installed on pins adjacent to letters.

Excitation output	Jumper locations	
5 Vdc ±5%, 100 mA max	**b, d, e**	
10 Vdc ±5%, 120 mA max	**b, d, f**	
24 Vdc ±5%, 50 mA max	**c**	

2. SELECTION OF OTHER JUMPERS

Jumper a - Front panel menu lockout, locked when installed. See Section 9.
Jumper g – Sets P1-4 to be a +5V, 50 mA power output when installed.
Jumper h – Sets P1-4 to be Control Input 2 when installed (factory default).

18. INSTRUMENT SETUP VIA PC

Instrument Setup software is a PC program which is much easier to learn than front panel programming. It is of benefit whether or not the meter is connected to a PC. With the meter connected to a PC, it allows uploading, editing and downloading of setup data, execution of commands under computer control, listing, plotting and graphing of data, and computer prompted calibration. With the meter unconnected to a PC, it provides quick selection of jumper locations and a printable display of menu selections for front panel setup.

SOFTWARE INSTALLATION

Under Windows 7 or 8, first set User Account Control (UAC) to "Never Notify" so that the software can write files. Download *IS2*.exe* onto your PC from our website. Double-click on the downloaded file to unzip it into a directory, such as *c:\temp*. Within that directory, double-click on *setup.exe*, which will install the software on your PC.

PREREQUISITES FOR CONNECTED USE


1) PC with an available RS232 or USB port.
2) Meter to be set up.
3) RS232 or USB board in the meter. This board can be removed following meter setup.
4) RJ11-to-DB9 cable from the meter to a PC RS232 com port, or a USB cable to a PC USB port (see Section 1, Ordering Guide).
5) *Instrument Setup* software.





RJ11-to-DB9 RS232 cable with rear view of DB9 connector to PC


ESTABLISHING COMMUNICATIONS

Connect the meter and PC. Apply power to the meter. Be sure that the meter is in Run Mode, not Setup Mode. To start the software from Windows, click on *Start* => *Programs* => *IS2* => *IS2*. Click on *RS232* => *Establish*. The program will temporarily set the selected Com port to the required baud rate, parity, data bits and stop bit. Once communications have been established, click on *Main Menu*. The software will sense the type of meter and installed boards, but it cannot sense jumpers positions nor set jumpers for you. If the computer is not connected to a meter, select *Counter/Timer* and *Series 2*.










SETUP OF CONNECTED METER

A setup file can be retrieved from the meter (*Counter => Get Setup*), be edited (*View => Setup*), be saved to disk (*File => Save Setup*), be retrieved from disk (*File => Open Setup*), and be downloaded into one or multiple meters (*Counter => Put Setup*). Downloading of setup files from a PC can be a major time saving when multiple counters have to be set up in the same way.


You will find that *Instrument Setup software* is very user friendly, with separate tab-selectable windows for *Input+Display*, *Scaling*, *Filter*, *Relay Alarms*, *Communications*, *Analog Out*, and *Lockouts*. If the required hardware, such as the analog output board, is not sensed, the corresponding tab will be grayed out.

ADDITIONAL FEATURES WHEN CONNECTED

- **The Commands pull-down menu** allows you to perform Reset functions, to enter numerical values into the meter, and to retrieve numerical values from the meter (Items 1, 2, 3, Peak, Valley).



Plot



Graph

- **The Readings pull-down menu** provides three formats to display meter data on the PC monitor. Use the *Pause* and *Continue* buttons to control the timing of data collection, then press *Print* for a hardcopy record on your PC printer.
  - **List** presents the latest readings in a 20-row by 10-column table. Press *Pause* at any time to freeze the display. This is one method to capture peak readings.
  - **Plot** generates a plot of readings vs. time in seconds. It effectively turns the DPM-PC combination into a printing digital oscilloscope.
  - **Graph** generates a histogram, where the horizontal axis is the reading and the vertical axis is the number of occurrences of readings. The display continually resizes itself as the number of readings increases.
- **The Jumpers pull-down menu** shows board jumper corresponding to specific user selections.
- **The Calibration pull-down menu** allows easy frequency calibration of the quartz crystal. Simply apply a known calibration frequency up to 1 MHz to Channel A of the dual channel signal conditioner board, type in the frequency value in Hz, and press *Enter*.

METER SETUP WITH AN UNCONNECTED PC

Instrument Setup software is also of benefit when the PC is not connected to a meter.

Upon launching the software, click on *None* for *Communications*, then on *Counter/Timer* and *Series 2*. Click on *File => Default Setup* to retrieve a default setup file from disk, or on *File => Open Setup* to retrieve a previously saved setup file from disk.

To enter new setup information, click on *View => Setup*, then make your screen selections as if you were connected to a meter. Tabs will be grayed out if you have not selected the required hardware under the *Input+Display* tab. When done, press on *Main Menu*, then on *View => Menu*. The selections made under *Setup* will now be shown in the form of the required front panel programming sequence, where each row corresponds to a menu item selected by the ↵ key, and the seven data columns correspond to values entered via the ▶ and ▲ keys.

Click on any step in the sequence to bring up a detailed help window.


Click on *Print* for a hardcopy, which you can then use as an instruction sheet to program your meter via its front panel.

Click on *Main Menu => File => Save Setup As* to save your setup to disk and have an electronic record.

Dig. No.	S	1	2	3	4	5	6
InPut				r	A	t	E
SEtuP			0	0	0	0	0
ConFiG				0	1	0	0
dSPyno						0	1
GAtE t			0	0	0.	1	0
ti Out			0	0	3.	0	0
FiLtEr			0	0	0	1	1
SLOPE						0	1
DecPt1		1	1	1	1	1	1.
DecPt2		2	2	2	2	2	2.
SCALE1	+	1.	0	0	0	0	0
OFFSt1	+	0	0	0	0	0	0
SCALE2	+	1.	0	0	0	0	0
OFFSt2	+	0	0	0	0	0	0
SourcE				1	1		
AL SEt			0	0	0	0	0
dEUn1b	+	0	0	0	0	0	0
dEUn2b	+	0	0	0	0	0	0
SEr 1					0	5	0
SEr 2				0	0	1	1
SEr 3			0	0	0	0	1
SEr 4					0	1	0
Addr					0	0	1
CALib	-		0	0	1	0	0
Loc 1				0	0	0	0
Loc 2				0	0	0	0
Loc 3				0	0	0	0
Loc 4				0	0	0	0


19. CUSTOM CURVE LINEARIZATION

Curve.exe is a DOS-based, executable PC program used to set up an Extended meter so that the readings have a user-defined, non-linear relationship with the input signal. For example, it allows a meter to correct for non-linearity of transducers, or to display volume from pressure at the bottom of an irregularly shaped tank. The linearizing parameters are downloaded into non-volatile memory of the meter. The curve fitting algorithm is uses quadratic segments of varying length and curvature, and provides diagnostics to estimate curve fitting errors. The program is self-prompting, avoiding the need for a manual.



PREREQUISITES

1) PC-compatible computer with an available RS232 or USB port.
2) Extended meter*.
3) A serial communication board in the meter. This board can be removed following meter setup.
4) A suitable cable to connect the meter to a PC.
5) *Curve.exe* software (downloadable at no charge).



RJ11-to-DB9 RS-232 cable

GETTING STARTED

Download *curve.exe* into the same directory that will contain your data files, such as *c:\curves*. Set the meter to custom curve linearization. To do so, press the ↵ key to get to **ConFG**, then set the fifth digit to **1**. This digit will only be displayed with an Extended meter*. Set the meter baud rate to 9600. To do so, press the ↵ key to get to **SEr 1**, then set the entry to **_050**. Set the meter address to 1. To do so, press the ↵ key to get to **SEr 2**, then set the entry to **_0011**. To execute the program from Windows, simply double-click on *curve.exe*. No software installation is required.

OPERATING MODES

The program will prompt you to enter your data in one of four modes. Pressing **R** (Enter) at any time returns you to the main menu.

1) **Text file entry mode,** with an X value in one column and a Y value in another. There can be additional columns, which are ignored. The file must have a DOS name of up to 8 characters and the extension .RAW. There can be from 5 to 180 rows. X is the input value and should be in the unit of measure for which the meter was set up, such as mV, V, mA or A. Y is the desired corresponding reading and can range from -99999 to 99999 with any decimal point.
2) **2-coordinate keyboard entry mode,** where an actual X input signal is applied, and the desired Y reading is entered from the keyboard.
3) **2-coordinate file entry mode,** where an actual X input signal is applied, and the desired Y reading is provided from a file.

4) **Equation entry mode,** where the coefficients of a polynomial Y = K1X^P1 + K2X^P2 + K3*X^P3 + … are entered. Up to 20 terms are allowed. And offset can be built into X.

REQUIRED USER INPUTS

- Select CTR
- You will be asked to supply the following:

  LOW X-COORDINATE VALUE >
  LOW INPUT MEASUREMENT VALUE >
  HIGH X-COORDINATE VALUE >
  HIGH INPUT MEASUREMENT VALUE >

  This informs the computer of your signal conditioner jumper settings. Enter 0 and 0 for the two LOW values. For HIGH X, enter your signal conditioner jumper range in the same units of measure that you will be using in your *.RAW data input file. Enter **20** for 20 mA or **10** for 10V. For HIGH INPUT MEASUREMENT VALUE, enter **100000**,

  You will be asked to select the position of the decimal point from 6=X.XXXXX, 5= XX.XXX, 4=XXX.XXX, 3=XXXX.XX, 2=XXXXX.X, 1=XXXXXX (for DPMs, the leading X is a blank). Specify the same position that you specified in the **dEc.Pt1** decimal point menu selection.

20. METER CALIBRATION

All ranges of the meter have been digitally calibrated at the factory prior to shipment using computers and calibration equipment certified to NIST standards. If recalibration is required, the meter may be returned to the factory or to any authorized distributor.

For frequency and rate measurements with the dual-channel signal conditioner, a calibration correction to the quartz crystal oscillator is stored in EEPROM on the main board. Calibration constants are also stored in EEPROM in the process receiver & totalizer signal conditioner board and in the analog output board. As a result, these two boards can be mixed and inter-changed without requiring recalibration.

For frequency calibration using the dual-channel signal conditioner board, calibration may be performed in the field as follows using the front panel pushbuttons:

1. Set jumpers for “Logic levels” (top of page 14) to remove filtering.
2. Set *InPut* to *rAtE* and *A only*.
3. Enter 0 in *CALib* to set initial correction to 0 PPM.
4. Set *SCALE* to -9.99999
5. Set *OFFSt1* to 999999
6. Apply a 100 kHz reference signal to channel A.
7. Enter the displayed reading in *CALib*.

For calibration of the process receiver & totalizer signal conditioner board or analog output board, an RS-232 board must be installed in the meter for serial communication with a PC. This board may be removed upon completion of calibration. Calibration software and step-by-step instructions are available from the factory.

21. SPECIFICATIONS

DISPLAY

Type ..... 6 LED digits, 7-segment, 14.2mm, plus 4 LED indicators
Digit Color ..... Red or green
Display Range ..... -999999 to +999999

CONVERSION (FREQUENCY INPUT)

Conversion Technique 1/period
Conversion Rate ..... Gate Time + 30 ms + 2 signal periods (max)
Gate Time ..... 0 to 199.99 sec (selectable)
Time Before Zero Output (Time-Out) ..... 0 to 199.99 sec (selectable)
Output & Display Update Rate ..... Same as conversion rate
Time Base Accuracy ..... Calibrated to ±2 ppm

INPUT ISOLATION

CMV from DC to 60 Hz ..... Withstand 250Vac
Dielectric strength ..... 2.3 kV ac for 1 min

DUAL CHANNEL SIGNAL CONDITIONER

Accuracy at 25ºC ..... ±2 ppm
Tempco ..... ±1 ppm/degree C
Long-Term Drift of Crystal ..... ±5 ppm/year
Signal Types ..... AC, NPN, PNP transistor outputs, contact closures, magnetic pickups
Max Pulse Rate ..... 1 MHz on Channel A, 250 kHz on Channel B
Channel Isolation ..... Channel A & channel B share common ground
Low Pass Filter ..... 250 Hz or 30kHz (selectable)
Hysteresis ..... 15 mV to 2.2 Vp-p (selectable)
Trigger Level ..... ±15 mV to ±1.7 V (selectable)
Debounce Circuitry ..... 0, 3, 50 ms (selectable)
Maximum Signal Voltage ..... 250 Vac
Input Resistance ..... 100 kΩ

PROCESS RECEIVER & TOTALIZER SIGNAL CONDITIONER

Input Signal Levels ..... 4-20 mA, 0-1 mA, 0-10 V (jumper selectable)
Input Resistance ..... 50Ω for 4-20 mA, 1.00 k Ω for 0-1 mA, 1.01 MΩ for 0-10V
Accuracy at 25ºC ..... ±0.01%
Span Tempco ..... ±0.003% of reading /°C
Zero Tempco ..... ±0.003% of full scale /°C

QUADRATURE SIGNAL CONDITIONER

Signal Type ..... Differential or single-ended quadrature
Transitions Monitored ..... x1, x2 or x4
Max Pulse Rate ..... 250 kHz at x1, 125 kHz at x2, 62.5 kHz at x4
Differential High Threshold Voltage ..... +200 mV
Differential Low Threshold Voltage ..... -200 mV
Differential Limits ..... -11V to +14V

Common Mode Voltage for ±200 mV sensitivity ..... ±7V
Single-ended High Voltage ..... 2.5V to 5.5V
Single-ended Low Voltage ..... -1V to +1V
Input resistance, Typ. ..... 17 kOhm
Conversion Technique for Rate 1/period
Conversion Time for Rate ..... Gate time + 30 ms + 0-2 signal periods
Time Before Zero Output for Rate ..... 0 to 199.99 sec (selectable)
Zero Wait Time for Rate ..... 0 to 199.99 sec (selectable)
Output & Display Update Rate ..... Same as conversion rate
Time Base Accuracy for Rate ..... Calibrated to ±2 ppm

POWER REQUIREMENTS

Input Voltage (standard power) ..... 85-264 Vac or 90-300 Vdc
Input Voltage (low voltage power option) ..... 12-32 Vac or 10-48 Vdc
Power Line Frequency ..... DC and 47-63 Hz
Power consumption (typical, base meter) . ..... 1.2W @ 120 Vac, 1.5W @ 240 Vac, 1.3W @ 10 Vdc, 1.4W @ 20 Vdc, 1.55W @ 30 Vdc, 1.8W @ 40 Vdc, 2.15W @ 48 Vdc

EXCITATION OUTPUTS

Voltage & Current Levels (jumper selectable) ..... 5V dc ±5%, 100 mA max
10V dc ±5%, 120 mA max; 24V dc ± 5%, 50 mA max
Excitation Output Ripple ..... 100 mVp max
Isolation from Power and Outputs ..... 250 Vac
Insulation Dielectric Strength to Power & Outputs ..... 2.3 kV ac for 1 min
Isolation to Signal Common ..... 50V dc

DUAL OR QUAD RELAY OPTIONS

Power to Relay Option ..... Powered by meter
Setpoint Setup ..... Via front panel pushbuttons or RS232/485
Update Rate ..... 56/s at 60 Hz, 47/s at 50 Hz
Response to Input Signal (min) ..... Display update rate
Input Signal (selectable) ..... Filtered or unfiltered input signal
Actuation Modes (selectable) ..... Above or below setpoint, latching or non-latching, disabled
Output Time Delay (selectable) ..... 1 to 128 readings
Front Panel Enable / Lockout Modes (selectable) ..... 1) Display and change setpoints
2) Display but do not change setpoints
3) Neither display nor change setpoints
Alarm Status Indication ..... 2 or 4 red LED lamps
Status Indication Setup (selectable) ..... Lit when output is ON or OFF

Form C, SPDT Relay Output:

AC Rating ..... 8A @ 240 Vac
DC Rating ..... 8A @ 24 Vdc
Isolation rating between signal common and contacts ..... 250 Vac
Insulation dielectric strength between signal common and contacts ..... 2.3 kV ac for 1 min

Form A, SPST Solid State Relay Output:

AC Rating ..... 120 mA @ 140 Vac
DC Rating ..... 120 mA @ 180 Vdc
Isolation rating between signal common and contacts ..... 250V ac
Insulation dielectric strength between signal common and contacts ..... 2.3 kV ac for 1 min

ANALOG OUTPUT OPTION

Power to Analog Output Option ..... Powered by meter
Output Levels, Single Analog Output Option ..... 0-20 mA, 4-20 mA, 0-10V, -10 to +10V
Output Levels, Dual Analog Output Option ..... 0-20 mA, 4-20 mA, 0-10V
Voltage Compliance, 0-20 mA Output ..... 12V (0-600 Ohm load)
Current Compliance, 0-10V Output ..... 2 mA (5 kOhm or higher load)
Accuracy ..... Meter input accuracy ±0.02% of full scale analog output
Resolution ..... 16 bit (1 part in 65,536)
Response Time, Max ..... 30/sec. Limited by gate time or period for rate.
Scaling of Reading for Zero Output ..... -999,999 to +999,999
Scaling of Reading for Full Scale Output ..... -999,999 to +999,999
Isolation rating between signal common and analog output ..... 250V ac
Insulation dielectric strength between signal common & analog output ..... 2.3 kV ac for 1 min

SERIAL INTERFACE OPTIONS (Ethernet, USB, RS232, RS485, RS485-Modbus boards)

Output Types ..... RS232, RS485, RS485-Modbus, USB, USB-to-RS485 converter
..... Ethernet, Ethernet-to-RS485 converter
Power to Interface Option ..... Powered by meter
RS485 Wiring ..... Half or full duplex
Baud Rates 300, 600, 1200, 2400, 4800, 9600, 19200
Serial Protocols ..... Custom ASCII, Modbus RTU, Modbus ASCII (selectable)
Signal Levels ..... Meet RS232, RS485, USB, Ethernet standards
Response Time, Max ..... 30/sec. Limited by gate time or period for rate.
Isolation rating between signal common and serial I/O ..... 250V ac
Insulation dielectric strength between signal common and serial I/O ..... 2.3 kV ac for 1 min
Option Board Connectors:
- RS232 ..... Single RJ11 jack
- RS485 ..... Two RJ11 jacks (for daisy chaining with 6-wire data cables)
- RS485 Modbus ..... Two RJ45 jacks (for daisy chaining with 8-wire data cables)
- USB ..... USB type B plug
- USB-to-RS485 converter ..... USB type B plug plus RJ11 jack to RS485 bus
- Ethernet ..... Single RJ45 jack to Ethernet
- Ethernet-to-RS485 converter ..... RJ45 jack to Ethernet plus RJ11 jack to RS485 bus

ENVIRONMENTAL

Operating Temperature ..... 0°C to 55°C
Storage Temperature ..... -40°C to 85°C
Relative Humidity ..... 95% from 0°C to 40°C, non-condensing
Case ..... NEMA-4X (IP65) from front when panel mounted (not verified for UL)
Shock ..... 10 G at 1 kHz, applied in X, Y, Z axes
Vibration ..... 15 Hz to 150 Hz, 1 mm to 2 mm amplitude, 20 G max.


22. GLOSSARY OF TERMS

Adaptive filter threshold

A threshold which causes an adaptive moving average filter to be reset to the latest reading when the accumulated difference between individual readings and the filtered reading exceeds that threshold. Adaptive moving average filtering allows a meter to respond rapidly to actual changes in signal while filtering out normal noise. The accumulated difference is also reset to zero when the latest reading has a different polarity than the filtered reading. A low adaptive filter threshold is normally selected. A high filter threshold should be selected if the signal has large transients.


Alarm, latched

An alarm which stays actuated until reset. Latched alarms can shut down machinery or a process when an operating limit has been exceeded, or maintain an alarm condition until acknowledged by an operator.



Alarm, non-latched

An alarm which changes state automatically when the reading rises above a specified limit and changes back automatically when the reading falls below a limit.



Autofilter A selectable digital filter mode which automatically selects an appropriate moving average filter time constant from 0.08 sec to 9.6 sec for the encountered noise condition.

Batch control An operating mode of the Extended counter with a relay board, where the counter is used to control repetitive fill operations by counting up from zero to a preset, or counting down from a preset to zero.

Calculated total

While most totals are based on direct pulse counts, certain totals are calculated as running totals based on displayed rate (e.g., Total A, Rate A). The totalizing process assumes that rate is displayed in units per second, such as 300 gallons per second, allowing a scale factor of 1 to be used. If the rate is not in units per second, a different scale factor has to be applied.

Coordinates of 2 points method

A scaling method where the coordinates of 2 points are entered. For a pulse rate input, the first entered point is would be low frequency in Hz and low desired reading. The second entered point would be high frequency in Hz and high desired reading.

Counts The reading displayed on the meter ignoring the decimal point.


Custom ASCII protocol

A simplified, short protocol for use with panel meters, counters and timers. It allows 31 digital addresses. Not an industry-standard protocol, like the more complex *Modbus protocol*, which is also offered with these instruments.

Custom curve A user-specified nonlinear relationship between the input signal and displayed reading. Custom curve linearization is available with the *Extended counter*. One way to supply the data is via a text file with up to 180 data points, which is processed on a PC using furnished software and is then downloaded into EEPROM via serial communications.

Cutoff A programmable threshold in units of flow applicable to Total and Batch Control with the process receiver and totalizer signal conditioner. Flow rates below the cutoff, deemed to be zero offset errors, will not be totalized. Otherwise, small zero offset errors could result in a large error if accumulated over a long time.

Deviation band



A band in counts which controls relay action symmetrically around a *setpoint*. The relay actuates when the reading falls within the deviation band, and de-actuates when the reading falls outside of this band. A deviation limit (e.g., 50 counts) is set up around both sides of the setpoint to create a deviation band (e.g., 100 counts). Setting up a pass-band around a setpoint is often used for component testing. Deviation limits are programmed by entering menu item *dEUn1b* for Alarm 1 and *dEUn2b* for Alarm 2.

Duty cycle ON or OFF period of square waves as a percentage of total period over a *gate time* which is selectable from 10 ms to 199.99 sec. With the dual input signal conditioner, the same signal is applied to Channels A and B. Duty cycle can then be read out with resolution to 0.01%.

Extended counter

A counter with enhanced microcomputer firmware in the main board for advanced programmable functions.

Frequency Rate in cycles per second or Hertz (Hz). In rate meter mode, a scale factor of 1 and offset of 0 cause a display directly in Hertz with resolution of 1 Hz. To increase or decrease resolution, increase or decrease the scale factor.

Function reset


The action of resetting Peak, Valley, latched alarms, and count totals. Normally achieved by an external pushbutton switch, which connects a control input at the rear of the meter to digital ground. The functions of control inputs 1 and 2 are programmed under Setup.

Gate Time A user-specified time interval from 10 ms to 199.99 sec over which the meter measures frequency. The meter times an integral number of signal periods over the gate time, and then taking the inverse of period. The display update rate of the meter is gate time + 1 period + 30 ms. Selecting a longer gate time produces a more stable reading as more cycles are averaged, but slows down

the update rate. At very low frequencies, the update rate of the meter is controlled by the period. In totalizing mode, the gate is always open, but the gate time setting still determines the update rate of the meter. See also *Time-out* or *Time before zero output*.


Hysteresis, Split

Relay operation is specified symmetrically around a setpoint. The relay closes (or opens) when the reading rises above the setpoint plus one hysteresis limit, and opens (or closes) when the reading falls below the setpoint less one hysteresis limit. A narrow hysteresis band can be used to minimize relay chatter. A wide hysteresis band can be used for control.



Hysteresis, Span

Same relay operation as for split hysteresis, but specified differently. Here the setpoint is the upper control limit, and the lower control limit is the setpoint less the hysteresis band.



Item #

Also called Display Item. A numerical value in the meter available for display under control of a front panel key or serial communications. For example, in the A+B totalizer mode, the sum of A+B is Item #1, Total A is Item #2, and Total B is Item #3. When the meter is reset, Item #1 is always displayed. To view another Item, press the *RESET* key. For Item 1, the yellow View "V" LED is unlit. For Item 2, the "V" LED is lit. For Item 3 the "V" LED flashes.

Menu mode

Meter programming mode used for input and range selection, setup, and configuration. Entered into from the Run mode by pressing the MENU key. Can be locked out by a jumper on the power supply board.

Meter Hold

A rear panel input which freezes the meter display and all meter outputs while that input is tied to logic ground by a switch or is held at 0V (logic level true). The meter will resume operation when the input is disconnected or is held at +5V (logic level false).

Moving average filter

A digital filter mode which displays a weighting moving average of readings. Eight moving average modes are selectable with the following RC time constants: no filter, 0.1 sec, 0.2 sec, 0.4 sec, 0.8 sec, 1.6 sec, 3.2 sec, 6.4 sec.

Multiplier

A constant multiplier from 0.00001 to 100000 (in decade steps) that is combined with a *scale factor* from 0.00000 to 9.99999 (fixed decimal point and settable digits) to go from frequency in Hz to rate in engineering units such as gallons per minute or from pulse counts to total in engineering units, such as gallons. The combination of a 6-digit scale factor with a multiplier provides more dynamic range with no loss of resolution than could be achieved with a 6-digit scale factor only.

Offset A constant adder to the displayed reading. This may be any value from -999,999 to 999,99. The offset may be used as a preset in the totalize mode, where the total can be counted down from the preset to zero.

Peak display The maximum (or most positive) reading since that value was last reset. Reset can be via the meter front panel, an external input, or a software command. The displayed value can reflect the filtered or unfiltered readings.

Period The time of one complete cycle of the input frequency. A scale factor of 1 and multiplier of 1 produce a display in microseconds.

Phase angle The lead or lag in degrees between two AC signals of the same frequency. With signals applied to Channels A and B of the dual pulse input signal conditioner, phase angle can be displayed from -180° to +180° with 0.01° resolution.

Pulses Voltage waveshapes with leading and trailing edges that are detected for determination of frequency, period or time. With the quadrature signal conditioner, the menu item *Pulses* is used to set the number of pulses generated by a quadrature encoder for each zero index pulse. This setting is equal to the number of pulses per revolution of the encoder (times 2 or 4 if the count by 2 or 4 is selected on the signal conditioner) times the scale factor.

Process signal
An analog signal whose display requires setup of *scale* and *offset* for display in engineering units (such as psi). The process receiver & totalizer signal conditioner accepts 0-1 mA, 4-20 mA or 0-10 V process signals.

Quadrature A quadrature encoder generates 2 signals that are 90° out of phase based on the position of a rotor or linear scale. The phase relationship of these signals depends on the direction of rotation of the encoder. The meter counts up or down depending on the phase. Quadrature is used for very accurate determination of length or position.

Rate Same as frequency, except that a *scale factor* and *multiplier* have been applied to convert the reading in Hz to a reading in engineering units, such as RPM.

Remote Display
A display mode which allows a counter to serve as a 6-digit remote display when connected to a computer or meter via a serial communications output.

Reset Two types of Reset are applicable to counter/timer operation:
- Peak and Valley Reset. Achieved by simultaneously pressing the *RESET* and *PEAK* keys.
- Latched Alarm Reset. Achieved by simultaneously pressing the *RESET* and *ALARMS* keys.

Resolution A menu item which controls the resolution of arithmetic functions (A+B, A-B, AxB, A/B, A/B-1) of Grand Total in batch mode. It multiplies the displayed value by a factor of 0.00001 to 100,000 in decade steps. The decimal point then has to be moved appropriately.

RS485 half duplex

Serial communications implemented with two wires, allowing data transmission in both directions, but not simultaneously.

RS485 full duplex

Serial communications implemented with four wires, allowing data transmission in two directions simultaneously.

Run Mode The normal operating mode of the meter, where readings are taken, as opposed to the *menu mode*.

Scale factor A constant multiplier used to go from a raw reading in pulses per second or total pulses to a reading in engineering units. The scale factor consists of a scale value from 0.00000 to 9.99999 (fixed decimal point, settable digits) and a scale multiplier from 0.00001 to 100000 (in decade steps).

Scaling The process of setting *scale* and *offset* so that the meter reads properly in engineering units (such as gallons/minute).

Scaling, coordinates of 2 points method

A scaling method where four numbers are entered manually: low input, desired reading at low input; high input, and desired reading at high input. The meter then applies a straight line fit.

Scaling, scale and offset method

A scaling method where *scale* and *offset* are entered manually.

Setpoint A value compared to the reading to determine the state of a relay. Term often used interchangeably with “alarm setpoint.”

Stopwatch mode

A timing operating mode for single events. Stopwatch A-to-A measures time between the same positive (or negative) edge of start and stop pulses applied to Channel A. Stopwatch A-to-B measures time between a start pulse on Channel A and a stop pulse on Channel B.

Time interval mode

Returns the average duration of repetitive events over a programmed gate time. Time may be measured from the leading or trailing edge of pulses applied to Channel A to the leading or trailing edge of pulses applied to Channel B.

Time-out (or time before zero output)

The time the meter waits for a signal to start or end a conversion. While waiting, the counter displays rEAdinG. If pulses are not received before the time-out ends, the meter reads zero. The longer the time-out, the lower the minimum frequency the meter can display. This term is also used for the programmable time that the batch relay stays de-energized at the end of a batch cycle.

23. WARRANTY

Laurel Electronics Inc. warrants its products against defects in materials or workmanship for a period of one year from the date of purchase.

In the event of a defect during the warranty period, the defective unit may be returned to the seller, which may be Laurel or a Laurel distributor. The seller may then repair or replace the defective unit at its option. In the event of such a return, freight charges from the buyer shall be paid by the buyer, and freight charges from the seller shall be paid by the seller.

LIMITATION OF WARRANTY

The foregoing warranty shall not apply to defects resulting from:

1. Improper installation or miswiring.
2. Improper or inadequate maintenance.
3. Unauthorized modification or misuse.
4. Operation outside the environmental specifications.
5. Mishandling or abuse.

The warranty set forth above is exclusive, and no other warranty, whether written or oral, is expressed or implied. Laurel specifically disclaims implied warranties of merchantability and fitness for a particular purpose.

Any electronic product may fail or malfunction over time. To minimize risks associated with reliance on Laurel products, users are expected to provide adequate system-level design and operating safeguards. Laurel's products are intended for general purpose industrial or laboratory use. They are not intended nor certified for use in life-critical medical, nuclear, or aerospace applications, or for use in hazardous locations.

EXCLUSIVE REMEDIES

The remedies provided herein are Buyer's sole and exclusive remedies. In no event shall Laurel be liable for direct, indirect, incidental or consequential damages (including loss of profits) whether based on contract, tort, or any other legal theory.

Copyright 1999-2019, Laurel Electronics, Inc.

Artisan Technology Group is an independent supplier of quality pre-owned equipment

Gold-standard solutions

Extend the life of your critical industrial, commercial, and military systems with our superior service and support.

We buy equipment

Planning to upgrade your current equipment? Have surplus equipment taking up shelf space? We'll give it a new home.

Learn more!

Visit us at **artisantg.com** for more info on price quotes, drivers, technical specifications, manuals, and documentation.

Artisan Scientific Corporation dba Artisan Technology Group is not an affiliate, representative, or authorized distributor for any manufacturer listed herein.

We're here to make your life easier. How can we help you today?

(217) 352-9330 | sales@artisantg.com | artisantg.com

ARTISAN® TECHNOLOGY GROUP