ARTISAN®
TECHNOLOGY GROUP

Your **definitive** source for quality pre-owned equipment.

Artisan Technology Group
(217) 352-9330 | sales@artisantg.com | artisantg.com

Full-service, independent repair center
with experienced engineers and technicians on staff.

We buy your excess, underutilized, and idle equipment
along with credit for buybacks and trade-ins.

Custom engineering
so your equipment works exactly as you specify.

- Critical and expedited services
- In stock / Ready-to-ship
- Leasing / Rentals / Demos
- ITAR-certified secure asset solutions


Expert team | Trust guarantee | 100% satisfaction

All trademarks, brand names, and brands appearing herein are the property of their respective owners.

Find the *MEN Micro / Mikro Elektronik D2* at our website: *Click HERE*

Embedded Solutions

D2 - 6U Advanced Pentium CompactPCI Workstation



User Manual

Board-Level Computers for Industrial Applications

mikro elektronik gmbh · nürnberg

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

D2 - 6U Advanced Pentium CompactPCI Workstation

The D2 is a high-end PentiumIII-class workstation optimized for industrial requirements in control and instrumentation in terms of functionality, environmental conditions and cost. It needs only one slot in a CompactPCI system. Its "Socket 7+"-based computing core supports CPUs such as AMD's K6-III+ processor with 100MHz bus frequency and 400MHz and more internal clock speeds. The fast chip set comes with 100MHz CPU and 33MHz PCI bus clock and supports the latest DRAM technology. All PCI components are carefully selected for optimum support regarding long-term availability.

In addition to state-of-the-art PC functionality - such as 10/100Mbit Ethernet, UARTs, EIDE, LPT, Microsoft ACPI, floppy, GPIO and USB - the D2 is equipped with a bundle of industrial functions. These unique features are highly reliable, SMT-mounted SDRAM in addition to SO-DIMMs, SRAM as NOVRAM disk, flexible CompactFlash™ extension up to 100MB and more, BIOS extensions for non-video, boot from CompactFlash™ etc., support of PXI trigger signals (National Instruments), three local PC•MIP™ mezzanines for flexible and individual workstation I/O extensions like graphics, SCSI, additional serial lines, field buses etc. and various board and system control mechanisms.

The D2 is carefully prepared for all types of industrial qualification procedures such as extended temperature range (-40..+85°C), shock, vibration, humidity etc.

Technical Data

CompactPCI Bus

- 6U CompactPCI CPU board rev. 2.1 compliant
- Ali Aladdin V chip set
  - compliance with PCI specification 2.1
  - up to 33 MHz PCI frequency
- 32-bit CompactPCI system slot functionality
- 7 possible external loads due to PCI-to-PCI bridge
- DEC 21150 PCI-to-PCI bridge
- single-slot solution
- V(I/O): +3.3V or +5V (Universal Board)

CPU

- Pentium with MMX, 266MHz Tillamook, K6-III+ (Pentium III class)
- passive cooling
- up to 550MHz CPU frequency
- up to 100MHz local bus frequency

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Memory

- 512KB Level 2 Cache
- 32..288MB DRAM
  - 32MB on board
  - 128MB each on two SO-DIMM sockets
  - 100MHz SDRAM clock
- up to 4 MB battery-backed SRAM for user applications
  - via local PCI bus
  - no loss of data
- CompactFlash™ card interface for on-board Flash ATA
- 2Mbit BIOS Flash

Interfaces

- two serial communication ports (COM1/COM2)
- COM1: RS232 physical interface
  - 9-pin D-Sub connectors at front panel or via CompactPCI J4/J5
- COM2 via CompactPCI J5/J4
- full-duplex 10/100Mbit/s PCI Ethernet controller
  - 21143 PCI LAN controller
  - 10Base-T/100Base-TX interface at front panel (RJ45 connector)
  - simultaneous transmission of 10Mbit/s and 100Mbit/s frames
- three USB (Universal Serial Bus) interfaces
  - via CompactPCI J4/J5
  - conforming to Open HCI 1.0a
- keyboard and mouse at 6-pin PS2 connector at front panel
- parallel port (SPP, EPP, ECP) via CompactPCI J4/J5
- optional GPIOs at J4/J5 or Fast IR interface

PXI

- five trigger lines compliant with PXI Specification rev. 1.0

Local Extensions

- PC•MIP I/O at front panel or via CompactPCI rear I/O
- three PC•MIP mezzanine extension slots compliant with PC•MIP specification (2 Type I/II slots, 1 Type I slot)

Mass Storage

- two fast IDE interfaces
  - up to 33 MB/s (supports UltraDMA and PIO mode 4)
  - via Compact PCI J3/J4
- floppy-disk controller
  - 2.88 MB
  - via CompactPCI J4/J5

Miscellaneous

- battery-backed real-time clock

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

- external user-definable watchdog
- integrated hardware monitor
  - alarm function
  - supervises temperature, all voltages including back-up battery, and power supply (via CompactPCI)
- reset button at front panel
  - can be disabled through software
- LEDs at front panel: IDE, LAN, Power, user-definable
- power supply controlled by CPU: software-controlled power down

Electrical Specifications

- supply voltage/power consumption:
  - +5V: 4.85V..5.25V @ 2.95A (K6-III/450MHz), 1.66A (Tillamook/266MHz)
  - +3.3V: 3.0V..3.6V @ 0.98A (K6-III/450MHz), 0.83A (Tillamook/266MHz)
  - +12V: 11.4V..12.6V; -12V: -11.4V..-12.6V (power consumption determined by PC•MIPs used)
- MTBF: 66,200h @ 50°C

Mechanical Specifications

- dimensions: conforming to CompactPCI specification for 6U boards
- CompactPCI slots:
  - 4HP total for processors < 8W power dissipation
  - 8HP for processors > 8W power dissipation
  - only 4HP on CompactPCI backplane
- weight: 530g

Environmental Specifications

- temperature range (operation):
  - 0..+60°C (Pentium MMX/266MHz) or -40..+85°C (K6-III+/450)
  - airflow: min. 10m³/h
- temperature range (storage): -40..+85°C
- relative humidity range (operation): max. 95% non-condensing
- relative humidity range (storage): max. 95% non-condensing
- altitude: -300m to + 3,000m
- shock: 15g/0.33ms, 6g/6ms
- vibration: 1g/5..2,000Hz

Safety

- PCB manufactured with a flammability rating of 94V-0 by UL recognized manufacturers

EMC

- tested according to IEC1000-4-2 (burst) and IEC1000-4-4 (ESD) with regard to CE conformity

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

BIOS


- Plug and Play Award BIOS for industrial applications
- CMOS back-up: configuration data stored in EEPROM
- boot support for CompactFlash interface (DOS, VxWorks)
- console redirection: serial console administration via terminal (VT100; DOS, VxWorks)

Software Support

- WindowsNT
- VxWorks

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Block Diagram



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Ordering Information

Standard Hardware

02D002-00	D2, CompactPCI 6U, single board computer, Pentium MMX/ 266MHz, , 1MB cache, 1MB SRAM, 32MB DRAM, 100Mbit Ethernet, 3 PC•MIP slots, 1-slot front panel
02D002-03	D2, CompactPCI 6U, single board computer, K6-III+/450, 1MB cache, 32MB DRAM, 100Mbit Ethernet, 3 PC•MIP slots, temperature range 0..+45°C

Accessories

0500-0002	battery M4T28... for Timekeeper M48T86 (spare part)
05A000-10	keyboard/mouse Y-cable, 6-pin mini DIN plug to two 6-pin mini DIN receptacles (0.1m)
0751-0001	CompactFlash 32MB ATA/true IDE
0751-0002	CompactFlash card 8MB
0751-0003	CompactFlash card 192MB
0751-0005	CompactFlash card, 32MB, Type I, -40..+85°C
0751-0007	CompactFlash card, 512MB, Type I, -40..+85°C
0752-0007	DRAM SO-DIMM 64MB SDRAM, 10ns, 3.3V
0752-0008	DRAM SO-DIMM 128MB SDRAM, 10ns, 3.3V
08CT02-00	CompactPCI transition module 6U/80mm, I/O connection for D2
08SA01-00	serial interface adapter, RS232, not optically isolated
08SA02-00	serial interface adapter, RS422/485, half duplex, optically isolated
08SA02-01	serial interface adapter, RS422/485, full duplex, optically isolated
08SA03-00	serial interface adapter, RS232, optically isolated
08SA04-00	serial interface adapter, TTY, optically isolated
08SA05-00	serial interface adapter, RS232, not optically isolated

Basic Systems

0701-0004	CompactPCI 19" 3U rack-mount enclosure, 6U CompactPCI midplane, ATX power supply, fan, 2 batteries
0701-0010	CompactPCI 19" 7U rack-mount enclosure, 6U 8-slot CompactPCI midplane, ATX power supply, prepared for FD, HD and CD, 1U fan tray

EIDE, floppy and CD-ROM drives are delivered as requested.
Different rack sizes, power supplies and backplanes (3U/6U, J1..J5) on request.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Standard Software

10ABMX-08	Microsoft Windows NT 4.0: workstation license, German OEM version, CD-ROM and manual
10ABMX-09	Microsoft WindowsNT 4.0: workstation license, English OEM version, CD-ROM and manual
10D002-60	VxWorks V.5.4/Tornado II standard BSP for D2
13D002-00	WindowsNT: driver package for D2 (object code, MEN)
13M000-06	MDIS4 for WindowsNT system package download
13M000-07	MDIS4 for VxWorks system package download
13M000-08	MDIS4 for OS-9 system package download
13M000-13	MDIS4 for Linux system package download
13P003-70	WindowsNT V.4.0: Ethernet driver for P3/D1/D2/F2 (DEC, object code for x86), documentation of third-party supplier download
13Z001-06	low-level sources LM78 (MDIS4) incl. documentation (PDF) download
13Z002-06	low-level sources for Z8536/watchdog (MDIS4) incl. documentation (PDF) download
13Z004-06	low-level sources for ALI1543 user LEDs (MDIS4), incl. documentation (PDF) download
13Z008-06	DeviceNet sources for ALI1543, GPIO (MDIS4), incl. documentation (PDF) download

User Manuals

20D002-00	D2 user manual download
20CT02-00	CT02 user manual download
20SA00-00	SA adapter user manual download

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

About this Document

This user manual describes the hardware functions of the board, connection of peripheral devices and integration into a system. It also provides additional information for special applications and configurations of the board.

The manual does not include detailed information on individual components (data sheets etc.). A list of literature is given in the appendix.

History

Edition	Description	Technical Content	Date of Issue
E1	First edition	Jürgen Steinert	1999-10-19
E2	Second edition	Jürgen Steinert	2001-03-23
E3	Third edition	Klaus Weinert	2001-12-04

Conventions



This sign marks important notes or warnings concerning proper functionality of the product described in this document. You should read them in any case.

italics — Folder and file names are printed in *italics*.

bold — **Bold** type is used for emphasis.

hyperlink — Hyperlinks are printed in blue color.



The globe will show you where hyperlinks lead directly to the Internet, so you can look for the latest information online.

`0xFF` — Hexadecimal numbers are preceded by "0x", which is the usual C-language convention, and are printed in a monospace type, e.g. `0x00FFFF`.

IRQ# /IRQ — Signal names followed by "#" or preceded by a slash ("/") indicate that this signal is either active low or that it becomes active at a falling edge.

in/out — Signal directions in signal mnemonics tables generally refer to the corresponding board or component, "in" meaning "to the board or component", "out" meaning "coming from it".

Vertical lines on the outer margin signal technical changes to the previous edition of the document.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Short Glossary of PC•MIP Terms

For a complete glossary of PC•MIP terms and definitions, please refer to the PC•MIP specification.

Front

The front of the PC•MIP module is the flat surface of the module that faces outward, away from the carrier board, when the module is mounted on the carrier.

J1, J2

J1 and J2 are two 64-pin receptacle connectors on the PC•MIP module that carry the 32-bit PCI bus via which the carrier and the module communicate. J1 and J2 mate to P1 and P2 on the carrier board respectively.

J3

J3 is the 64-pin I/O receptacle connector between the module and the carrier board. 14 ground pins are defined on this connector by the specification, but the remaining 50 pin functions are defined by each module. J3 mates to P3 on the carrier board.

J4

J4 is a term reserved for the "front panel" I/O connector on type II PC•MIP modules, but not on type I modules. The selection of the physical connector is left to manufacturer of the type II module, and is not defined in the specification. J4 typically mates to a an equivalent P4 connector on a cable.

Rear

The rear of the PC•MIP module is the flat surface of the module that faces inward, towards the carrier board, when the module is mounted on the carrier.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com



ESD Warning

Computer boards and components contain very delicate Integrated Circuit (IC) chips. Electrostatic discharge (ESD) can damage components. To protect the board and other components against damage from static electricity, you should follow some precautions whenever you work on your computer.

- Power down and unplug your computer system when working on the inside.
- Hold components by the edges and try not to touch the IC chips, leads, or circuitry.
- Use a grounded wrist strap before handling computer components.
- Place components on a grounded antistatic pad or on the bag that came with the component whenever the components are separated from the system.
- Store the board only in its original ESD-protected packaging. Retain the original packaging in case you need to return the board to MEN for repair.

Copyright Information

MEN reserves the right to make changes without further notice to any products herein. MEN makes no warranty, representation or guarantee regarding the suitability of its products for any particular purpose, nor does MEN assume any liability arising out of the application or use of any product or circuit, and specifically disclaims any and all liability, including without limitation consequential or incidental damages.
"Typical" parameters can and do vary in different applications. All operating parameters, including "Typicals" must be validated for each customer application by customer's technical experts.
MEN does not convey any license under its patent rights nor the rights of others.
MEN products are not designed, intended, or authorized for use as components in systems intended for surgical implant into the body, or other applications intended to support or sustain life, or for any other application in which the failure of the MEN product could create a situation where personal injury or death may occur. Should Buyer purchase or use MEN products for any such unintended or unauthorized application, Buyer shall indemnify and hold MEN and its officers, employees, subsidiaries, affiliates, and distributors harmless against all claims, costs, damages, and expenses, and reasonable attorney fees arising out of, directly or indirectly, any claim of personal injury or death associated with such unintended or unauthorized use, even if such claim alleges that MEN was negligent regarding the design or manufacture of the part.

All brand or product names are trademarks or registered trademarks of their respective holders.

Information in this document has been carefully checked and is believed to be accurate as of the date of publication; however, no responsibility is assumed for inaccuracies. MEN will not be liable for any consequential or incidental damages arising from reliance on the accuracy of this document. The information contained herein is subject to change without notice.

Copyright © 2001 MEN Mikro Elektronik GmbH. All rights reserved.

Germany
MEN Mikro Elektronik GmbH
Neuwieder Straße 7
90411 Nuremberg
Phone +49-911-99 33 5-0
Fax +49-911-99 33 5-99
E-mail info@men.de
www.men.de

France
MEN Mikro Elektronik SA
18, rue René Cassin
ZA de la Châtelaine
74240 Gaillard
Phone +33 (0) 450-955-312
Fax +33 (0) 450-955-211
E-mail info@men-france.fr
www.men-france.fr

UK
MEN Micro Ltd
Whitehall, 75 School Lane
Hartford, Northwich
Cheshire UK, CW8 1PF
Phone +44 (0) 1477-549-185
Fax +44 (0) 1477-549-178
E-mail info@menmicro.co.uk
www.menmicro.co.uk

USA
MEN Micro, Inc.
3740 North Josey Lane, Suite 203
Carrollton, TX 75007
Phone 972-939-2675
Fax 972-939-0055
E-mail sales@menmicro.com
www.menmicro.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Contents

1 Getting Started 16
1.1 Map of the Board 16
1.2 Configuring the Hardware 17
1.3 Integrating the Board into a System 18
1.4 Troubleshooting at Start-up 18
1.5 Configuring BIOS 19
1.6 Installing Operating System Software 19
2 Functional Description 20
2.1 Power Supply 20
2.2 Clock Supply 20
2.3 Processor Core 21
2.3.1 Socket 7+ 21
2.3.2 Host-to-PCI Bridge 21
2.3.3 Main Memory (DRAM) 22
2.3.4 L2 Cache 23
2.4 CompactPCI Interface 24
2.4.1 General 24
2.4.2 Extensions 25
2.5 Ethernet Interface 32
2.5.1 Implementation on D2 32
2.5.2 General 33
2.5.3 10Base-5 33
2.5.4 10Base-2 33
2.5.5 10Base-T 34
2.5.6 100Base-T 34
2.6 CompactFlash/SRAM Interface 35
2.6.1 CompactFlash Interface 35
2.6.2 Battery-backed SRAM 36
2.6.3 Booting from CompactFlash/SRAM 36
2.7 Super I/O Controller 37
2.7.1 COM1 Port 37
2.7.2 Keyboard/Mouse Interface 38
2.7.3 EIDE Interface 39
2.7.4 USB Interface 39
2.7.5 GPIO Interface 39
2.8 PC•MIP Slots 40
2.8.1 Installing a PC•MIP 40
2.8.2 PC•MIP Connectors 41
2.8.3 Signal Mapping from PC•MIP Connector to Rear I/O 41
2.9 Front LEDs and Reset Button 43
2.10 System Trigger, Watchdog and Hardware Monitor 44

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3 Award BIOS 46
3.1 Main Setup Menu 46
3.2 Special Features Setup 48
3.3 Console Redirection 49
3.3.1 Configuring BIOS 49
3.3.2 Configuring a Terminal Cable 50
3.3.3 Configuring the Terminal 50
3.4 BIOS Restrictions 51
3.5 BIOS Troubleshooting 51
4 Organization of the Board 52
4.1 Local PCI Bus 52
4.1.1 Device Numbers 52
4.1.2 Interrupt Routing 52
4.2 CompactPCI Bus 53
4.2.1 Device Numbers 53
4.2.2 Interrupt Routing and Buffering 53
4.3 ISA Bus 53
5 Appendix 54
5.1 Literature and WWW Resources 54
5.1.1 CompactPCI/PCI 54
5.1.2 PXI 54
5.1.3 PC•MIP 54
5.1.4 EIDE 54
5.1.5 Parallel Peripherals - EPP 54
5.1.6 Ethernet 55
5.1.7 USB 55
5.2 Board Revisions 55
5.3 Component Plans 56

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Figures

Figure 1. Map of the Board - Front Panel and Top View 16
Figure 2. Installing an SO-DIMM DRAM Module 22
Figure 3. Inserting a CompactFlash Card 35
Figure 4. Installation of a PC•MIP (example for slot A or B) 41
Figure 5. Front Panel LEDs and Reset Button 43
Figure 6. BIOS CMOS Setup Utility - Main Menu 46
Figure 7. Component Plan of D2 Rev. 02 - Top Side 56
Figure 8. Component Plan of D2 Rev. 02 - Bottom Side 57

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Tables

Table 1. Pin Assignment of CompactPCI J2 (110-pin type "B" modified) 25
Table 2. Signal Mnemonics for CompactPCI J2 25
Table 3. Pin Assignment of CompactPCI J3 (95-pin type "B" modified) 26
Table 4. Signal Mnemonics of Connector J3 27
Table 5. Pin Assignment of CompactPCI J4 (110-pin type "A") 28
Table 6. Signal Mnemonics of Connector J4 29
Table 7. Pin Assignment of CompactPCI J5 (110-pin type "B" modified) 31
Table 8. Signal Mnemonics for CompactPCI J5 31
Table 9. Pin Assignment of the 8-pin RJ45 Ethernet 10Base-T/100Base-TX Connector 32
Table 10. Signal Mnemonics for Ethernet 10Base-T/100Base-TX Interface. . . . 32
Table 11. Pin Assignment of the 9-pin D-Sub COM1 Plug Connector 37
Table 12. Signal Mnemonics for Serial Port COM1 37
Table 13. Pin Assignment of the 6-Pin Mini DIN Keyboard/Mouse Connector . 38
Table 14. Signal Mnemonics for Keyboard/Mouse Interface 38
Table 15. Correspondence between GPIO and UART3 Pins 39
Table 16. Signal Mapping from PC•MIP J3/P3 to Rear I/O 42
Table 17. Port Pin Assignment of the Z8536 CIO 44
Table 18. Pin Assignment for Terminal Cable 50
Table 19. Device Numbers on Local PCI Bus 52
Table 20. Device Numbers on CompactPCI Backplane. 53
Table 21. ISA Bus Plug and Play Device IDs 53
Table 22. Table of Hardware Revisions 55


Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

1 Getting Started

Before you install the D2 in your system you should check if you need to make any changes to the factory configuration. The following overview of the board and the subsequent chapters including a "check list" will help you do this.

1.1 Map of the Board

Figure 1. *Map of the Board - Front Panel and Top View*



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

1.2 Configuring the Hardware

You should check your hardware requirements before installing the board in a system, since most modifications are difficult or even impossible to do when the board is mounted in a rack.

The following check list will give an overview on what you might want to configure.

☑ DRAM SO-DIMM modules

The D2 may be shipped without any DRAM on board, depending on the model ordered. You should check on your main memory needs and install suitable 8-byte SO-DIMM modules.

Refer to Chapter 2.3.3 Main Memory (DRAM) on page 22 for a detailed installation description and hints on supported SO-DIMM modules.

☑ CompactFlash

Refer to Chapter 2.6.1 CompactFlash Interface on page 35 for a detailed installation description and hints on supported CompactFlash cards.

☑ PC•MIP mezzanine modules

Refer to Chapter 2.8.1 Installing a PC•MIP on page 40 for a detailed installation description.

☑ CT02 transition module

MEN offers the CT02 transition module for connection of mass storage devices and other peripherals.
If you want to use this interface adapter together with the D2, you must install the adapter in the rack **before** you install the CPU board. For details on connection and installation please refer to the CT02 manual.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

1.3 Integrating the Board into a System



Keep in mind that the D2 is a pure motherboard! To get into BIOS and carry out the following steps, you will have to connect at least a **terminal** or a **graphics card**, **VGA monitor** and **keyboard**. The D2 supports connection of a terminal to COM1/ COM2. If you want to make use of this option, please refer to Chapter 3.3 Console Redirection on page 49.

The following check list will help you make your D2 board run a system with minimum configuration.

- ☑ Power down the system.
- ☑ Remove all boards from the CompactPCI system.
- ☑ Insert the D2 into the system slot of your CompactPCI system, making sure that the CompactPCI connectors are properly aligned.



Note: The D2 **must** be inserted into the system slot! The system slot of every CompactPCI system is marked by a △ triangle on the backplane and/or at the front panel. It also has red guide rails.

- ☑ Power up the system.
- ☑ You can fork up BIOS now by hitting the DEL key.
- ☑ Now you can make configurations in BIOS setup (see Chapter 3 Award BIOS on page 46).
- ☑ Observe the installation instructions in your WindowsNT or VxWorks documentation.

1.4 Troubleshooting at Start-up

Usually, problems at start-up of a system can be dealt with through BIOS. You can start the board with BIOS default settings for troubleshooting. Please refer to Chapter 3.5 BIOS Troubleshooting on page 51.

D2 Models without VBAT and +5V_STDBY

There may be problems at start-up with D2 models up to hardware revision 02.xx that do not have VBAT and +5V_STDBY lines (for ATX power supplies). When the system was powered down for longer periods of time, there may be problems at system start-up. The D2 starts normally only after powering down and up several times.

The reason for this behavior lies in the missing VBAT and +5V_STDBY lines.

To guarantee a safe start-up, you must connect +5V to the VBAT line at the power supply/utility connector of the CT02. In addition you must connect the +5V_STDBY pin to ground. Then, the D2 will not expect an ATX-compatible power supply.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

1.5 Configuring BIOS

The D2 is equipped with an Award Elite BIOS which is compliant with the Plug and Play BIOS specification, V. 1.0A and the PCI BIOS specification, V. 1.0.

Normally you won't need to make any changes in the BIOS setup. If you do, however, you find further details on the D2's Award BIOS in Chapter 3 Award BIOS on page 46.

1.6 Installing Operating System Software

The D2 fully supports WindowsNT version 4.0 and VxWorks version 5.3.1.



By standard, no operating system is installed on the board. Please refer to your WindowsNT or VxWorks documentation on how to install the software!

Note: Please keep in mind that you need a hard disk and probably a CD-ROM drive to install operating system software.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2 Functional Description

2.1 Power Supply

Power is fed via the CompactPCI backplane in accordance with the CompactPCI specification.

The D2 supports soft power down and up operation as described in the ATX specification. The necessary signals (PS_ON, +5V_STDBY, PWR_BTN#) are provided at the J4 connector for use via the CT02 transition module.

PS_ON is used as an output to the ATX power supply.

PWR_BTN# is normally connected to a push button of the ATX power supply unit. Pushing the button shortly switches the power supply on. Pushing the button for more than four seconds switches the power supply off, i.e. the D2 is put to standby mode.

In standby mode, the yellow "Standby" LED at the front panel will be lighted (see Figure 1, Map of the Board - Front Panel and Top View, on page 16).

The power supply/utility connector implemented on the CT02 transition module also provides I²C signals SCL and SDA, and battery backup lines (VBAT and GND (VBAT-)) for the D2's SRAM. You can either connect these lines to the ATX power supply or use an external battery to supply SRAM.

Note: Pull-up resistors required for I²C operation are implemented on the D2 CPU board itself.



Note: If you have a complete CompactPCI system from MEN, the power pins will already be wired correctly. If you do not have a complete system, make sure to wire the three power pins as is adequate. Please refer to the ATX specification for wiring recommendations.

2.2 Clock Supply

A clock supply generates all clocks necessary for operation of the D2, i.e. the clocks for the Pentium local bus and PCI bus in particular. The configuration depends on the processor installed and is done by MEN.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.3 Processor Core

2.3.1 Socket 7+

The D2 is equipped with a 321-pin socket compliant to the Intel® Socket 7+ specification. Supported processor types are:

- Mobile Pentium Processor with Voltage Reduction Technology (type P54C with VRT)
- Pentium Tillamook processor with MMX technology
- Pentium with MMX Technology (type P55C)
- AMD K6-III(+)

Contact MEN for other processor options.



Note: MEN gives no warranty on functionality and reliability of the D2 if you use any other processor than that supplied by MEN. Please contact either MEN directly or your local MEN sales office!

Processors supplied by MEN are equipped with an appropriate heat sink or fan/heat sink assembly, respectively. The fans/heat sinks supplied by MEN will match the thermal characteristics of the processor. Moreover, in case a fan/heat sink assembly is used, MEN selects fans with an appropriate MTBF (usually 210,000 h at 60°C) and a tachometer pulse pin. The tachometer pulses will be monitored on the D2.



MEN provides driver software for the hardware monitor of the D2, which allows to generate an alarm to the user before the application fails! For current software support, please refer to our website: www.men.de.



Note: Don't use any other heat sinks or fans than that supplied by MEN!

2.3.2 Host-to-PCI Bridge

The D2 uses the Ali Aladdin V chipset. The host-to-PCI bridge ("Northbridge") of this chip set is called M1541. The M1541 contains the host interface unit, the DRAM and L2 cache controllers, and the PCI interface unit. The M1541 acts as the PCI system master.

The M1541 is initialized by BIOS.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.3.3 Main Memory (DRAM)

The D2 provides two SO-DIMM sockets for installation of 512MB DRAM maximum.

32MB of DRAM (128MB max.) may be soldered to the D2 directly. The on-board DRAM covers bank 2.


We recommend use of SDRAM SO-DIMMs complying with the PC100 specification for maximum performance. These modules shall support 100MHz operation with a maximum clock-to-output of 6ns.

You may use either single or double-sided modules using 4 Mbit, 16 Mbit, 64 Mbit or 256 Mbit DRAM chips with x64 organization. Supply voltage for the SO-DIMM modules is 3.3V.

2.3.3.1 Installing a SO-DIMM Module

The D2 is normally shipped without any DRAM SO-DIMM modules installed. To install SO-DIMM modules, please stick to the following procedure.

Figure 2. *Installing an SO-DIMM DRAM Module*



The DRAM module will only fit as shown above because of a safety tab on the SO-DIMM socket which requires a notch in the SO-DIMM module.



- ☑ Power down the system before installing a SO-DIMM module to avoid damage of the D2!
- ☑ Place the memory module into the socket at a 45° angle and make sure that the safety tab and notch are aligned.
- ☑ Carefully push the memory module into the contact groove of the socket.
- ☑ Press the memory module down until it clicks into place.
- ☑ The plastic clips of the socket now hold the memory module in place.
- ☑ To release the module, squeeze both plastic clips outwards and carefully pull the module out of the socket.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.3.3.2 Supported SO-DIMM Modules

You can install standard SO-DIMM modules with SDRAM components. See Chapter Ordering Information on page 7 for memory modules available from MEN.



Note: MEN gives no warranty on functionality and reliability of the D2 if you use any other module than that qualified and/or supplied by MEN. Please contact either MEN directly or your local MEN sales office.

2.3.4 L2 Cache

The D2 is equipped with 1MB L2 cache.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.4 CompactPCI Interface

2.4.1 General

The D2 is a 6U CompactPCI system slot board. It implements a 32-bit PCI interface to the CompactPCI backplane which may use either a 5V or 3.3V signaling voltage.

The local PCI bus and the CompactPCI bus are coupled using a DEC DS21150 PCI-to-PCI bridge. This has several advantages:

- The D2 presents only one load to the CompactPCI backplane and thus surpasses the CompactPCI specification. This results in increased reliability.
- The D2 supports independent clocks for any CompactPCI slot as defined in the CompactPCI specification 2.1.
- The D2 provides seven REQ#/GNT# pairs, which means that PCI bus masters are supported on any CompactPCI slot.
- The D2 supports either 3.3V or 5V signaling voltage on the CompactPCI backplane. This guarantees maximum flexibility in the design of a CompactPCI system.
- Concurrent operation of local PCI and CompactPCI.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.4.2 Extensions

2.4.2.1 CompactPCI J1/J2

The D2 supports the latest features incorporated in the CompactPCI specification 2.1: It provides separate clocks for slots 7 and 8 (CLK5, CLK6) and supports geographic addressing.

Moreover it supports the PXI specification (issued by National Instruments, Inc.): It provides five independently programmable trigger lines connected to PXI_TRIG[4:0].


In addition the central backup battery is connected to the CompactPCI backplane.

Connector types:

- shielded, 2mm-pitch, 5-row receptacle according to IEC 917 and IEC 1076-4-101

The pin assignment of connectors J1 and J2 as defined in the CompactPCI specification will not be repeated here. The table below shows the special features of the D2 (i.e. the upper half of J2) only.

Table 1. *Pin Assignment of CompactPCI J2 (110-pin type "B" modified)*



	F	E	D	C	B	A
22	GND	GA[0]	GA[1]	GA[2]	GA[3]	GA[4]
21	GND	RES	RES	RES	GND	CLK[6]
20	GND	RES	GND	RES	GND	CLK[5]
19	GND	RES	RES	RES	GND	GND
18	GND	RES	GND	RES	PXI_TRIG[4]	PXI_TRIG[3]
17	GND	GNT[6]#	REQ[6]#	PBRST#	GND	PXI_TRIG[2]
16	GND	RES	GND	PS_DEG#	PXI_TRIG[0]	PXI_TRIG[1]
15	GND	GNT[5]#	REQ[5]#	PS_FAIL#	GND	RES

Table 2. *Signal Mnemonics for CompactPCI J2*

	Signal	Direction	Function
	GND	-	logic ground
CompactPCI	CLK[6:5]	out	clocks 5 and 6
	GA[4:0]	in	geographic address bits
	REQ#/GNT#[6:5]	in/out	request/grant pairs 5:6
	PBRST#	in	push button reset
	PS_FAIL#	in	power supply fail
	PS_DEG#	in	power supply degenerate
	RES	-	reserved
PXI	PXI_TRIG[4:0]	in/out	trigger lines according to PXI specification 1.0

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.4.2.2 CompactPCI J3/J4/J5


CompactPCI J3/J4/J5 are used to put peripheral interfaces off the board: These connectors contain interfaces such as PC•MIP I/O, EIDE, serial I/O, floppy disk and parallel port.

CT02 Transition Module

MEN offers a transition module for connection to J3/J4/J5 that implements all interfaces led through this connector for direct connection. If you use this adapter, please refer to its user manual for a detailed description.

The tables below show the pin assignment of J3/J4/J5. The connector types are identical with J1/J2. The different functional groups are marked through different colors in the tables.

Table 3. *Pin Assignment of CompactPCI J3 (95-pin type "B" modified)*



	F	E	D	C	B	A
19	GND	+12V	GND	+12V	GND	+5V
18	GND	SIDE_ACT#	SIDE_CS3#	GND	SIDE_CS1#	+5V
17	GND	SIDE_A[2]	SIDE_A[0]	SIDE_A[1]	SIDE_IRQ	SIDE_DAK#
16	GND	SIDE_RDY	SIDE_RD#	GND	SIDE_WR#	GND
15	GND	SIDE_DRQ	GND	SIDE_D[15]	SIDE_D[0]	SIDE_D[14]
14	GND	SIDE_D[1]	SIDE_D[13]	SIDE_D[2]	SIDE_D[12]	SIDE_D[3]
13	GND	SIDE_D[11]	SIDE_D[4]	SIDE_D[10]	SIDE_D[5]	SIDE_D[9]
12	GND	SIDE_D[6]	SIDE_D[8]	SIDE_D[7]	GND	SIDE_RST#
11	GND	+5V	+5V	+3.3V	+3.3V	+3.3V
10	GND	-	-	-	-	-
9	GND	-	-	-	-	-
8	GND	-	-	-	-	-
7	GND	-	-	-	-	-
6	GND	-	-	-	-	-
5	GND	-	-	-	-	-
4	GND	-	-	-	-	-
3	GND	-	-	-	-	-
2	GND	-	-	-	-	-
1	GND	-	-	-	-	-


Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Table 4. *Signal Mnemonics of Connector J3*

	Signal	Direction	Function
Power	GND	-	digital ground
	+3.3V	-	+3.3V power supply
	+5V	-	+5V power supply
	+12V	-	+12V power supply
Secondary IDE	SIDE_RST#	out	secondary IDE reset; active low
	SIDE_D[15:0]	in/out	secondary IDE data [15:0]
	SIDE_A[2:0]	out	secondary IDE address [2:0]
	SIDE_WR#	out	secondary IDE write strobe; active low
	SIDE_RD#	out	secondary IDE read strobe; active low
	SIDE_RDY#	in	secondary IDE ready; active low
	SIDE_DRQ	in	secondary IDE DMA request
	SIDE_DAK#	out	secondary IDE DMA acknowledge; active low
	SIDE_IRQ	in	secondary IDE interrupt request
	SIDE_CS1#	out	secondary IDE chip select 1; active low
	SIDE_CS3#	out	secondary IDE chip select 3; active low
	SIDE_ACT#	in	secondary IDE active; active low

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Table 5. *Pin Assignment of CompactPCI J4 (110-pin type "A")*



	F	E	D	C	B	A
25	GND	USBP1+	PWR_BTN#	GPIO[4]	GPIO[0]	VBAT
24	GND	USBP1-	PS_ON	GPIO[5]	GPIO[1]	SDA
23	GND	USBP0+	+5V_STDBY	GPIO[6]	GPIO[2]	SCL
22	GND	USBP0-	+5V	GPIO[7]	GPIO[3]	RI2#
21	GND	USB_OVR#	DCD2#	CTS2#	DSR2#	RTS2#
20	GND	DTR2#	RXD2#	TXD2	+5V	RI1#
19	GND	DCD1#	CTS1#	DSR1#	RTS1#	DTR1#
18	GND	RXD1	TXD1	+5V	SLCT	PE
17	GND	BUSY	ACK#	PD[7]	PD[6]	PD[5]
16	GND	PD[4]	PD[3]	SLIN#	PD[2]	INIT#
15	GND	PD[1]	ERR#	PD[0]	AFD#	STB#
Voltage Key						
11	GND	DSKCHG#	HDSEL#	RDATA#	WP#	TRK0#
10	GND	WGATE#	WDATA#	STEP#	DIR#	MOTOR1#
9	GND	DRVSEL0#	DRVSEL1#	MOTOR0#	INDEX#	DENSEL
8	GND	+12V	GND	+12V	GND	+5V
7	GND	PIDE_ACT#	PIDE_CS3#	GND	PIDE_CS1#	+5V
6	GND	PIDE_A[2]#	PIDE_A[0]	PIDE_A[1]	PIDE_IRQ	PIDE_DAK#
5	GND	PIDE_RDY#	PIDE_RD#	GND	PIDE_WR#	GND
4	GND	PIDE_DRQ	GND	PIDE_D[15]	PIDE_D[0]	PIDE_D[14]
3	GND	PIDE_D[1]	PIDE_D[13]	PIDE_D[2]	PIDE_D[12]	PIDE_D[3]
2	GND	PIDE_D[11]	PIDE_D[4]	PIDE_D[10]	PIDE_D[5]	PIDE_D[9]
1	GND	PIDE_D[6]	PIDE_D[8]	PIDE_D[7]	GND	PIDE_RST#

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Table 6. *Signal Mnemonics of Connector J4*


	Signal	Direction	Function
Power Lines	+12V	-	+12V power supply
	+3.3V	-	+3.3V power supply
	+5V	-	+5V power supply
	+5V_STDBY	-	+5V standby power supply
	GND	-	digital ground
	PS_ON	out	power supply on
	PWR_BTN#	in	power button
	VBAT	-	battery backup voltage
Primary IDE	PIDE_A[2:0]	out	primary IDE address [2:0]
	PIDE_ACT#	in	primary IDE active
	PIDE_CS1#	out	primary IDE chip select 1
	PIDE_CS3	out	primary IDE chip select 3
	PIDE_D[15:0]	in/out	primary IDE data [15:0]
	PIDE_DAK#	out	primary IDE DMA acknowledge
	PIDE_DRQ	in	primary IDE DMA request
	PIDE_IRQ	in	primary IDE interrupt request
	PIDE_RD#	out	primary IDE read strobe
	PIDE_RDY#	in	primary IDE ready
	PIDE_RST#	out	primary IDE reset
	PIDE_WR#	out	primary IDE write strobe
Floppy Disk	DENSEL	out	floppy disk density select
	DIR#	out	floppy disk direction
	DRVSEL0#	out	floppy disk drive select 0
	DRVSEL1#	out	floppy disk drive select1
	DSKCHG#	in	floppy disk disk change
	HDSEL#	out	floppy disk head select
	INDEX#	in	floppy disk index
	MOTOR0#	out	floppy disk motor on 0
	MOTOR1#	out	floppy disk motor on 1
	RDATA#	in	floppy disk read data
	STEP#	out	floppy disk step
	TRK0#	in	floppy disk track 0
	WDATA#	out	floppy disk write data
	WGATE#	out	floppy disk write gate
	WP#	in	floppy disk write protect

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

	Signal	Direction	Function
Parallel Port	ACK#	in	parallel port acknowledge
	AFD#	out	parallel port auto feed
	BUSY	in	parallel port busy
	ERR#	in	parallel port error
	INIT#	out	parallel port init
	PD[7:0]	in/out	parallel port data [7:0]
	PE	in	parallel port paper end
	SLCT	out	parallel port select
	SLIN#	in	parallel port select in
	STB#	out	parallel port strobe
COM1	CTS1#	in	serial port 1 clear to send
	DCD1#	in	serial port 1 data carrier detect
	DSR1#	in	serial port 1 data set ready
	DTR1#	out	serial port 1 data terminal ready
	RI1#	in	serial port 1 ring indicator
	RTS1#	out	serial port 1 request to send
	RXD1	in	serial port 1 Receive data
	TXD1	out	serial port 1 transmit data
COM2	CTS2#	in	serial port 2 clear to send
	DCD2#	in	serial port 2 data carrier detect
	DSR2#	in	serial port 2 data set ready
	DTR2#	out	serial port 2 data terminal ready
	RI2#	in	serial port 2 ring indicator
	RTS2#	out	serial port 2 request to send
	RXD2	in	serial port 2 receive data
	TXD2	out	serial port 2 transmit data
Utility	SCL	in/out	I²C serial clock
	SDA	in/out	I²C serial data
GPIO	GPIO[7:0]	in/out	general purpose I/Os [7:0]
USB	USBP0-, USBP0+	in/out	USB port 0 differential pair
	USBP1-, USBP1+	in/out	USB port 1 differential pair
	USB_OVR#	in	USB overcurrent detection

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Table 7. *Pin Assignment of CompactPCI J5 (110-pin type "B" modified)*



	F	E	D	C	B	A
22	GND	MIPE_IO[46]	MIPE_IO[47]	MIPE_IO[48]	MIPE_IO[49]	MIPE_IO[50]
21	GND	MIPE_IO[41]	MIPE_IO[42]	MIPE_IO[43]	MIPE_IO[44	MIPE_IO[45
20	GND	MIPE_IO[36]	MIPE_IO[37]	MIPE_IO[38]	MIPE_IO[39]	MIPE_IO[40]
19	GND	MIPE_IO[31]	MIPE_IO[32]	MIPE_IO[33]	MIPE_IO[34]	MIPE_IO[35]
18	GND	MIPE_IO[26]	MIPE_IO[27]	MIPE_IO[28]	MIPE_IO[29]	MIPE_IO[30]
17	GND	MIPE_IO[21]	MIPE_IO[22]	MIPE_IO[23]	MIPE_IO[24]	MIPE_IO[25]
16	GND	MIPE_IO[16]	MIPE_IO[17]	MIPE_IO[18]	MIPE_IO[19]	MIPE_IO[20]
15	GND	MIPE_IO[11]	MIPE_IO[12]	MIPE_IO[13]	MIPE_IO[14]	MIPE_IO[15]
14	GND	MIPE_IO[6]	MIPE_IO[7]	MIPE_IO[8]	MIPE_IO[9]	MIPE_IO[10]
13	GND	MIPE_IO[1]	MIPE_IO[2]	MIPE_IO[3]	MIPE_IO[4]	MIPE_IO[5]
12	GND	+5V	+5V	+3.3V	+3.3V	+3.3V
11	GND	MIPA_IO[46]	MIPA_IO[47	MIPA_IO[48]	MIPA_IO[49]	MIPA_IO[50]
10	GND	MIPA_IO[41]	MIPA_IO[42	MIPA_IO[43]	MIPA_IO[44]	MIPA_IO[45
9	GND	MIPA_IO[36]	MIPA_IO[37]	MIPA_IO[38]	MIPA_IO[39]	MIPA_IO[40]
8	GND	MIPA_IO[31]	MIPA_IO[32]	MIPA_IO[33]	MIPA_IO[34]	MIPA_IO[35]
7	GND	MIPA_IO[26]	MIPA_IO[27]	MIPA_IO[28]	MIPA_IO[29]	MIPA_IO[30]
6	GND	MIPA_IO[21]	MIPA_IO[22]	MIPA_IO[23]	MIPA_IO[24]	MIPA_IO[25]
5	GND	MIPA_IO[16]	MIPA_IO[17]	MIPA_IO[18]	MIPA_IO[19]	MIPA_IO[20]
4	GND	MIPA_IO[11]	MIPA_IO[12]	MIPA_IO[13]	MIPA_IO[14]	MIPA_IO[15]
3	GND	MIPA_IO[6]	MIPA_IO[7]	MIPA_IO[8]	MIPA_IO[9]	MIPA_IO[10]
2	GND	MIPA_IO[1]	MIPA_IO[2]	MIPA_IO[3]	MIPA_IO[4]	MIPA_IO[5]
1	GND	+5V	+5V	+3.3V	+3.3V	+3.3V

Table 8. *Signal Mnemonics for CompactPCI J5*

Signal	Direction	Function
+3.3V	-	+3.3V power supply
+5V	-	+5V power supply
GND	-	logic ground
MIPA_IO[50:1]	in/out	PC•MIP A rear panel I/Os [50:1], signals from PC•MIP slot A
MIPE_IO[50:1]	in/out	PC•MIP 3 rear panel I/Os [50:1], signals from PC•MIP slot E

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.5 Ethernet Interface


2.5.1 Implementation on D2

The Ethernet interface is built around Intel's DS21143 Fast Ethernet Controller. This chip connects directly to the local PCI bus. The physical interface is implemented as 10Base-T/100Base-TX (Twisted Pair) with a standard 8-pin RJ45 connector at the front panel.

Connector types:

- modular 8/8-pin mounting jack according to FCC68
- mating connector:
  modular 8/8-pin plug according to FCC68

Table 9. *Pin Assignment of the 8-pin RJ45 Ethernet 10Base-T/100Base-TX Connector*



1	TD+
2	TD-
3	RD+
4	-
5	-
6	RD-
7	-
8	-

Table 10. *Signal Mnemonics for Ethernet 10Base-T/100Base-TX Interface*

Signal	Direction	Function
TD+/-	out	differential pair of transmit data lines
RD+/-	in	differential pair of receive data lines

Full-duplex operation is also supported and full-duplex and half-duplex network environments are autodetected using the IEEE802.3 autonegotiation algorithm.

The Ethernet interfaces allow data rates of 100Mbit/s and even 200Mbit/s with full-duplex operation.

The DS21143 supports a Microwire EEPROM to store the Ethernet MAC address and chip-specific data for power-on configuration. This EEPROM is programmed by MEN with a unique MAC address reserved for MEN. You should not alter its contents.

For further details about the DS21143, please refer to the literature listed in Chapter 5.1 Literature and WWW Resources on page 54.

For resources on the WWW, please refer to the links in Chapter 5.1.6 Ethernet on page 55.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.5.2 General

Quelle: http://webopedia.internet.com/TERM/E/Ethernet.html

Ethernet is a local-area network (LAN) protocol that uses a bus or star topology and supports data transfer rates of 100Mbps and more. The Ethernet specification served as the basis for the IEEE 802.3 standard, which specifies the physical and lower software layers. Ethernet uses the CSMA/CD access method to handle simultaneous demands. It is one of the most widely implemented LAN standards.

Ethernet networks provide high-speed data exchange in areas that require economical connection to a local communication medium carrying bursty traffic at high-peak data rates.

A classic Ethernet system consists of a backbone cable and connecting hardware (e.g. transceivers), which links the controllers of the individual stations via transceiver (transmitter-receiver) cables to this backbone cable and thus permits communication between the stations.

2.5.3 10Base-5

The yellow 10Base-5 thick-wire AUI line is the original type of Ethernet cable. The simplest configuration is to connect the AUI connector of each station to this yellow cable using a transceiver line and a transceiver. An Ethernet cable like this must not be longer than 500m, and may have a maximum of 100 transceivers. The distance between two transceivers must be at least 2.5m.

A transceiver contains the transmit and receive logic. It ensures regeneration-free data transfers up to 500m cable length and carries out collision detection and carrier sensing. Another task is electrical isolation between the station and the thick-wire cable. The transceiver is supplied by the station via the transceiver cable. There are also mini-transceivers that can be plugged directly to the AUI connector of the Ethernet device.

The thick-wire cable must be electrically terminated by a 50-Ω termination resistor. The line must only be grounded at one end (not at both).

2.5.4 10Base-2

This Ethernet variety conforms to the 10Base-2 standard and primarily functions like the normal thick-wire Ethernet, but it employs a somewhat thinner, more flexible and less expensive coaxial cable, therefore it is called Cheapernet.

Thin-wire connection has its advantages and disadvantages. Many stations (workstations, terminal servers, PCs) are provided with a direct connection for Cheapernet in addition to the flexible AUI connector. Using this connection, you will save the transceiver cable and transceiver. Stations with an AUI connector can be connected using a transceiver cable and a thin-wire transceiver (often called station adapter). Thin-wire mini-transceivers can be plugged directly to the AUI connector, making a transceiver cable unnecessary.

A drawback of Cheapernet is that the total line length must not exceed 185m and there must not be more than 30 stations (minimum distance between the stations: 0.5m). Another drawback is that the thin-wire line must be separated in order to install a station. The station adapter is connected to the two separated parts of the coaxial cable using a T link. The T link must be plugged directly on the station adapter and may not be extended by means of a coaxial cable. Therefore, the coaxial

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

cable must be led to the station in a loop for stations with an integrated thin-wire adapter. The ends of the thin-wire line must be terminated.

2.5.5 10Base-T

Quelle: http://webopedia.internet.com/TERM/E/Ethernet.html

10Base-T is one of several adaptations of the Ethernet (IEEE 802.3) standard for Local Area Networks (LANs). The 10Base-T standard (also called Twisted Pair Ethernet) uses a twisted-pair cable with maximum lengths of 100 meters. The cable is thinner and more flexible than the coaxial cable used for the 10Base-2 or 10Base-5 standards. Since it is also cheaper, it is the preferable solution for cost-sensitive applications.

Cables in the 10Base-T system connect with RJ45 connectors. A star topology is common with 12 or more computers connected directly to a hub or concentrator.

The 10Base-T system operates at 10Mbps and uses baseband transmission methods.

2.5.6 100Base-T

Quelle: http://webopedia.internet.com/TERM/E/Ethernet.html

The 100Base-T networking standard supports data transfer rates up to 100Mbps. 100Base-T is actually based on the older Ethernet standard. Because it is 10 times faster than Ethernet, it is often referred to as Fast Ethernet. Officially, the 100Base-T standard is IEEE 802.3u.

Like Ethernet, 100Base-T is based on the CSMA/CD LAN access method. There are several different cabling schemes that can be used with 100Base-T, including:

- 100Base-TX: two pairs of high-quality twisted-pair wires
- 100Base-T4: four pairs of normal-quality twisted-pair wires
- 100Base-FX: fiber optic cables

Note: The D2 only supports 100Base-TX. It does not support 100Base-T4 and 100Base-FX.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.6 CompactFlash/SRAM Interface

A PCI PC card controller is used to interface both the CompactFlash disk and 1..4 MB of battery-backed SRAM to the host. The PC card controller is an enhanced version of the industry standard PCIC (Intel 82365SL) and backward-compatible to this device.

2.6.1 CompactFlash Interface


CompactFlash is a standard for small form factor ATA Flash drives. It is electrically compatible to the PC Card 1995 and PC Card ATA standards.

The CompactFlash standard is supported by industry's leading vendors of Flash cards such as SanDisk™, Hitachi, Smart, Panasonic and others.

2.6.1.1 Installing CompactFlash

The D2 is shipped without a CompactFlash card installed. To install CompactFlash, please stick to the following procedure.

Figure 3. *Inserting a CompactFlash Card*



- ☑ Insert the card carefully as indicated by the arrow on top of the card, making sure that all the contacts are aligned properly and the card is firmly in the card socket.
- ☑ Remove the CompactFlash card by pressing the ejector.
- ☑ Observe manufacturer notes on usage of CompactFlash cards.

Note: You do not need to power down the system to change CompactFlash cards. However, make sure that the card's data is not used when you remove the card!

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.6.1.2 Supported CompactFlash Cards

The D2 supports standard CompactFlash cards, e.g. from SanDisk. For CompactFlash cards available from MEN see Chapter Ordering Information on page 7.

2.6.2 Battery-backed SRAM

The D2 supports 1 MB to 4 MB of battery-backed SRAM. The standard model of the D2 features 1 MB of SRAM but may be upgraded to 2 MB and 4 MB. For short power-down intervals, a local GoldCap capacitor supplies the backup voltage.

A central buffer battery bridges longer power-down cycles. This central battery also buffers the real-time clock and CMOS RAM.

The backup voltage is connected via the CT02 transition module. Please refer to the CT02 user manual for connection options.

2.6.3 Booting from CompactFlash/SRAM

When you configure BIOS to boot from PCMCIA, BIOS assigns disk drives to the media in the order that it finds them. This means that BIOS searches for media with a bootable partition. The SRAM is located in socket 0 of the CardBus controller, the CompactFlash in socket 1. When the SRAM is detected as a bootable medium, it is assigned drive name *A:*. If you boot from CompactFlash, this is assigned drive name *C:*.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.7 Super I/O Controller

The Super I/O controller comprises the keyboard/mouse controller, floppy disk controller, two serial ports with 16C550-compatible UARTs, one IEEE1284-compatible parallel port, real-time clock and CMOS RAM. It is compatible with the PC-AT standard.

You can connect a keyboard, mouse (via Y-cable) and COM1 (UART1) directly at the front panel. The parallel port (LPT), COM2 and floppy disk interfaces are available via CompactPCI connector J4 (see Chapter 2.4.2.2 CompactPCI J3/J4/J5 on page 26) or via MEN's CT02, respectively.

2.7.1 COM1 Port

Through BIOS you can select whether you want to use the front-panel RS232 interface or one of MEN's SA adapters with different line drivers via the CT02 transition module (see Chapter 3.2 Special Features Setup on page 48).

Note: COM2 is only wired via CT02 and MEN SA adapter.

Connector types:

- 9-pin D-Sub receptacle according to DIN41652/MIL-C-24308
- mating connector:
  9-pin D-Sub plug according to DIN41652/MIL-C-24308, with thread bolt UNC 4-40, available for ribbon cable (insulation piercing connection), hand-soldering connection or crimp connection

Table 11. *Pin Assignment of the 9-pin D-Sub COM1 Plug Connector*




Table 12. *Signal Mnemonics for Serial Port COM1*

Signal	Direction	Function
CTS	in	clear to send
DCD	in	data carrier detect
DSR	in	data set ready
DTR	out	data terminal ready
GND	-	logic ground
RI	in	ring indicator
RTS	out	request to send
RXD	in	receive data
TXD	out	transmit data

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.7.2 Keyboard/Mouse Interface

A 6-pin mini DIN connector is provided to connect a standard PS/2 keyboard and mouse or other pointing device.


The connector pinout allows you to connect either a standard keyboard or both a keyboard and mouse.

Note: For the connection of both devices a special cable is necessary. MEN offers a Y-cable for easy connection of a keyboard and mouse. For ordering numbers please refer to Chapter Ordering Information on page 7.

Connector types:

- 6-pin circular mini DIN receptacle
- mating connector:
  6-pin circular mini DIN plug, available for soldering and crimp connection

Table 13. *Pin Assignment of the 6-Pin Mini DIN Keyboard/Mouse Connector*



6	MSCLK	5	KBCLOCK
4	+5V	3	GND
2	MSDATA	1	KBDATA

Table 14. *Signal Mnemonics for Keyboard/Mouse Interface*

Signal	Direction	Function
+5V	-	+5V supply, max. DC current 200mA
GND	-	logic ground
KBCLOCK	out	keyboard clock
KBDATA	in/out	keyboard data
MSCLOCK	out	mouse clock
MSDATA	in/out	mouse data

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.7.3 EIDE Interface

The EIDE controller is built into the Southbridge. It supports two EIDE channels (primary and secondary) and ATA-4 (PIO mode 4, DMA mode 2). You can connect hard-disk drives or CD-ROM drives to the two ports.

The maximum data rate is 22MB/s.

Connection of EIDE1 and EIDE2 is via CompactPCI J3/J4 or via MEN's CT02 transition module (see CT02 Transition Module, Chapter 2.4.2.2 CompactPCI J3/J4/J5 on page 26).

2.7.4 USB Interface

The USB controller is also integrated in the Southbridge. It drives one host port according to the USB specification Open HCI 1.0a. The D2 supports three USB interfaces, one of them using GPIO lines 4 and 5 (see Chapter 2.7.5 GPIO Interface on page 39).

You can enable or disable the USB interface in BIOS (see Chapter 3.2 Special Features Setup on page 48).

You can connect USB devices via the CT02 transition module and a MEN SA adapter (in preparation).

2.7.5 GPIO Interface

The F2 supports six GPIO lines, which provide a third USB interface and an infrared serial interface.

Depending on the BIOS setting, you can connect this interface via a 10-pin plug on the CT02 rear I/O adapter (cf. pin assignments in the CT02 user manual and Chapter 2.4.2.2 CompactPCI J3/J4/J5 on page 26).

Table 15. *Correspondence between GPIO and UART3 Pins*

Pin	GPIO Function	UART3 Function
GPIO[0]	GPIO 0	infrared serial interface IRTX line
GPIO[1]	GPIO 1	infrared serial interface IRXH line
GPIO[2]	GPIO 2	infrared serial interface IRRX line
GPIO[3]	GPIO 3	infrared serial interface CVROFF line
GPIO[4]	GPIO 4	third USB port, USBP2+
GPIO[5]	GPIO 5	third USB port, USBP2-
GPIO[6]	reserved	-
GPIO[7]	GPIO 7	-

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.8 PC•MIP Slots

The D2 has three PC•MIP slots: two for Type-I/ Type-II modules (slots A and B) and one for Type-I modules (slot E).

The PC•MIP slots enable the user to add functionality to the D2 CPU board, from graphics to process I/O.

Note: Please note that only PC•MIP slots A and E support rear I/O!

2.8.1 Installing a PC•MIP

Perform the following steps to install a PC•MIP on slot A or B:

- ☑ Power down your system and remove the D2 from the system.
- ☑ If you want to install a Type-II PC•MIP (with front connector), you must remove the blank bezel at the front panel of the D2 first:
  Remove the respective bezel keeper by loosening the keeper screw at the solder side of the D2. (See Figure 1, Map of the Board - Front Panel and Top View, on page 16).
- ☑ Place the finished bezel supplied with your PC•MIP in the front panel cut-out and reinstall the bezel keeper.
- ☑ If you are installing a Type-II PC•MIP, carefully put the module's front connector through the finished bezel, holding the module at a 45° angle.
- ☑ Place the PC•MIP on the target slot of the D2, aligning the three connectors (P1/J1, P2/J2, P3/J3) and the two standoffs.
- ☑ Screw the PC•MIP to the carrier by **alternately** tightening the two captive screws on the label side of the PC•MIP. The module will be "injected" safely.


If you want to install a PC•MIP on slot E, the procedure is easier:

- ☑ Place the PC•MIP on the target slot of the D2, aligning the three connectors (P1/J1, P2/J2, P3/J3) and the two standoffs.
- ☑ Screw the PC•MIP to the carrier by **alternately** tightening the two captive screws on the label side of the PC•MIP. The module will be "injected" safely.

Note: It is possible to plug Type-I modules on Type-II slots. However, you cannot do this vice versa, since the front connectors of Type-II modules would collide with the enclosure.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Figure 4. *Installation of a PC•MIP (example for slot A or B)*



To deinstall PC•MIPs from the carrier board, just loosen the appropriate screws at the label side of the PC•MIP. The injector/ejector system will "eject" the PC•MIP.

2.8.2 PC•MIP Connectors

PC•MIP modules connect to the D2's PCI bus via the two identical 64-pin connectors P1 and P2. The connector layout is fully compatible to the PC•MIP specification and will not be repeated here.

Connector P3 leads PC•MIP signals to rear I/O, see Chapter 2.8.3 Signal Mapping from PC•MIP Connector to Rear I/O on page 41.

Connector types of P1, P2 and P3:

- 64-pin plug connector according to IEEE P1386, e.g. Molex 71436-0164
- mating connector:
  64-pin receptacle connector according to IEEE P1386, e.g. Molex 71439-0164


2.8.3 Signal Mapping from PC•MIP Connector to Rear I/O

The signal assignment of 64-pin connector P3 depends on the PC•MIP module used. The following table gives only the mapping of I/O signals from PC•MIP connector J3/P3 to rear I/O connectors.

Note: You will find special mapping tables for the standard 50-pin and 68-pin connectors on transition modules in the respective MEN PC•MIP user manual.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Table 16. *Signal Mapping from PC•MIP J3/P3 to Rear I/O*



	2	MIP_IO[2]	1	MIP_IO[1]
	4	MIP_IO[4]	3	MIP_IO[3]
	6	MIP_IO[5]	5	GND
	8	MIP_IO[7]	7	MIP_IO[6]
	10	GND	9	MIP_IO[8]
	12	MIP_IO[10]	11	MIP_IO[9]
	14	MIP_IO[11]	13	GND
	16	MIP_IO[13]	15	MIP_IO[12]
	18	GND	17	MIP_IO[14]
	20	MIP_IO[16]	19	MIP_IO[15]
	22	MIP_IO[17]	21	GND
	24	MIP_IO[19]	23	MIP_IO[18]
	26	GND	25	MIP_IO[20]
	28	MIP_IO[22]	27	MIP_IO[21]
	30	MIP_IO[23]	29	GND
	32	MIP_IO[25]	31	MIP_IO[24]
	34	GND	33	MIP_IO[26]
	36	MIP_IO[28]	35	MIP_IO[27]
	38	MIP_IO[29]	37	GND
	40	MIP_IO[31]	39	MIP_IO[30]
	42	GND	41	MIP_IO[32]
	44	MIP_IO[34]	43	MIP_IO[33]
	46	MIP_IO[35]	45	GND
	48	MIP_IO[37]	47	MIP_IO[36]
	50	GND	49	MIP_IO[38]
	52	MIP_IO[40]	51	MIP_IO[39]
	54	MIP_IO[41]	53	GND
	56	MIP_IO[43]	55	MIP_IO[42]
	58	GND	57	MIP_IO[44]
	60	MIP_IO[46]	59	MIP_IO[45]
	62	MIP_IO[48]	61	MIP_IO[47]
	64	MIP_IO[50]	63	MIP_IO[49]


Note: The GND pins of the J3/P3 connector are not mapped.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.9 Front LEDs and Reset Button

The D2 has nine front panel LEDs and a reset button. The reset button is controlled by the BIOS. It can be enabled or disabled in the BIOS setup.

Figure 5. *Front Panel LEDs and Reset Button*



The USER LEDs can be programmed by software as needed.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.10 System Trigger, Watchdog and Hardware Monitor

The D2 uses a Z8536 component as a system trigger, watchdog and hardware monitor. The ports of the Z8536 are assigned as follows:

Table 17. *Port Pin Assignment of the Z8536 CIO*

Port Pin	Signal Name	Direction	Description
PA0	WD_TRIG	out	watchdog
PA1	-	-	-
PA2	-	-	-
PA3	-	-	-
PA4	SCL	in	I^2C bus SCL in - hardware monitor
PA5	SCL	out	I^2C bus SCL out - hardware monitor
PA6	SDA	in	I^2C bus SDA in - hardware monitor
PA7	SDA	out	I^2C bus SDA out - hardware monitor
PB0	PXI_TRIG[3]	out	PXI trigger PXI_TRIG[3] out
PB1		out	PXI trigger PXI_TRIG[3] out enable (0 = enable, 1 = disable)
PB2		out	PXI trigger PXI_TRIG[4] out enable (0 = enable, 1 = disable)
PB3		out	PXI trigger PXI_TRIG[2] out enable (0 = enable, 1 = disable)
PB4	PXI_TRIG[4]	out	PXI trigger PXI_TRIG[4] out
PB5		out	PXI trigger PXI_TRIG[0] out enable (0 = enable, 1 = disable)
PB6	PXI_TRIG[0]	in	PXI trigger PXI_TRIG[0] in
PB7	PXI_TRIG[1]	in	PXI trigger PXI_TRIG[1] in
PC0	PXI_TRIG[2]	out	PXI trigger PXI_TRIG[2] out
PC1	PXI_TRIG[0]	out	PXI trigger PXI_TRIG[0] out
PC2	PXI_TRIG[1]	out	PXI trigger PXI_TRIG[1] out
PC3		out	PXI trigger PXI_TRIG[1] out enable (0 = enable, 1 = disable)

System Trigger

The system trigger supports trigger lines PXI_TRIG[4:0] according to the PXI specification 1.0 (see Chapter 5.1 Literature and WWW Resources on page 54).

The maximum trigger frequency is 1MHz.

Watchdog

You can enable or disable the watchdog. If the watchdog is not retriggered within a 4.2-second interval, the platform will be hard-reset.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Hardware Monitor

The hardware monitor watches

- all voltages: +5V, +3.3V, +12V, -12V, switched mode power supply for processor core, buffer battery.
  The monitor will generate an alarm if the threshold values are exceeded.
- the speed of the processor fan
- the temperature on the board
- the power supply: support of PS_FAIL# and PS_DEG# according to the CompactPCI specification.
  - PS_DEG# can be sampled via the LM79 (BTI).
  - PS_FAIL# causes a reset.



MEN provides driver software for the hardware monitor of the D2, which allows you to generate an alarm signal if the threshold values are exceeded. For current software support, please refer to our website: www.men.de.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3 Award BIOS

The following chapter gives a rough overview of the Award BIOS Setup program. The Setup program lets you modify basic system configuration settings. The settings are then stored in a dedicated battery-backed memory, called CMOS RAM, that retains the information when the power is turned off.

The D2's Award BIOS is a customized version of an industry-standard BIOS for IBM PC AT-compatible personal computers. It provides critical low-level support for the system central processing, memory, and I/O subsystems.

The Award BIOS has been customized by adding important, but nonstandard, features such as virus and password protection, power management, and detailed fine-tuning of the chipset controlling the system.

For D2, the BIOS was further enhanced by special, hardware-dependent, functions.




For a detailed description of the standard functions of the Award BIOS please refer to their website: www.award.com. This chapter will give details only on the special D2 functions.

3.1 Main Setup Menu

When you enter the Award BIOS CMOS Setup Utility by pressing DEL at start-up, a Main Menu appears on the screen. The Main Menu allows you to select from several Setup functions and two exit choices. Use the arrow keys to select among the items and press Enter to accept and enter the sub-menu.

Figure 6. *BIOS CMOS Setup Utility - Main Menu*



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

The following is a brief summary of each Setup category.

Standard CMOS Setup
Options in the original PC AT-compatible BIOS.

BIOS Features Setup
Award enhanced BIOS options.

Chipset Features Setup
Options specific to your system chipset.

Power Management Setup
Advanced Power Management (APM) options.

PnP/PCI Configuration
Plug and Play standard and PCI Local Bus configuration options.

Load BIOS Defaults
BIOS defaults are factory settings for the most stable, minimal-performance system operations.

Load Setup Defaults
Setup defaults are factory settings for optimal-performance system operations.

Integrated Peripherals
I/O subsystems that depend on the integrated peripherals controller in your system.

Special Features Setup
Hardware-dependent settings for D2 (see Chapter 3.2 Special Features Setup on page 48).

Password Setting
Change, set, or disable a password. In BIOS versions that allow separate user and supervisor passwords, only the supervisor password permits access to Setup. The user password generally allows only power-on access.

IDE HDD Auto Detection
Automatically detect IDE hard disk parameters.

Save & Exit Setup
Save settings in nonvolatile CMOS RAM and exit Setup.

Exit Without Saving
Abandon all changes and exit Setup.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3.2 Special Features Setup

This section describes the hardware-specific BIOS settings of the D2 such as UART1 (COM1), GPIO and reset button modes.

UART1 High Speed Mode

This option selects the baud rate mode for UART1 (COM1).

On	high-speed baud rates up to 460,800 baud
Off	standard baud rates up to 115,200 baud

UART1 Transceiver

This option defines if UART1 (COM1) is used at the front panel or via the rear I/O transition module (CT02).

Internal	UART1 at front panel
External	UART1 at CompactPCI rear I/O transition module

UART3/GPIO 0-3 Select

IR-UART3 is not supported on the D2. The pins are used for general purpose I/O at the rear I/O transition module (CT02) via the CompactPCI bus.

Input	GPIO pin is configured as input
Output	GPIO pin is configured as output

USB/GPIO 4-5 Select

This option allows you to select between a third USB port and general purpose I/O GPIO 4..5 for use at the rear I/O transition module (CT02).

GPIO	GPIO is enabled
	Input GPIO pin is configured as input
	Output GPIO pin is configured as output
3rd USB	3rd USB is enabled

Reset Button

Enabled	the reset button at the front is enabled
Disabled	the reset button at the front is disabled

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3.3 Console Redirection



The D2's Award BIOS features "console redirection", allowing you to supervise and influence the boot procedure of the D2 using a terminal, similar to a monitor. To do this, you can use software such as HyperTerm under Windows, or Award's APM software (Award Preboot Manager). See also www.award.com.

3.3.1 Configuring BIOS

As of revision 00.02, BIOS is preconfigured for the system to boot both with or without a graphics card, so that you do not need to configure BIOS to perform console redirection.

Without a graphics card, the boot process is performed up to the BIOS setup, where you can make changes using a terminal.

This mechanism is controlled via the "Award Preboot Agent" and "Agent after boot" accessible in the BIOS Features Setup.

Award Preboot Agent

Enabled	if a terminal is connected, the agent redirects to this console while the system is booting (default)
Disabled	no redirection

Agent after boot

Enabled	if a terminal is connected, the agent redirects to this console after the system has booted
Disabled	no redirection (default)

Options "Serial Port" (terminal connection) and "Use Host Drive A" (used by APM software) should not be changed. The default configuration ensures that the system can be booted both with or without a graphics card and that you can make necessary settings in BIOS in any event.

If you do not need the Preboot Agent at all, you should disable it.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3.3.2 Configuring a Terminal Cable

For connection of the D2 to a terminal using a serial cable, we recommend the following pin assignment (compatible with APM software):

Table 18. *Pin Assignment for Terminal Cable*

D2 Side		Terminal/PC Side	
1	DCD	4	DTR
2	RXD	3	TXD
3	TXD	2	RXD
4	DTR	1	DCD
5	GND	5	GND
6	DSR	-	
7	RTS	8	CTS
8	CTS	7	RTS
9	RI	-	

3.3.3 Configuring the Terminal

Set your terminal to the following values:

- 19200 baud
- 8 data bits
- no parity
- 1 stop bit
- Xon/Xoff protocol

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3.4 BIOS Restrictions

BIOS Version 00.00 to 00.03

- If the Preboot Agent is enabled, you must permanently allocate the serial interfaces, e. g. COM 1 to 3F8 IRQ 4 and COM2 to 2F8 IRQ3.
- The D2's PCI-to-PCI bridge is not initialized properly when there are additional cards in the system that have a large I/O space (e. g. CompactPCI boards or PC•MIP mezzanines). As of version 00.03, VGA BIOS may be 64KB large.

BIOS Version < 00.03

- BIOS displays a CPU host clock of 83 MHz/ASyn in the Chipset Features Setup. This entry is correct! The D2 is operated with an FSB of 83MHz and a multiplier of 5.5. These values cannot be changed. They depend on the processor and are permanently wired.

3.5 BIOS Troubleshooting

In case you have any problems with start-up of the D2, e.g. after a BIOS update, you can start the board with BIOS default values. This will allow you to start up the board and check your BIOS settings.

This is how it works:

☑ Press the "Insert" key on your keyboard before power-up.

☑ Power up the system with the "Insert" key pressed.

☑ Release the "Insert" key when the D2 has beeped.

Now the D2 is run with the BIOS default values. Although these values are used, **they do not overwrite your BIOS settings**.

☑ You can now check, modify and store your BIOS settings as usual.

☑ To activate your new BIOS configuration, reset the D2.

If your problems persist, please turn to our customer support: support@men.de.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4 Organization of the Board

The D2 is backward-compatible to the PC-AT. It provides the standard periphery found on today's personal computers. All addresses and other resources (i.e. interrupts and DMA channels) used by these standard components are compatible to the IBM PC. For a description of these components please refer to the IBM AT technical reference (see Chapter 5.1 Literature and WWW Resources on page 54) or other literature.

You can use the BIOS services to locate devices on the D2 and allocate and deallocate hardware resources for them (see Chapter 3 Award BIOS on page 46).

4.1 Local PCI Bus

Several devices reside on the local PCI bus:

- host-to-PCI bridge ("Northbridge")
- PCI-to-ISA bridge ("Southbridge")
- PCI-to-PCI bridge which couples the local PCI bus and the CompactPCI back-plane
- Fast Ethernet controller
- PCMCIA controller
- PC•MIP slots

4.1.1 Device Numbers

The following list contains the device numbers for the local PCI bus of the D2. The Vendor and Device IDs for each device are given for reference only. Note that the Southbridge is a multifunction device and has unique Device IDs for each function.

Table 19. *Device Numbers on Local PCI Bus*

Device No.	Device	Vendor/Device ID
0x00	Northbridge	
0x07	Southbridge	8086/7000 (function 0) 8086/7010 (function 1) 8086/7020 (function 2)
0x14	PCI-to-PCI bridge	1011/0022
0x11	Ethernet controller	1011/0014
0x10	PCMCIA controller	104c/ac15
0x13	PC•MIP slot	defined by module used

4.1.2 Interrupt Routing

Interrupt routing conforms to the recommendations of the PCI specification, rev. 2.1 (see Chapter 5.1 Literature and WWW Resources on page 54).

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4.2 CompactPCI Bus

4.2.1 Device Numbers

The system slot on a CompactPCI backplane is labeled as slot number 1. The peripheral slots are numbered 2..8 starting from the slot next to the system slot towards the slot opposite the system slot.

Peripheral CompactPCI boards plugged into these slots appear as devices on **PCI bus number 1**. The mapping is listed below.

Table 20. *Device Numbers on CompactPCI Backplane*

Device Number	Slot Number
0x0F	2
0x0E	3
0x0D	4
0x0C	5
0x0B	6
0x0A	7
0x09	8

4.2.2 Interrupt Routing and Buffering

Interrupts are routed on the backplane. The CompactPCI interrupts are connected to the local PCI bus interrupts by an open drain buffer to increase signal integrity.

4.3 ISA Bus

All standard components are compatible with the PC-AT standard. Non-standard components are connected to the ISA bus via the ISA Plug and Play controller. The Plug and Play ID is "SEN 0010".

When booting, the Plug and Play controller comes up with device name "*MEN CompactPCI Workstation D002 Rxx*", where *Rxx* is the revision of the D2's Plug and Play controller.

The interface to the system trigger, watchdog and hardware monitor as well as the CAN bus interface are implemented via the Plug and Play controller.

The resources needed are all allocated via Plug and Play BIOS.

Table 21. *ISA Bus Plug and Play Device IDs*

Device ID	Device	Resources needed
SEN 0010	monitor interface	one 8-byte I/O window one 4-byte I/O window one interrupt

Hardware of the monitor unit is based on the LM79 and CIO Z8536 devices. The two components share one interrupt.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

5 Appendix



5.1 Literature and WWW Resources

5.1.1 CompactPCI/PCI

- CompactPCI Specification Revision 2.0 R2.1:
  1997; PCI Industrial Computers Manufacturers Group (PICMG)
  www.picmg.org
- PCI Local Bus Specification Revision 2.1:
  1995; PCI Special Interest Group
  P.O. Box 14070
  Portland, OR 97214, USA
  www.pcisig.com

5.1.2 PXI

- PXI Specification, PCI eXtensions for Instrumentation, An Implementation of CompactPCI, Revision 1.0; 1997; National Instruments, Inc.
  www.natinst.com

5.1.3 PC•MIP

- PC•MIP Draft Standard:
  draft standard ANSI/VITA 29;
  VMEbus International Trade Association
  7825 E. Gelding Dr., Ste. 104,
  Scottsdale, AZ 85260
  www.vita.com

  You can download the latest draft specification also from MEN's website:
  www.men.de.

5.1.4 EIDE

- EIDE:
  Information Technology - AT Attachment-3 Interface (ATA-3), Revision 6, working draft; 1995; Accredited Standards Committee X3T10

5.1.5 Parallel Peripherals - EPP

- Parallel Port (EPP):
  1284-1994 IEEE Standard Signaling Method for a Bidirectional Parallel Peripheral Interface for Personal Computers; 1994; IEEE
  www.ieee.org

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

5.1.6 Ethernet

- Ethernet controller DS21041:
  Digital Semiconductor 21041 PCI Ethernet LAN Controller, Data Sheet; 1996; Digital Equipment Corporation
  www.digital.com
- Ethernet in general:
  - The Ethernet, A Local Area Network, Data Link Layer and Physical Layer Specifications, Version 2.0; 1982; Digital Equipment Corporation, Intel Corp., Xerox Corp.
  - ANSI/IEEE 802.3-1996, Information Technology - Telecommunications and Information Exchange between Systems - Local and Metropolitan Area Networks - Specific Requirements - Part 3: Carrier Sense Multiple Access with Collision Detection (CSMA/CD) Access Method and Physical Layer Specifications; 1996; IEEE
    www.ieee.org
- www.ots.utexas.edu/ethernet/descript-100quickref.html
  links to documents describing Ethernet, components, media, the Auto-Negotiation system, multi-segment configuration guidelines, and information on the Ethernet Configuration Guidelines book
- www.iol.unh.edu/training/ethernet.html
  collection of links to Ethernet information, including tutorials, FAQs, and guides
- www.made-it.com/CKP/ieee8023.html
  Connectivity Knowledge Platform at Made IT technology information service, with lots of general information on Ethernet
- www.yahoo.com/Computers_and_Internet/Communications_and_Networking/LANs/Ethernet/
  Yahoo!'s Ethernet directory

5.1.7 USB

- USB:
  Universal Serial Bus Specification Revision 1.0; 1996; Compaq, Digital Equipment Corporation, IBM PC Company, Intel, Microsoft, NEC, Northern Telecom
  www.usb.org

5.2 Board Revisions


Table 22. *Table of Hardware Revisions*

Revision	Comment	Restrictions
00.xx	first revision released	none known
01.xx	second revision	The ISA/PNP Controller still displays hardware revision 00. This is a MEN error. See Chapter 4.3 ISA Bus on page 53.
02.xx	third revision	none known

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com


5.3 Component Plans

Figure 7. *Component Plan of D2 Rev. 02 - Top Side*



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Figure 8. *Component Plan of D2 Rev. 02 - Bottom Side*



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

You can request the circuit diagrams for the current revision of the product described in this manual by completely filling out and signing the following non-disclosure agreement.

Please send the agreement to MEN by mail. We will send you the circuit diagrams along with a copy of the completely signed agreement by return mail.

MEN reserves the right to refuse sending of confidential information for any reason that MEN may consider substantial.

Non-Disclosure Agreement

for Circuit Diagrams provided by MEN Mikro Elektronik GmbH

between

MEN Mikro Elektronik GmbH
Neuwieder Straße 7
D-90411 Nürnberg

("**MEN**")

and

_____
_____
_____
_____

("**Recipient**")

We confirm the following Agreement:

MEN		**Recipient**	
Date:	_____	Date:	_____
Name:	_____	Name:	_____
Function:	_____	Function:	_____
Signature:		Signature:	
_____		_____	

The following Agreement is valid as of the date of MEN's signature.

mikro elektronik
gmbh • nürnberg

Neuwieder Straße 7
D-90411 Nürnberg
Phone +49-911-99 33 5-0
Fax +49-911-99 33 5-99
E-Mail info@men.de
WWW www.men.de

ISO 9001 certified

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

1 Subject

The subject of this Agreement is to protect all information contained in the circuit diagrams of the following product:

Article Number:_____ [filled out by recipient]

MEN provides the recipient with the circuit diagrams requested through this Agreement only for information.

2 Responsibilities of MEN

Information in the circuit diagrams has been carefully checked and is believed to be accurate as of the date of release; however, no responsibility is assumed for inaccuracies. MEN will not be liable for any consequential or incidental damages arising from reliance on the accuracy of the circuit diagrams. The information contained therein is subject to change without notice.

3 Responsibilities of Recipient

The recipient, obtaining confidential information from MEN because of this Agreement, is obliged to protect this information.

The recipient will not pass on the circuit diagrams or parts thereof to third parties, neither to individuals nor to companies or other organizations, without the written permission by MEN. The circuit diagrams may only be passed to employees who need to know their content. The recipient protects the confidential information obtained through the circuit diagrams in the same way as he protects his own confidential information of the same kind.

4 Violation of Agreement

The recipient is liable for any damage arising from violation of one or several sections of this Agreement. MEN has a right to claim damages amounting to the damage caused, at least to DM 100,000.

5 Other Agreements

MEN reserves the right to pass on its circuit diagrams to other business relations to the extent permitted by the Agreement.

Neither MEN nor the recipient acquire licenses for the right of intellectual possession of the other party because of this Agreement.

This Agreement does not result in any obligation of the parties to purchase services or products from the other party.

6 Validity of Agreement

The period after which MEN agrees not to assert claims against the recipient with respect to the confidential information disclosed under this Agreement shall be _____ months [filled out by MEN]. (Not less than twenty-four (24) nor more than sixty (60) months.)

7 General

If any provision of this Agreement is held to be invalid, such decision shall not affect the validity of the remaining provisions and such provision shall be reformed to and only to the extent necessary to make it effective and legal.

This Agreement is only effective if signed by both parties.

Amendments to this Agreement can be adopted only in writing. There are no supplementary oral agreements.

This Agreement shall be governed by German Law.

The court of jurisdiction shall be Nuremberg.

mikro elektronik
gmbh • nürnberg

Neuwieder Straße 7
D-90411 Nürnberg
Phone +49-911-99 33 5-0
Fax +49-911-99 33 5-99
E-Mail info@men.de
WWW www.men.de

ISO 9001 certified

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Fax Reply

mikro elektronik
gmbh • nürnberg

Who you are...

Name _____ **Phone No.** _____

Company _____ **Fax No.** _____

Department _____ **E-mail** _____

What we can do for you...

Product Support

Product Article No. _____

Revision __ __ . __ __ . __ __

If the product is a mezzanine module:

Carrier Article No. _____

Revision __ __ . __ __ . __ __

Operating system

- ❍ OS-9
- ❍ VxWorks
- ❍ WindowsNT
- ❍ other: _____

Manual Feedback

Manual Article No. _____

Edition E ___

Useful or awful?

very useful ❍ ❍ ❍ ❍ ❍ totally awful

Usage

- ❑ I read the manual and decided to buy the related product.
- ❑ I read the manual when I got the product.
- ❑ I refer to the manual only when I have problems.

Your problems/comments...

Use our online forms at www.men.de

- Technical Support
- User Manuals

Neuwieder Straße 7
D-90411 Nürnberg
Phone +49-911-99 33 5-0
Fax +49-911-99 33 5-99
E-Mail info@men.de
WWW www.men.de

ISO 9001 certified

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group is an independent supplier of quality pre-owned equipment

Gold-standard solutions

Extend the life of your critical industrial, commercial, and military systems with our superior service and support.

We buy equipment

Planning to upgrade your current equipment? Have surplus equipment taking up shelf space? We'll give it a new home.

Learn more!

Visit us at **artisantg.com** for more info on price quotes, drivers, technical specifications, manuals, and documentation.

Artisan Scientific Corporation dba Artisan Technology Group is not an affiliate, representative, or authorized distributor for any manufacturer listed herein.

We're here to make your life easier. How can we help you today?

(217) 352-9330 | sales@artisantg.com | artisantg.com

ARTISAN® TECHNOLOGY GROUP