

ARTISAN®
TECHNOLOGY GROUP

Your **definitive** source for quality pre-owned equipment.

Artisan Technology Group
(217) 352-9330 | sales@artisantg.com | artisantg.com

Full-service, independent repair center
with experienced engineers and technicians on staff.

We buy your excess, underutilized, and idle equipment
along with credit for buybacks and trade-ins.

Custom engineering
so your equipment works exactly as you specify.

- Critical and expedited services
- In stock / Ready-to-ship
- Leasing / Rentals / Demos
- ITAR-certified secure asset solutions

Expert team | Trust guarantee | 100% satisfaction

All trademarks, brand names, and brands appearing herein are the property of their respective owners.

Find the *NH Research 14-0847A-00* at our website: *Click HERE*

VXI LOAD OPERATIONS

MODELS 81201 & 81210

USER'S MANUAL



Part No. 09-0129

REVISION C

March 31, 1998

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Document History

Rev C	**ECO 14612**	**3/31/98**	**B. H.**

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Proprietary Rights Notice

This document and the information that it contains are the property of NH Research, Incorporated. The rights to duplicate or otherwise copy this document, the rights to disclose the document and its information to others, and the right to use the information therein may be acquired only by written permission signed by a duly authorized officer of NH Research, Incorporated.

Unauthorized duplication of software and documentation provided with the test workstations violates the copyright protection provided by law. However, backup copies of programs are permitted for archives and recovery from hardware failures.

The material in this publication is current as of the release date on the cover page and is subject to change without notice. Any questions concerning the product or any questions or comments concerning this manual should be directed to the NH Research Field Service Department during normal business hours Monday through Friday at (949) 474-3900 or FAX (949) 474-7062 or www.nhresearch.com.

POWERTEST and POWERFLEX are trademarks of NH Research, Incorporated.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

TABLE OF CONTENTS

1. INTRODUCTION 7

2. OPERATIONAL THEORY 9
2.1 PROTECTION 9

3. VXI LOAD PROGRAMMING SPECIFICATIONS 11
3.1 GENERAL PROGRAMMING STRUCTURE 13
3.2 READING THE EEPROM 13

4. OPERATING COMMANDS 15
4.1 LOAD RESET 15
4.2 SET LOAD CURRENT 15
4.3 SET THE LOAD VOLTAGE 15
4.4 SET THE LOAD OPERATING MODE 16
4.5 MISCELLANEOUS FUNCTIONS 16

5. READING AND METERING 19
5.1 READING LOAD STATUS 19
5.2 READING THE ANALOG TO DIGITAL CONVERTER (ADC) 19
5.3 METERING 20

6. CALIBRATION 21

APPENDIX A 23
SPECIFICATIONS AND PANEL CONNECTIONS 23

APPENDIX B 27
EEPROM TIMING DIAGRAMS 27

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

1. INTRODUCTION

VXIbus electronic loads are designed for low-power output loading of DC power supplies or other devices needing loads with either static or dynamic modes of operation. Each load is a self-contained instrument on a single-slot, C-size VXlbus module making them ideal for applications where size is important. The 81201 and 81210 can be integrated into any VXlbus-based test system, but they are particularly well-suited to the POWERTEST family of automatic power supply test systems from NH Research.

Although rated at 50 Watts continuous power, the 81201 and 81210 can be used at considerably higher ratings. As most testing is carried out at substantially lower duty cycles, analog control circuitry is used to continuously monitor internal conditions permitting the load to increase its power handling capability with decreasing duty cycles. Because the monitoring is carried out in real time, the protection circuitry is tripped only if the load is in danger of being damaged. This allows testing for short periods or small duty cycles at power levels in excess of the steady state specifications If higher power is continuously required, two or more loads may be operated in parallel.

The 81201 and 81210 offer programmable transient response. Programmable rise times permit the dynamic characteristics of the load to more closely approximate the operational conditions in which the unit under test (UUT) will be expected to function. In applications requiring testing under complex loading profiles, an analog input is provided which allows external control of the load current over the load's full operating ranges. Using an arbitrary waveform generator, virtually any required loading profile can be realized.

Frequently, switching power supplies must be turned on into a constant resistance load before testing with a constant current load can begin. The 81201 and 81210 provide a glitch-free transition from one mode to another; the supply under test does not see the load current fall to zero during the mode transition. In the short circuit mode of operation, an SCR in parallel with the shorting relay is used to give fast, low resistance short. It is possible to shift from any mode to any other mode of operation under program control.

The loads are fully protected against various fault conditions including overvoltage, reverse voltage, overcurrent, overpower and overtemperature. All calibration and configuration data is stored in an on-board EEPROM, resulting in fast, internal “no pots" calibration of setting and metering parameters. The result is a rugged, highly reliable load that requires minimal maintenance.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2. OPERATIONAL THEORY

The VXlbus loads use power MOSFETs for the current sinking devices. The control circuits are practically identical for both the 81201 and the 81210 loads. A few resistors and a capacitor in the feedback are the differences (see page 3 of drawing 10-3860). A control voltage is routed to the inverting input of an op-amp U9. The voltage developed across the precision shunt is scaled and routed back into the op-amp. This op-amp drives the gate of the MOSFET and will slew controlling the current until the error goes to zero.

The control voltage is programmed by the use of a 12 bit DAC U18. The stable voltage reference for the DAC comes from U13. The DAC reference can come from 2 places, one is the fixed reference, the other is derived from the constant resistance DAC U19. The UUT voltage sensed by op-amp U1 is scaled such that full scale voltage represents 3.75 VDC. This voltage representing the UUT voltage is scaled for any nominal operating voltage selected by DAC U19. Voltage references of both DAC U19 (Constant Resistance) and DAC U18 (Constant Current) can be controlled by op-amp U1. This method of controlling the reference allows the current of the load to be proportional to the UUT voltage (i.e. constant resistance mode). Analog switch U16 controls the selection of references and the mode of operation, Constant Resistance, or Constant Current. U16 also controls slew rates by selecting between RC timing networks.

2.1 Protection

Temperature is sensed on the load heat sink by a temperature transducer. The output is scaled by op-amp U15 and is compared to a stabilized reference. The output of the transducer is also scaled by op-amp U8 and summed along with power multiplier U7. Both outputs of the op-amps are ORed through diodes CR8 and CR9. If power is exceeded or the temperature should rise above the preset value the load will be shut down and a status bit will be available to the controller.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3. VXI LOAD PROGRAMMING SPECIFICATIONS

In general all addresses are offset values from the base load logical address as set be the DIP switch, SW1.

SW1: open = 1, closed = 0

NUMBER	ADDRESS
1	A7
2	A6
3	A5
4	A4
5	A3
6	A2
7	A1
8	A0

For example, the logical address switch setting for 25(decimal) would look like:

1	2	3	4	5	6	7	8	
			X	X			X	open
X	X	X			X	X		closed

The remaining addresses listed are OFFSET values from the base address. Also, addresses are HEX values, unless specified explicitly.

There are four (4) types of VXI load registers that begin at this Base address. Al1 addresses are 16 bits.

REGISTER	OFFSET	BIT DEFINITION	
ID (read)	00	B0 - B11	: Manufacture ID
		B12 - B13	: 00 (address space = A16/24)
		B14 - B15	: 11 (register based)
DEV-TYPE (read)	02	B0 - B11	: Model Code
		B12 - B15	: 1110 (required memory)
STATUS (read)	04	B2	: 1 (self test passed)
		B3	: 1 (self test extended)
		B14	: MODID* self test extended
		B15	: A24 active
(write)		B0	: Reset
		B1	: Sysfail Inhibit - other bits not used
		B15	: A24 Enable

All device dependent registers begin at address 20 (HEX). There are 5 device write registers and 3 device read registers.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

READ

ADDRESSES	OFFSET	BIT DEFINITION	
Load Byte	20	B0	EEPROM DATA IN/OUT (SERIAL)
		B1	SHORT CIRCUIT (also after an Over Voltage)
		B2	Power Limit (1=good, 0=bad)
		B3	ADC STATUS(1=Converting, 0=done)
		B4	OVER TEMPERATURE
		B5 - B7	0
Load Byte	24	B0 - B7	ADC Lower 8 bits
Load Byte	26	B0 - B3	ADC Upper 4 bits
		B4	ADC Overrange
		B5	ADC Polarity

WRITE

ADDRESSES	OFFSET	BIT DEFINITION	
Load Byte	20	B0	EEPROM CHIP SELECT
		B1	EEPROM SERIAL CLOCK
		B2	EEPROM DATA INPUT
		B3	SHORT CIRCUIT ON
		B4	ADC RUN
		B5	
		B6	OV RESET (also clears short circuit)
		B7	
Load Byte	22	B0 - B3	Current DAC LSB's
		B4 - B7	Voltage Scaling DAC LSB's
Load Byte	24	B0 - B7	Current DAC MSB's (also loads LSB's)
Load Byte (also all	26	B0 - B7	Voltage Scaling DAC MSB's loads LSB's, Current and Voltage)
Analog Switches	28	B0 - B1	Mode Control (10=Constant Resistance, 01 =Constant Current)
		B2 - B3	Slew Rate Control (10=slow, 01=medium, 11=high)
		B4	not used
		B5	Current Metering
		B6	Voltage Metering
		B7	Temperature Metering

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3.1 General Programming Structure

Typical operation of a load is described below. This assumes the resource manager (RM) of the system has recognized the Load. The load supports VXI MODID device recognition.

1. Configure
   A. Read EEPROM data to determine the calibration data offset and gain factors for the various functions.
   B. Save this data in memory.
2. Reset load to desired start conditions
   A. Registers for addresses 20, 22 and 28 should be saved. They will be referred to as DATA 20, DATA 22, and DATA 28. These variables will contain the last data written to these addresses.

3.2 Reading The EEPROM

Calibration data is stored in a the EEPROM serially. Following is a description of each of the calibration words. All values are signed integers.

Word 1	EEPROM	data valid = 1	address 0
Word 2	IADC	gain	address 1
Word 3	IADC	offset	address 2
Word 4	VADC	gain	address 3
Word 5	VADC	offset	address 4
Word 6	IDAC	gain	address 5
Word 7	IDAC	offset	address 6

Data is read by setting EEPROM-Chip Select (CS) high, then serially shifting the address data into the EEPROM via EEPROM-Data Input (Dl) and EEPROM-Serial Clock (SK).

The operation code for read is 110 followed by a 6 bit address value in the form: A5, A4, A3, A2, A1, A0. The 16 bit data value for the desired address is then read from the EEPROM-Data Out (DO) line in the format: 0, D15, D14,. . . D2, D1, D0. Note that the first bit read is always 0, and should be discarded. All input/output data is valid on the low-to-high transition of EEPROM-SK.

For example, to read the IDAC gain:
This example we would like to read word 7, or address 6 of the EEPROM. From the device dependent register list we see that EEPROM-Chip Select (CS) is Bit 0 or B0. Also EEPROM-Serial Clock (SK) is B1 and EEPROM-Data Input (Dl) is B2.

All of these are at Base Address (+) Offset 20.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

	B2	B1	B0	
Write to address 20 - data = 1	0	0	1	an instruction pending
Write to address 20 - data = 3	0	1	1	clock in pending instruction
Write to address 20 - data = 5	1	0	1	clock low, first bit of read op-code (110)
Write to address 20 - data = 7	1	1	1	clock in read command
Write to address 20 - data = 5	1	0	1	clock low, second bit of read op-code (110)
Write to address 20 - data = 7	1	1	1	clock in, second bit of read op-code
Write to address 20 - data = 1	0	0	1	clock low, last bit of read op-code (110).
Write to address 20 - data = 3	0	1	1	clock in, last bit of read op-code.

The EEPROM now needs the Address. Address 6 = 0 0 0 1 1 0.
For each 0, write 1, followed by 3.
For each 1, write 5, followed by 7.

Now that the command and address have been set, reading address 20 should have B0 and B1 both 0 (zero). This is the data start bit, and should be discarded.

For each bit of data: Write a 1, followed by a 3 (clock low to high) and then read the data bit on the EEPROM Data Output (DO) line. This must be done 16 times in order to read the entire 16 bit value. Please see timing diagram in appendix B.

Offset and Gain are divided by 10000 (decimal) to convert from integer to floating point values.

Set Current offset:	IDAC OFFSET/10000
Set Current gain:	IDAC GAIN/10000
Read Current Offset:	IADC OFFSET/10000
Read Current Gain:	IADC GAIN/10000
Read Voltage Offset:	VADC OFFSET/10000
Read Voltage Gain:	VADC GAIN/10000

Note: Some offset factors may be large (i.e., in the 65000 range). These are actually small negative number because the MSB (sign bit) implies an negative value.

The EEPROM should only be read once. The gain and offset factors saved in memory for later usage. These numbers must be stored in standard 8088 16 bit Integer format, with the 8 LSB at Varptr + 0 and 8 MSB at Varptr + 1.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4. OPERATING COMMANDS

4.1 Load Reset

To reset the load the following steps must be taken:

1. Set the load current to zero (0).
2. Set the load mode to constant current.
3. Turn off the meter bus.
4. Pulse the over-voltage reset line.

4.2 Set Load Current

This function sets the current drawn by the load and requires two writes to the load.

Assume AMPS is the current to be set. To calculate what bits to write to the load scaling must be done. Multiply the desired current by the IDAC gain previously extracted from the EEPROM. Add the IDAC offset. Divide by the full scale current (81201 = 1 Amp and 81210 = 10 Amps) and multiply by 4095.

Scaled AMPS = (AMPS * IDAC gain) + IDAC offset

Bits to write = (Scaled AMPS/full scale current) * 4095

Calculate the most significant bits (MSB).

MSB = Bits to write\16 (integer divide to get 8 MSBs)

LSB = Bits to write and (HEX) OF (get 4 LSBs)

DATA 22 = (DATA 22 and (HEX)F0) or LSB (save the DATA 22 register)

write to device address 22, DATA 22
write to device address 24, MSB

4.3 Set the Load Voltage

This command sets the nominal load voltage used for constant resistance mode. This function requires two (2) writes.

Assume VOLTS is the nominal load voltage to be set.

Bits to write = (VOLTS/75)*4095 (scaled by full scale voltage)

MSB = Bits to write\16 (integer divide to get 8 MSB)

LSB = Bits to write and (HEX) OF (4 LSB)

DATA 22 = (DATA 22 and (HEX)OF) or (LSB*16)
(save the DATA 22 register)

write to device address 22, DATA 22
write to device address 26, MSB

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4.4 Set the Load Operating Mode

This function will set constant current or constant resistance operation.

CONSTANT CURRENT

DATA 28 = DATA 28 and Hex FC	(save value of register 28)
write to device address 28, Hex FC	(clear mode)
DATA 28 = DATA 28 or 1	(Constant Current Mode)
write to device address 28, DATA 28	(write to address CC Mode)

CONSTANT RESISTANCE

Same as above only Constant Resistance Mode is a 2.

DATA 28 = DATA 28 or 2.

Notes:

- *A nominal voltage value should already have written prior to setting CR mode.*
- *The data written to address 28 should always have D0 or D1 set!*
- *To read load voltage or operate in constant resistance mode, the sense inputs must be connected.*

SET THE LOAD SLEW RATES

There are 3 possible slew rate values.

Slow = Hex 8
Medium = Hex 4
Fast = Hex 0C

Define rate = appropriate Hex value

DATA 28 = DATA 28 and Hex F3	(clear slew registers)
DATA 28 = DATA 28 or RATE	(set desired rate)
	write to device address 28, DATA 28

4.5 Miscellaneous Functions

SHORT THE LOAD

DATA 20 = DATA 20 or 8
write to device address 20, DATA 20

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

UNSHORT THE LOAD OR RESET OVER-VOLTAGE LATCH

(DATA 20 and Hex F7) or Hex 40
write to device address 20, DATA 20
DATA 20 = DATA 20 and Hex BF
write to device address 20, DATA 20

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

5. READING AND METERING

5.1 Reading Load Status

Executing a read from device address 20 will return a value for load status. Only the 5 LSB are defined.

B0 = EEPROM - DO	Data line to read when reading EEPROM data.
B1 = Short relay on/off*	A high indicates that the short relay has been activated
B2 = Normal/Power limit*	A low indicates the load is in power limit
B3 = ADC status converting/Done*	A high indicates the ACD converter is running
B4 = 0vertemp/Normal*	A high indicates an overtemp condition

5.2 Reading the Analog to Digital Converter (ADC)

The following shows the type of algorithm required to control the ICL7109 ADC.

1. Select the load function to be read.
2. Set run/hold* line high
   a. DATA 20 = DATA 20 or Hex 10 write to device address 20, DATA 20
3. Delay 10mS (at least)
4. Set run/hold* line low
   a. DATA 20 = DATA 20 or Hex EF write to device address 20, DATA 20
5. Monitor the ADC status line until it goes low.
   a. Read device address 20
   b. If (data read and Hex 08) = 8 then keep reading this until it equals zero (0).
6. Read data
   a. Read device address 24 to get 8 LSB
   b. Read device address 26 to get 4 MSB
   c. If the data read from address has bit 4 set, indicates and ADC overrange (data read and Hex 10).
   d. If (data read and Hex 20) = 0 then signal is negative.
7. Scale data depending on function being read and set proper polarity for reading.
   For Voltage:
   If (DATA and Hex 20) = 0 then the voltage is negative.
   For Current:

   If (DATA and Hex 20) = Hex 20 then the current is negative. There really is no such thing as a negative current for this load, so this value should be returned as 0 amps.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

5.3 Metering

The load has both current and voltage available as measured values.

READ LOAD CURRENT

To select current readings:

DATA 28 = (DATA 28 and Hex OF) or Hex B0 write to address 28, DATA 28
Once selected, read the ADC to get:
LSB = the 8 least significant bits
MSB = the 4 MSB

To scale reading:

Bits = (MSB*256) + LSB
Store = (full scale current/3839.0) * Bits
Current Reading = (IADC gain * Store) + IADC offset

READ LOAD VOLTAGE

To select voltage readings:

DATA 28 = (DATA 28 and Hex OF) or Hex B0 write to address 28, DATA 28

Once selected, read the ADC to get:

LSB = the 8 least significant bits
MSB = the 4 MSB

To scale reading:

Bits = (MSB *256) +LSB
Store = (0.0195 * Bits) (0.0195 = 79.8525/4096)
Voltage Reading = (VADC gain * Store) + VADC offset

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

6. CALIBRATION

All the Calibration data is stored on the EEPROM internal to the unit. This allows for a software "no pots" calibration. Calibration data is stored in a the EEPROM serially. Following is a description of each of the calibration words. All values are signed integers.

Word 1	EEPROM	data valid = 1	address 0
Word 2	IADC	gain	address 1
Word 3	IADC	offset	address 2
Word 4	VADC	gain	address 3
Word 5	VADC	offset	address 4
Word 6	IDAC	gain	address 5
Word 7	IDAC	offset	address 6

A precision shunt, a DC Supply and a DMM are needed to calibrate the load. Calibration points are 10% and 90% of Full Scale Voltage and Current.

Calibration Equations are as follows: Gain = QC2 - X1)/(Y2 - Y1)

0ffset = ((Y2*X1) - (Y1 *X2))/(Y2 - Y1)

IDAC:	X1:	10% OF FULL SCALE CURRENT(1 AMP for model 81201 and 10 Amps for model 81210
	X2:	90% OF FULL SCALE CURRENT
	Y1:	READING OF SHUNT AT 10% SETTING
	Y2:	READING OF SHUNT AT 90% SETTING
IADC	X1:	READING OF SHUNT AT 10% SETTING
	X2:	READING OF SHUNT AT 90% SETTING
	Y1:	READING OF IADC AT 10% SETTING
	Y2:	READING OF IADC AT 90% SETTING
VADC	X1:	VOLTAGE READ AT 10% SETTING (DMM)
	X2:	VOLTAGE READ AT 90% SETTING (DMM)
	Y1:	VOLTAGE READ AT 10% SETTING (√ADC)
	Y2:	VOLTAGE READ AT 90% SETTING (VADC)

Calibration parameters should be multiplied by 10000 (decimal) to convert floating point to integer value before writing to the EEPROM.

The registers in the EEPROM must be erased (all bits set to logical "1") before new data can be written into the registers. Registers are erased by setting the EEPROM Chip-Select (CS) high then serially shifting the operation code and address data into the EEPROM via EEPROM Dl and EEPROM SK. (please refer to section 3.2 Reading the EEPROM).

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

The operation code for read is 111 followed by a 6 bit address value in the form: A5, A4, A3, A2, A1, AO. After the Erase instruction is loaded into the EEPROM, CS must be pulled low. The falling edge of this signal initiates the self-timed programming cycle. If CS is brought high after a minimum delay of 1us the DO pin will remain low as long as the EEPROM is still in the programming mode, and the return of this signal to logical "1" indicates the device is now ready for the next instruction.

After erasing the register, write the new calibration parameters. Data is written by setting the EEPROM Chip-Select (CS) high then serially shifting the operation code and address data into the EEPROM via EEPROM Dl and EEPROM SK. (please refer to section 3.2 Reading the EEPROM).

The operating code for a write is 101. The 16 bits of data must be loaded into the device in the format D15, D14, . . ., D2, D1, DO. After the last bit of data is loaded CS must be brought low before the next rising edge of the serial clock. The high to low transition of CS will initiate a programming cycle to the register whose address was specified in the write instruction. (Please refer to timing diagram Appendix B).

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

APPENDIX A

SPECIFICATIONS AND PANEL CONNECTIONS

VDC Range	Current Range	Power	BW
1.5 - 75 VDC	1 A	50 W	100 KHz
1.5 - 75 VDC	10 A	50 W	100 KHz

Note: All VXIbus loads will operate below 1.5 volts in the constant resistance mode. The programmed load voltage must still be within the ranges specified above.

Current Programming

Accuracy: 0.4% of FS + 0.4% of setting
Resolution: 12 bits

1 Amp full scale - 0.26 milliAmps
10 Amps full scale - 0.52 milliAmps

Voltage reading:

Resolution: 12 Bits
Accuracy: 0.1% of FS +0.5% of reading

Current reading:

Resolution: 12 Bits
Accuracy: 0.2% of FS +0.4% of reading

Operating Modes: Constant Resistance
Constant Current
Short circuit (on/off)
Shut down.(high Z)


Equivalent Resistance Accuracy: 2% (V/I)

Load Speed (10% to 90% risetime - SW selectable):

FAST	MEDIUM	SLOW
5 uSecs	50 uSecs	500 uSecs

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com


VXIbus Load Module - Front Panel



J1 - Auxillary
J2 - UUT Input
J3 - Over voltage power supply
J4 - Over voltage coil

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

VXIbus Load Module - Front Panel



J4 connector type: MOLEX 09-50-3021
NHR part # 6300052

Pin 2 - - OV Coil (relay drive)
Pin 1 - + OV Coil (relay drive)

J3 connector type: MOLEX 09-50-3021
NHR part # 6300052

Pin 2 - + OVPS input
Pin 1 - - OVPS input

J2 connector type: MOLEX 09-50-3061
NHR part # 6300052

Pin 6 - - input
Pin 5 - + input
Pin 4 - - input
Pin 3 - + input
Pin 2 - - input
Pin 1 - + input

J1 connector type: AMP 87922-1
NHR part # 6300052

Pin 1 - + input voltage sense
Pin 2 - - input voltage sense
Pin 3 - NC
Pin 4 - Current Monitor +
Pin 5 - NC
Pin 6 - Current Monitor Ret
Pin 7 - NC
Pin 8 - External Modulation +
Pin 9 - NC
Pin 10 - External Modulation Ret

Notes:


- *Current Monitor is an output analog voltage from 0 to 8 VDC which corresponds to a current from 0 to FS.*
- *External Modulation is an analog-input voltage ranging from 0 to -10 Volts with load set to 0 amps.*
- *The voltage sense MUST be connected in order to enable voltage readback.*

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

APPENDIX B

EEPROM TIMING DIAGRAMS



Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group is an independent supplier of quality pre-owned equipment

Gold-standard solutions

Extend the life of your critical industrial, commercial, and military systems with our superior service and support.

We buy equipment

Planning to upgrade your current equipment? Have surplus equipment taking up shelf space? We'll give it a new home.

Learn more!

Visit us at **artisantg.com** for more info on price quotes, drivers, technical specifications, manuals, and documentation.

Artisan Scientific Corporation dba Artisan Technology Group is not an affiliate, representative, or authorized distributor for any manufacturer listed herein.

We're here to make your life easier. How can we help you today?

(217) 352-9330 | sales@artisantg.com | artisantg.com

ARTISAN® TECHNOLOGY GROUP