ARTISAN®
TECHNOLOGY GROUP

Your **definitive** source for quality pre-owned equipment.

Artisan Technology Group
(217) 352-9330 | sales@artisantg.com | artisantg.com

Full-service, independent repair center
with experienced engineers and technicians on staff.

We buy your excess, underutilized, and idle equipment
along with credit for buybacks and trade-ins.

Custom engineering
so your equipment works exactly as you specify.

- Critical and expedited services
- In stock / Ready-to-ship
- Leasing / Rentals / Demos
- ITAR-certified secure asset solutions

Expert team | Trust guarantee | 100% satisfaction

All trademarks, brand names, and brands appearing herein are the property of their respective owners.

Find the *Tektronix VX4357* at our website: ***Click HERE***

User Manual

Tektronix

VX4357
Relay Switching Module

070-9124-02

This document supports firmware version 1.00 and above.

Warning
The servicing instructions are for use by qualified personnel only. To avoid personal injury, do not perform any servicing unless you are qualified to do so. Refer to the Safety Summary prior to performing service.

CE

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Copyright © Tektronix, Inc. All rights reserved. Licensed software products are owned by Tektronix or its suppliers and are protected by United States copyright laws and international treaty provisions.

Use, duplication, or disclosure by the Government is subject to restrictions as set forth in subparagraph (c)(1)(ii) of the Rights in Technical Data and Computer Software clause at DFARS 252.227-7013, or subparagraphs (c)(1) and (2) of the Commercial Computer Software – Restricted Rights clause at FAR 52.227-19, as applicable.

Tektronix products are covered by U.S. and foreign patents, issued and pending. Information in this publication supercedes that in all previously published material. Specifications and price change privileges reserved.

Printed in the U.S.A.

Tektronix, Inc., P.O. Box 1000, Wilsonville, OR 97070–1000

TEKTRONIX and TEK are registered trademarks of Tektronix, Inc.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

WARRANTY

Tektronix warrants that this product will be free from defects in materials and workmanship for a period of three (3) years from the date of shipment. If any such product proves defective during this warranty period, Tektronix, at its option, either will repair the defective product without charge for parts and labor, or will provide a replacement in exchange for the defective product.

In order to obtain service under this warranty, Customer must notify Tektronix of the defect before the expiration of the warranty period and make suitable arrangements for the performance of service. Customer shall be responsible for packaging and shipping the defective product to the service center designated by Tektronix, with shipping charges prepaid. Tektronix shall pay for the return of the product to Customer if the shipment is to a location within the country in which the Tektronix service center is located. Customer shall be responsible for paying all shipping charges, duties, taxes, and any other charges for products returned to any other locations.

This warranty shall not apply to any defect, failure or damage caused by improper use or improper or inadequate maintenance and care. Tektronix shall not be obligated to furnish service under this warranty a) to repair damage resulting from attempts by personnel other than Tektronix representatives to install, repair or service the product; b) to repair damage resulting from improper use or connection to incompatible equipment; or c) to service a product that has been modified or integrated with other products when the effect of such modification or integration increases the time or difficulty of servicing the product.

THIS WARRANTY IS GIVEN BY TEKTRONIX WITH RESPECT TO THIS PRODUCT IN LIEU OF ANY OTHER WARRANTIES, EXPRESSED OR IMPLIED. TEKTRONIX AND ITS VENDORS DISCLAIM ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. TEKTRONIX' RESPONSIBILITY TO REPAIR OR REPLACE DEFECTIVE PRODUCTS IS THE SOLE AND EXCLUSIVE REMEDY PROVIDED TO THE CUSTOMER FOR BREACH OF THIS WARRANTY. TEKTRONIX AND ITS VENDORS WILL NOT BE LIABLE FOR ANY INDIRECT, SPECIAL, INCIDENTAL, OR CONSEQUENTIAL DAMAGES IRRESPECTIVE OF WHETHER TEKTRONIX OR THE VENDOR HAS ADVANCE NOTICE OF THE POSSIBILITY OF SUCH DAMAGES.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Contacting Tektronix

Product Support	For application-oriented questions about a Tektronix measurement product, call toll free in North America: 1-800-TEK-WIDE (1-800-835-9433 ext. 2400) 6:00 a.m. – 5:00 p.m. Pacific time Or contact us by e-mail: tm_app_supp@tek.com For product support outside of North America, contact your local Tektronix distributor or sales office.
Service Support	Contact your local Tektronix distributor or sales office. Or visit our web site for a listing of worldwide service locations. http://www.tek.com
For other information	In North America: 1-800-TEK-WIDE (1-800-835-9433) An operator will direct your call.
To write us	Tektronix, Inc. P.O. Box 1000 Wilsonville, OR 97070-1000

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

EC Declaration of Conformity

We

Tektronix Holland N.V.
Marktweg 73A
8444 AB Heerenveen
The Netherlands

declare under sole responsibility that the

VX4357

meets the intent of Directive 89/336/EEC for Electromagnetic Compatibility and Low Voltage Directive 73/23/ECC for Product Safety. Compliance was demonstrated to the following specifications as listed in the Official Journal of the European Communities:

EMC Directive 89/336/EEC:

EN 55011 Class A Radiated and Conducted Emissions

EN 50081-1 Emissions:

EN 60555-2 AC Power Line Harmonic Emissions

EN 50082-1 Immunity:

IEC 801-2 Electrostatic Discharge Immunity
IEC 801-3 RF Electromagnetic Field Immunity
IEC 801-4 Electrical Fast Transient/Burst Immunity
IEC 801-5 Power Line Surge Immunity

Low Voltage Directive 73/23/EEC:

EN 61010-1/A2 1995 Safety requirements for electrical equipment for measurement, control, and laboratory use

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

VX4357 MODULE
QUICK REFERENCE GUIDE

Numbers in parentheses refer to the page(s) in the Operating Manual.

SETUP

Be sure all switches are correctly set. (p. 1 - 3)
Follow Installation guidelines. (p. 2 - 1)

The default condition of the VX4357 Module after the completion of power-up self test is that all relays are open.

LEDs

When lit, the LEDs indicate the following:

Power	power supplies functioning
Failed	module failure
Message	module is processing a VMEbus cycle
CH00 - CH31	the associated relay is closed

SYSTEM COMMANDS

All VXIbus commands are accepted (e.g. DTACK* will be returned). VXI V1.3 commands have effect on this module. See the Specifications section for details.

COMMAND SYNTAX

Command protocol and syntax for the VX4357 Module is as follows: (3 - 2)

- Commands may be used in either the long or short form.
- Any character may be sent in either upper or lower case form.
- Commands are executed on receipt.
- The message terminator may be a line feed and/or EOM bit.
- Query commands (Q, T, and IDN) require a terminator. All other commands may be strung together with only the final command in the string requiring a terminator.

MODULE COMMANDS

Commands may be used in either long or short form.

Short/Long Form	Effect
Cz CLOSEz	closes relay z. (3 - 3)
Dz DELAYz	assigns time delay. (3 - 4)
IDN?	returns identification message. (3 - 5)
Oz OPENz	opens relay z. (3 - 6)
Qz QUERYz	queries relay z for status. (3 - 7)
R RESET	resets (opens) all relays. (3 - 8)
S SET	sets (closes) all relays. (3 - 9)
T TIME?	queries time delay. (3 - 10)

PROGRAMMING

The programming examples in the manual are written in Microsoft GW BASIC. For programming examples, see page 4 - 1.

CALL ENTER (R$, LENGTH%, ADDRESS%, STATUS%)

Inputs data into the string R$ from the IEEE-488 instrument whose decimal primary address is contained in the variable ADDRESS%. LENGTH% = the number of bytes read from the instrument. STATUS% = '0' if the transfer was successful; '8' if an operating system timeout occurred in the PC. To use the CALL ENTER statement, the string R$ must be set to a string of spaces whose length is greater than or equal to the maximum number of bytes expected from the 73A-332.

CALL SEND (ADDRESS%, WRT$, STATUS%)

Outputs the contents of the string variable WRT$ to the IEEE-488 instrument whose decimal primary address is in the variable ADDRESS%. The variable STATUS% = '0' if the transfer was successful and an '8' if an operating timeout occurred in the PC.

END Terminates the program.

FOR/NEXT

Repeats the instructions between the FOR and NEXT statements for a defined number of iterations.

GOSUB n Runs the subroutine beginning with line n. The end of the subroutine is delineated with a RETURN statement. When the subroutine reaches the RETURN statement, execution will resume on the line following the GOSUB command.

GOTO n Program branches to line n.

IF/THEN Sets up a conditional IF/THEN statement. Used with other commands, so that IF the stated condition is met, THEN the command following is effective.

REM All characters following the REM command are not executed.

RETURN Ends a subroutine and returns operation to the line after the last executed GOSUB command.

<CR> Carriage return character, decimal 13.

<LF> Line feed character, decimal 10.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Table of Contents

Section 1
General Information and Specifications

Introduction ..... 1 – 1
Controls And Indicators ..... 1 – 3
- Switches ..... 1 – 3
- LEDs ..... 1 – 4
- Fuses ..... 1 – 4

BITE (Built-in Test Equipment) ..... 1 – 5
Specifications ..... 1 – 6

Section 2
Preparation For Use

Installation Requirements And Cautions ..... 2 – 1
Installation Procedure ..... 2 – 2
Installation Checklist ..... 2 – 5

Section 3
Operation

Overview ..... 3 – 1
Power-up ..... 3 – 1
System Commands ..... 3 – 1
Module Commands ..... 3 – 2
- Command Syntax ..... 3 – 2
- Summary ..... 3 – 2
- Command Descriptions ..... 3 – 3

SYSFAIL, Self Test, and Initialization ..... 3 – 11

Section 4
Programming Examples

Definition of BASIC Commands ..... 4 – 1
Programming Example In BASIC ..... 4 – 2

Appendices

Appendix A – VXIbus Operation ..... A – 1
Appendix B – Input/Output Connections ..... A – 3
Appendix C – VXI Glossary ..... A – 5
Appendix D – User Service ..... A – 13
Appendix E – Performance Verification Procedure ..... A – 25

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Safety Summary

The general safety information in this summary is for both operating and servicing personnel. Additional specific warnings and cautions are found throughout the manual where they apply, and may not appear in this summary.

To avoid potential hazards, use this product only as specified.

TERMS

In This Manual

WARNING statements identify conditions or practices that could result in personal injury or loss of life.

CAUTION statements identify conditions or practices that could result in damage to the module or other property.

Marked on the Module

DANGER indicates a personal injury hazard immediately accessible as one reads the marking.

CAUTION indicates a personal injury hazard not immediately accessible as one reads the marking, or a hazard to property, including the module itself.

SYMBOLS

In This Manual



This symbol indicates where applicable cautionary or other information is to be found.



This symbol indicates where special explanatory information is included in the manual. There is no caution or danger associated with the information.

Marked on the Module



DANGER — High Voltage.



Protective ground (earth) terminal.



ATTENTION — Refer to the manual.



Refer to manual before using.

Power Source

This module is intended to operate in a mainframe whose power source does not apply more than 250V rms between the supply conductors or between either supply conductor and ground. A protective ground connection through the grounding conductor in the power cord(s) is essential for safe operation.

Grounding the Module

This module is grounded through the grounding conductor of the mainframe power cord(s). To avoid electrical shock, plug the mainframe power cord(s) into a properly wired receptacle before connecting to the module connectors. A protective ground connection through the mainframe is essential for safe operation.

Danger Arising from Loss of Ground

Upon loss of the protective-ground connection, all accessible conductive parts can render an electric shock.

Use the Proper Fuse

To avoid fire hazard, use only fuses specified in the module parts list. A replacement fuse must meet the type, voltage rating, and current rating specifications required for the fuse that it replaces.

Do Not Operate in Explosive Atmosphere

To avoid explosion, do not operate the module in an explosive atmosphere.

Do Not Remove Covers or Panels

To avoid personal injury, the module covers should be removed only by qualified service personnel. Do not operate the module without covers and panels properly installed.

Installation Category Description

CAT II Local-level mains (wall sockets). Equipment at this level includes appliances, portable tools, and similar products. Equipment is usually connected by a power cord.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

VX4357
Relay Switching Module

Section 1
General Information and Specifications

Introduction

The VX4357 Relay Switching Module is a printed circuit board assembly for use in a mainframe conforming to the VXIbus Specification, such as the VX1400 "C" size mainframe used in the Tektronix/CDS IAC System. The module provides 32 independently controlled single-pole, double-throw relays. Individual relays or all relays can be opened or closed under program control.

The amount of delay between successive operations and the relay closure dwell time can be controlled by software. Delay times from 0 to 65535 milliseconds can be selected. The module is programmed by transmitting ASCII characters from the system controller through the VXI system to the module.

The module's commands also provide access to system information. The position of any individual relay (open or closed) may be read back by the system controller and is also displayed by LEDs on the module's front panel. Other commands return the programmed time delay and identification information about the module.

Note that certain terms used in this manual have very specific meanings in the context of a VXIbus System. A list of these terms is presented in the VXIbus Glossary (Appendix C).




Figure 1: Typical SPDT Relay

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com




Figure 2: VX4357 Controls and Indicators


Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Controls And Indicators

The following controls and indicators are provided to select and display the functions of the VX4357 Module's operating environment. See Figures 2 and 3 for their physical locations.

Switches

Logical Address Switches



Each function module in a VXIbus System must be assigned a unique logical address, from 1 to 255 decimal. The base VMEbus address of the VX4357 is set to a value between 1 and FFh (255d) by two hexadecimal rotary switches. Align the desired switch position to the arrow on the module shield.

The actual physical address of the VX4357 Module is on a 64 byte boundary. If the switch representing the most significant digit (MSD) of the logical address is set to position X and the switch representing the least significant digit (LSD) of the logical address is set to position Y, then the base physical address of the VX4357 will be [(64d * XYh) + 49152d]. For example:

L.A.	MSD	LSD	Base Physical Addr. (d)
Ah	0	A	(64*10)+49152 = 49792d
15h	1	5	(64*21)+49152 = 50496d

where: L.A. = Logical Address
MSD = Most Significant Digit
LSD = Least Significant Digit


IEEE-488 Address

Using the VX4357 Module in an IEEE-488 environment requires knowing the module's IEEE-488 address in order to program it. Different manufacturers of IEEE-488 interface devices may have different algorithms for equating a logical address with an IEEE-488 address.

If the VX4357 is being used with a Tektronix/CDS IEEE-488 interface module, consult the operating manual of the Tektronix/CDS Resource Manager/IEEE-488 Interface Module being used.

If the VX4357 is not being used with a Tektronix/CDS Resource Manager/IEEE-488 Interface Module, consult the operating manual of the IEEE-488 interface device being used for recommendations on setting the logical address.

Halt Switch



This two-position slide switch selects the response of the VX4357 Module when the Reset bit in the module's VXIbus Control register is set. Control of the Reset bit depends on the capabilities of the VX4357's commander.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

If the Halt switch is in the ON position, then the VX4357 Module is reset to its power-up state and all programmed module parameters are reset to their default values.

If the Halt switch is in the OFF position, the module will ignore the Reset bit and no action will take place.

Note that module is not in strict compliance with the VXIbus Specification when the Halt switch is OFF.

LEDs

The following LEDs are visible at the top of the VX4357 Module's front panel to indicate the status of the module's operation:

Power LED
This green LED is normally lit and is extinguished if the +5V power supply fails or the +5V fuse opens.

Failed LED
This normally off red LED is lit whenever SYSFAIL* is asserted, indicating a module failure.

If the module's +5V fuse opens, the Failed LED will be lit and SYSFAIL* asserted. A module power failure is also indicated when the module's Power LED is extinguished.

Message LED
This green LED is normally off. When lit it indicates that the module is processing a VMEbus cycle. The LED is controlled by circuitry that appears to stretch the length of the VMEbus cycle. For example, a five microsecond cycle will light the LED for approximately 0.2 seconds. The LED will remain lit if the module is being constantly addressed.

Channel LEDs
The column of 32 green LEDs represent relays 00 through 31, reading from top to bottom. A lit LED indicates that the associated relay is closed.

Fuses

The VX4357 Module has one +5V, 5 amp fuse. The fuse protects the module in case of an accidental shorting of the power bus or any other situation where excessive current might be drawn.

If the +5V fuse opens, the VXIbus Resource Manager will be unable to assert SYSFAIL INHIBIT on this module to disable SYSFAIL*.

If the +5V fuse opens, remove the fault before replacing the fuse. Replacement fuse information is given in the Specifications section of this manual.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

BITE (Built-In Test Equipment)

Any individual channel position can be interrogated under program control to determine if the relay is open or closed. The controller signal for each relay is connected both to the channel LED and to a separate input buffer. The module can also return information on the programmed time delay and module identification information.




Figure 3: Front Panel Display

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Specifications

Configuration: 32 single-pole double-throw (SPDT) relays.

Relay: Aromat Corporation model S2EB-5V (per CDS specification).

Contact Ratings:
Maximum switching power:
1000 VA ac, 90 W dc.
Maximum switching voltage:
250 V ac, 48 V dc. **CAT II, 48 V dc**
Maximum switching current:
5 A (<40 operations per minute)

Maximum Power Dissipation Per Connector: 1 Watt. To determine the current capacity for specific applications, assume 20 milliohms resistance per pin.

Maximum Operating Speeds: 100 operations per second.

Programmable Relay Delay: 0 to 65,535 msec.

Recommended Maximum Operating Conditions and Operational Life:

Rate*	Volts	Amps	Op. Life*
40 OPM	30 V dc	3.0 A	2×10^5
40 OPM	250 V ac	4.0 A	10^5
40 OPM	130 V ac	5.0 A	1×10^4
40 OPM	20 V dc	5.0 A	2×10^5
20 OPS	30 V dc	2.0 A	10^6
20 OPS	250 V ac	2.0 A	10^6
100 OPS	1 V dc	1.0 mA	10^6

NOTE: OPS - operations per second
OPM - operations per minute
Op Life - operational life

An operation is defined as a close or an open. A close/open cycle is two operations.
* Values are for a 5% failure probability.

Duty Cycle: Continuous.

Dwell: Recommended dwell time at maximum switching rate is 4 msec minimum.

Signal Path Specifications: Single-line thermal offset:
Less than 10 microvolts.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Signal path resistance:
Initial: Less than 300 milliohms.
After full load-life: Less than 400 milliohms.
Insulation resistance:
Greater than 10 Gigohms.

Isolation - Wiper to Open Contact:

1 kHz	Less than -85 dB
10 kHz	Less than -55 dB
100 kHz	Less than -36 dB
1 MHz	Less than -18 dB

Measurement was made on both the normal open and normal closed contacts with a 600 ohm termination. The signal was applied to the wiper of the relay.

Crosstalk Between Channels:

1 kHz	Less than -90 dB
10 kHz	Less than -80 dB
100 kHz	Less than -60 dB
1 MHz	Less than -40 dB

Measurement was made on a closed relay with a 600 ohm termination and signal applied into an adjacent channel, open or closed relay, with and without 600 ohm termination.

Power Up: When power is turned on, all relays are open.

Power Down: When power is turned off, all relays are open.

VXIbus Compatibility: Fully compatible with the VXIbus Specification for **V1.4** message-based instruments with the Halt switch in the ON position.

Device Type: VXI message based instrument, **V1.4**

VXI Protocol: Word serial.

VXI Card Size: C size, one slot wide.

Module-Specific Commands: All module-specific commands and data are sent via the VXIbus Byte-Available command. All module-specific commands are made up of ASCII characters. Module-specific data may be in either ASCII or binary format.

VMEbus Interface: Data transfer bus (DTB) slave - A16, D16 only.

VXIbus Data Rate: 300K bytes/sec maximum.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

VXIbus Commands Supported:

All VXIbus commands are accepted (e.g. DTACK* will be returned). VXI V1.3 commands have effect on this module.

All Primary, MBD, VXIbus Instrument-required commands are supported:

- Abort Normal Operation
- Begin Normal Operation
- Byte Available
- Byte Request
- Clear
- End Normal Operation
- Read Protocol
- Read Protocol Error

The following additional commands are supported:

- Read STB
- Read Interrupters
- Asynchronous Mode Control
- Control Event
- Control Response
- Set Lock
- Clear Lock
- Trigger

All other commands will generate Word Serial Protocol 'Unsupported Command' errors.

VXIbus Registers:

ID
Device Type
Status
Control
Protocol
Response
Data Low
See Appendix A for definition of register contents.

Power Requirements:

All required dc power is provided by the power supply in the VXIbus mainframe.

Voltage:

5 volt supply: 4.75 V dc to 5.25 V dc.

Current (Peak Module, I_{PM}):

5 volt supply: 2.2 amps PTP.

Cooling:

Provided by fans in the mainframe. The module will have a temperature rise of < 10°C with 0.9 liters/sec per slot of air and a pressure drop of 0.16 mm of H_2O.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

	For 10°C rise, 1.2 liters/sec air at 0.01 mm of H_2O.
Fuses:	Replacement fuse: Littelfuse P/N 273005 SA, 125V, fast blow
Temperature:	0°C to +50°C, operating. -40°C to +85°C, storage.
Humidity:	Less than 95% R.H. non-condensing, 0°C to +30°C. Less than 75% R.H. non-condensing, +31°C to +40°C. Less than 45% R.H. non-condensing, +41°C to +50°C.
Radiated Emissions:	Complies with VXIbus Specification.
Conducted Emissions:	Complies with VXIbus Specification.
Module Envelope Dimensions:	VXI C size. 262 mm x 357 mm x 30.5 mm (10.3 in x 13.9 in x 1.2 in)
Dimensions, Shipping:	When ordered with a Tektronix/CDS mainframe, this module will be installed and secured in one of the instrument module slots (slots 1-12). When ordered alone, the card's shipping dimensions are: 406 mm x 305 mm x 102 mm. (16 in x 12 in x 4 in).
Weight:	1.60 kg. (3.56 lbs.)
Weight, Shipping:	When ordered with a Tektronix/CDS mainframe, this module will be installed and secured in one of the instrument module slots (slots 1-12). When ordered alone, the card's shipping weight is: 2.27 kg. (5.06 lbs.)
Mounting Position:	Any orientation.
Mounting Location:	Installs in an instrument module slot (slots 1-12) of a C or D size VXIbus mainframe. (Refer to D size mainframe manual for information on required adapters.)
Front Panel Signal Connectors:	2 DD-50P connectors. Refer to Appendix B for connector pinouts.
Recommended Cables:	Two VX1657S Data cables.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Equipment Supplied:	1 - VX4357 Module.
Optional Equipment:	2 - VX1657S cables or VX1780S connectors.
Software Revision:	V1.3

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Section 2
Preparation For Use

Installation Requirements And Cautions

The VX4357 Module is a C size VXIbus instrument module and therefore may be installed in any C or D size VXIbus mainframe slot other than slot 0. If the module is being installed in a D size mainframe, consult the operating manual for the mainframe to determine how to install the module in that particular mainframe. Setting the module's Logical Address switch defines the module's programming address. Refer to the Controls and Indicators subsection for information on selecting and setting the VX4357 Module's logical address.

Tools Required

The following tools are required for proper installation:

Slotted screwdriver set.



To avoid electric shock, tighten the module mounting screws after installing the module into the mainframe to ensure that the front panel is properly grounded.

Note. *There are two labeled ejector handles on the card. To install the card correctly, make sure the ejector labeled "VX4357" is at the top.*

Note. *To maintain proper mainframe cooling, unused mainframe slots must be covered with the blank front panels supplied with the mainframe.*

Verify that the mainframe is able to provide adequate cooling and power with this module installed. Refer to the mainframe Operating Manual for instructions.

Based on the number of instrument modules ordered with a Tektronix/CDS mainframe, blank front panels are supplied to cover all unused slots. Additional VXIbus C size single-slot and C size double-slot blank front panels can be ordered from your Tektronix supplier.

CAUTION

Verify that the mainframe is able to provide adequate cooling and power with this module installed. Refer to the mainframe Operating Manual for instructions.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

If the VX4357 is used in a VX1X Series Mainframe, all VX4357 cooling requirements will be met.

CAUTION

If the VX4357 Module is inserted in a slot with any empty slots to the left of the module, the VME daisy-chain jumpers must be installed on the backplane in order for the VX4357 Module to operate properly. Check the manual of the mainframe being used for jumpering instructions.

If a Tektronix/CDS VX1400 or VX1401 mainframe is being used, the jumper points may be reached through the front of the mainframe. There are five (5) jumpers that must be installed for each empty slot. The five jumpers are the pins to the left of the empty slot.

Installation Procedure

CAUTION

The VX4357 Module is a piece of electronic equipment and therefore has some susceptibility to electrostatic damage (ESD). ESD precautions must be taken whenever the module is handled.

1) Record the module's revision level, serial number (located on the label on the top shield of the VX4357), and switch settings on the Installation Checklist. Only qualified personnel should perform this installation.

2) Verify that the switches are switched to the correct values. The Halt switch should be in the ON position unless it is desired to not allow the resource manager to reset this module.

   Note that with either Halt switch position, a "hard" reset will occur at power-on and when SYSRST* is set true on the VXIbus backplane. If the module's commander is a Tektronix/CDS Resource Manager/IEEE-488 Interface Module, SYSRST* will be set true whenever the Reset switch on the front panel of that module is depressed. Also note that when the Halt switch is in the OFF position, the operation of this module is not VXIbus compatible.

3) The module can now be inserted into any slot of the chassis other than slot 0.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com




Figure 4: Module Installation

4) Install the cables - Use two VX1657S Analog Cables to interface between the module's output connector and the Unit Under Test (UUT).

If a special cable is needed, a VX1780S Hooded Connector may be used to cable between the module output connector and the UUT.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Installation Checklist

Installation parameters may vary depending on the mainframe being used. Be sure to consult the mainframe Operating Manual before installing and operating the VX4357 Module.

Revision Level: _____

Serial No.: _____

Mainframe Slot Number: _____

Switch Settings:

VXIbus Logical Address Switch: _____

Halt Switch: _____

Cable / Hooded Connector Installed:

VX1657S Cables: ____

VX1780S Connectors: ____

Performed by: _____ Date: _____

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Section 3
Operation

Overview

The VX4357 Relay Switching Module provides 32 independently controlled single pole, double throw relays. Individual relays or all relays can be opened or closed under program control.

The amount of delay between successive operations and relay closure dwell time can be controlled by software. Delay times from 0 to 65535 milliseconds can be selected.

The VX4357 Module is programmed by ASCII characters issued from the system controller to the VX4357 Module via the module's VXIbus commander and the VXIbus mainframe backplane. The module is a VXIbus Message Based instrument and communicates using the VXIbus Word Serial Protocol. Refer to the manual for the VXIbus device that will be the VX4357 Module's commander for details on the operation of that device.

If the module commander is a Tektronix/CDS Resource Manager/IEEE-488 Interface Module, refer to that Operating Manual and the programming examples in the Operation section of this manual for information on how the system controller communicates with the commander being used.

Power-up

The VX4357 Module will complete its self test and be ready for programming five seconds after power-up. The VXIbus Resource Manager may add an additional one or two second delay. The Power LED will be on, and all other LEDs off. The MSG LED will blink during the power-up sequence as the VXIbus Resource Manager addresses all modules in the mainframe. The default condition of the module after power-up is described in the SYSFAIL, Self Test and Initialization subsection.

System Commands

Although these non-data commands are initiated by the VX4357's commander (for example, the Tektronix/CDS VX4521 Enhanced Slot 0/Resource Manager) rather than the system controller, they have an effect on the VX4357 Module. The supported VXIbus commands are listed in the Specifications.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Module Commands

A summary of the VX4357's Module's commands is listed below. The summary also shows any required order of programming needed for commands. This is followed by detailed descriptions of each of the commands. A sample BASIC program using these commands is shown at the end of this section.

Command Syntax

Command protocol and syntax for the VX4357 Module are as follows:

- Commands may be used in either the long or short form.
- Any character may be sent in either upper or lower case form.
- Commands are executed on receipt.
- The message terminator may be a line feed and/or EOI bit.
- Query commands (Q, T, and IDN?) require a terminator. All other commands may be strung together with only the final command in the string requiring a terminator.

Summary

An overview of the commands, in the order they typically would be programmed, is as follows:

Short/Long Form	Effect
Dz DELAYz	assigns time delay.
R RESET	resets (opens) all relays.
S SET	sets (closes) all relays.
Cz CLOSEz	closes relay z.
Oz OPENz	opens relay z.
Qz QUERYz	queries relay z for status.
T TIME?	queries time delay.
IDN?	returns identification message.

A detailed description of each command, in alphabetical order, is given in the following pages.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Command Descriptions

Command: CLOSE (Close a single relay)

Syntax: Cz or CLOSEz

Purpose: This command Closes a single relay on the VX4357 Module.

Description: z a 1- or 2-digit decimal number (0-31) which specifies the relay to be closed by the C command.

If the addressed relay is already closed, it will remain closed. The module will not accept the next command in the command sequence until the Delay time has elapsed.

Valid relay numbers are 1- or 2-digit ASCII numbers from 00 to 31. A relay number above 31 will not cause any action or delay time.

Examples: The command "C04" closes relay 4. Closing relay 4 will turn on Channel LED 4.

The command:

"R00C1C00C24"

would open any closed relays and close relays 00, 01, and 24. Channel LEDs 00, 01, and 24 will be lit. The delay time set by the Delay command occurs after the reset and after the closing of each relay.

Note that the command sequence does not require a terminator.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Command: DELAY (set delay time)

Syntax: Dz or DELAYz

Purpose: This command assigns the time delay.

Description: z the time delay value, from 0 to 65,535 milliseconds.

The Delay command controls the amount of delay between successive relay operations. Once the delay is programmed, any commands will be delayed by the specified interval. This delay interval will remain valid until another value is programmed or until a Sysreset is issued.

Note that since this delay holds off the controller, the timeout of the controller must be set higher than the total time of the relay commands sent.

Example: The command

"D500C0C1C2"

programs the delay interval to be 500 ms, and closes relays 0, 1, and 2. There will be a 500 ms delay between each relay closing.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Command: IDN? (Identification)

Syntax: IDN?

Purpose: This command provides identification information about the module.

Description: When this command is issued, the module will return specific information about the module. This includes manufacturer's model number, type of device, and version of software.

Response Syntax: The module returns a string consisting of four parameters, separated by semicolons:

param1; param2; param3; param4

param1	manufacturer and model code
param2	type of module
param3	version of software
param4	date of software release

Note that this command will not return a response until the <CR><LF> terminator is received.

Example: The command

"IDN?"

could return the following string for this board:

Tek/CDS VX4357; 32 Channel Switching Module; Ver 1.0; JAN 30, 1992

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Command: OPEN (Open a single relay)

Syntax: Oz or OPENz

Purpose: This command Opens a single relay on the VX4357 Module.

Description: z a 1- or 2-digit decimal number (00-31) which specifies the relay to be opened by the O command.

Valid relay numbers are 1- or 2-digit ASCII numbers from 00 to 31. A relay number above 31 will not cause any action or delay time.

The module will not accept the next command in the command sequence until the Delay time has elapsed.

Examples: If relays 4 and 5 are closed, the command:

"O04"

opens relay 4 on the VX4357 Module. Only relay 5 will remain closed and only Channel LED 5 will remain lit.

The command:

"R00C0C1C2C3C4O3"

opens any closed relays, closes relays 0, 1, 2, 3, and 4, then re-opens relay 3. The time between execution of each of the commands in the sequence depends on the rate the string is transmitted and the Delay time setting.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Command: QUERY? (Query a relay)

Syntax: Qz or QUERY?z

Purpose: The Query command selects a particular relay for status query, without changing its current state.

Description: z a 1- or 2-digit decimal number (00-31) which specifies the relay to be queried by the Q command.

A read from the VX4357 Module will return the status of the last relay selected. A relay is selected when it is set or reset (S or R commands), or by use of the Query command. The Query command allows selecting a relay without changing its current state.

Following this command, a read from the VX4357 will return either a 0 for open, or a 1 for closed. The module will not accept the next command in the command sequence until the Delay time has elapsed.

A "Cz" or "Oz" command also selects relay z for query. However, only the last relay specified in a command sequence will be selected. A read following the command "C00C01C03" would return the status of relay 3.

Valid relay numbers are 1- or 2-digit ASCII numbers from 00 to 31. A relay number above 31 will not cause any action or delay time.

Note that this command will not return a response until the <CR><LF> terminator is received.

Response Syntax: The module returns a 3-character ASCII string consisting of a "1" or "0", a carriage return (hex D) and a line feed (hex A). The END bit (which translates to a GPIB EOI bit in an IEEE-488 system) is set on the line feed character.

Response	Indicates
0<CR><LF>	open
1<CR><LF>	closed

Examples: The command:

"Q03"

selects relay 3. If relay 3 is open and the VX4357 is read, 0<CR><LF> will be returned.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Command: RESET (Reset all relays)

Syntax: R[z] or RESET[z]

Purpose: This command Resets (opens) all relays on the VX4357 Module.

Description: An "R" in the command sequence opens all relays on the VX4357 Module. After this command, all the Relay LEDs will be off.

The optional [z] after the "R" initiates a delay. If z is specified, the module will not accept the next command in the command sequence until the Delay time has elapsed. z may be any valid relay number from 00 to 31 (usually 00). If any relay number is used, all relays will be opened and the delay specified by the Delay command will be initiated.

Example: The command:

"R00C00C24R00"

opens all relays, (delay sequence), closes relay 0, (delay sequence), closes relay 24, and then opens all relays again.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Command: SET (Set all relays)

Syntax: S[z] or SET[z]

Purpose: This command Sets (closes) all relays on the VX4357 Module.

Description: An "S" in the command sequence closes all relays on the VX4357 Module. After this command, all the Relay LEDs will be on.

The optional [z] after the "S" initiates a delay. If z is specified, the module will not accept the next command in the command sequence until the Delay time has elapsed. z may be any valid relay number from 00 to 31 (usually 00). If any relay number is used, all relays will be closed and the delay specified by the Delay command will be initiated.

Example: The command:

"S00O00O24R00"

closes all relays, (delay sequence), opens relay 0, (delay sequence), opens relay 24, and then opens all relays.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Command: TIME? (query time delay)

Syntax: T or TIME?

Purpose: This command returns the delay value.

Description: The delay value set by the Delay command is returned.

Response Syntax: The module returns a string consisting of up to five numbers, a carriage return (hex D), and a line feed (hex A). The End bit, which translates to a GPIB EOI bit in the IEEE-488 system, is set on the line feed character.

The response format is n<CR><LF>

where 'n' is a numeric value from 0 to 65,535, representing the delay value in milliseconds.

Note that this command will not return a response until the <CR><LF> terminator is received.

Example: The commands

"D100"
"T"

return

100<CR><LF>

The delay value is programmed for 100 milliseconds and this value is read back.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

SYSFAIL, Self Test, and Initialization

The default condition of the VX4357 Module after the completion of power-up is that all relays are open.

SYSFAIL* becomes active if the module's +5V bus fuses open. In this case, the mainframe Resource Manager will not be able to set the Sysfail Inhibit bit in the module's Control register, since the module logic will have lost power.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Section 4
Programming Examples

This section contains an example program which demonstrates how the various programmable features of the VX4357 are used. The example is written in BASIC using an IBM PC or equivalent computer as the system controller.

Definition of BASIC Commands

The programming examples in this manual are written in Microsoft GW BASIC. These examples use the GW BASIC commands described below. If the programming language you are using does not conform exactly to these definitions, use the command in that language that will give the same result.

Command Result

CALL ENTER (R$, LENGTH%, ADDRESS%, STATUS%)
The CALL ENTER statement inputs data into the string R$ from the IEEE-488 instrument whose decimal primary address is contained in the variable ADDRESS%. Following the input, the variable LENGTH% contains the number of bytes read from the instrument. The variable STATUS% contains the number '0' if the transfer was successful or an '8' if an operating system timeout occurred in the PC. Prior to using the CALL ENTER statement, the string R$ must be set to a string of spaces whose length is greater than or equal to the maximum number of bytes expected from the VX4357.

CALL SEND (ADDRESS%, OUT$, STATUS%)
The CALL SEND statement outputs the contents of the string variable OUT$ to the IEEE-488 instrument whose decimal primary address is contained in the variable ADDRESS%. Following the output of data, the variable STATUS% contains a '0' if the transfer was successful and an '8' if an operating timeout occurred in the PC.

END Terminates the program.

FOR/NEXT Repeats the instructions between the FOR and NEXT statements for a defined number of iterations.

GOSUB n Runs the subroutine beginning with line n. EX: GOSUB 750 - runs the subroutine beginning on line 750. The end of the subroutine is delineated with a RETURN statement. When the subroutine reaches the RETURN statement, execution will resume on the line following the GOSUB command.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

GOTO n	Program branches to line n. EX: GOTO 320 - directs execution to continue at line 320.
IF/THEN	Sets up a conditional IF/THEN statement. Used with other commands, such as PRINT or GOTO, so that IF the stated condition is met, THEN the command following is effective. EX: IF I = 3, GOTO 450 - will continue operation at line 450 when the value of variable I is 3.
REM	All characters following the REM command are not executed. REM statements are used for documentation and user instructions. EX: REM **CLOSE ISOLATION RELAYS**
RETURN	Ends a subroutine and returns operation to the line after the last executed GOSUB command.
<CR>	Carriage return character, decimal 13.
<LF>	Line feed character, decimal 10.

Programming Example In BASIC

The following sample BASIC program shows how commands for the VX4357 might be used. This example assumes that the VX4357 has logical address 24 and is installed in a VXIbus mainframe that is controlled via an IEEE-488 interface from an external system controller, such as an IBM PC or equivalent using a Capital Equipment Corp. IEEE-488 interface. The VXIbus IEEE-488 interface is assumed to have an IEEE-488 primary address of decimal 21 and to have converted the VX4357 Module's logical address to an IEEE-488 primary address of decimal 24.

Following each example, the data sent to and returned from the module is shown, with data returned by the module shown underlined.

The following program demonstrates communication with a VX4357.
Lines 10 through 40 initialize the PC's IEEE-488 interface card as a system controller with an IEEE-488 address of decimal 24.
Line 50 assigns the decimal IEEE-488 address of the VX4357 to the variable ADDR357%.

```
10  GOSUB 1000
20  ENTER = 21:SEND = 9 : INIT = 0
30  PC.ADDRESS% = 21 : CONTROL% = 0
40  CALL INIT (PC.ADDRESS%, CONTROL%)
50  ADDR357% = 24
60  O$ = "R00"
```

Lines 60-80 send the Reset command to open all relays.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

```
70   CALL SEND (ADDR357%,O$,STATUS%)
80   IF STATUS% < > 0 THEN PRINT "ERROR - IEEE-488 TIMEOUT":STOP
90   O$ = "C05"
          Lines 90-110 send the Close command to close relay 5.
100  CALL SEND (ADDR357%,O$,STATUS%)
110  IF STATUS% < > 0 THEN PRINT "ERROR - IEEE-488 TIMEOUT":STOP
120  O$ = "C03C08C27C25"
          Lines 120-140 send Close commands to close relays 3, 8, 27, and 25.
130  CALL SEND (ADDR357%,O$,STATUS%)
140  IF STATUS% < > 0 THEN PRINT "ERROR - IEEE-488 TIMEOUT":STOP
150  O$ = "Q08"
          Lines 150-170 send the Query command to select relay 8 for status.
160  CALL SEND (ADDR357%,O$,STATUS%)
170  IF STATUS% < > 0 THEN PRINT "ERROR - IEEE-488 TIMEOUT":STOP
180  R$ = SPACE$(3) : REM  MAKE A PLACE TO RECEIVE.
          Lines 180-220 read the status of relay 8 and print the status to the screen.
190  CALL ENTER (R$,LENGTH%,ADDR357%,STATUS%)
200  IF STATUS% < > 0 THEN PRINT "ERROR - IEEE-488 TIMEOUT":STOP
210  IF LEFT$(R$,1) = "1" THEN PRINT "RELAY 8 CLOSED"
220  IF LEFT$(R$,1) = "0" THEN PRINT "RELAY 8 OPEN"
230  O$ = "O25O08"
          Lines 230-250 send the Open command to open relays 25 and 8.
240  CALL SEND (ADDR357%,O$,STATUS%)
250  IF STATUS% < > 0 THEN PRINT "ERROR - IEEE-488 TIMEOUT":STOP
260  R$ = SPACE$(3) : REM  MAKE A PLACE TO RECEIVE.
          Lines 260-300 read the status of relay 8 and print the status to the screen.
270  CALL ENTER (R$,LENGTH%,ADDR357%,STATUS%)
280  IF STATUS% < > 0 THEN PRINT "ERROR - IEEE-488 TIMEOUT":STOP
290  IF LEFT$(R$,1) = "1" THEN PRINT "RELAY 8 CLOSED"
300  IF LEFT$(R$,1) = "0" THEN PRINT "RELAY 8 OPEN"
310  END


1000 '  Sub-routine identifies the memory location of CEC IEEE-488 Interface Card ROM.
1020 '
1030 FOR I = &H40 TO &HEC STEP &H4
1040 FAILED =0: DEF SEG = (I * &H100)
1050 IF CHR$ ( PEEK (50) ) < > "C" THEN FAILED =1
1060 IF CHR$ ( PEEK (51) ) < > "E" THEN FAILED =1
1070 IF CHR$ ( PEEK (52) ) < > "C" THEN FAILED =1
1080 IF FAILED = 0 THEN CECLOC = (I * &H100 ): I = &HEC
1090 NEXT I
1100 RETURN
```

Data sent and received:

R00<CR><LF>
C05<CR><LF>

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

C03C08C27C25<CR><LF>
Q08<CR><LF>
1<CR><LF>
O25O08<CR><LF>
0<CR><LF>

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Appendix A
VXIbus Operation

The VX4357 Module is a C size single slot VXIbus Message-Based Word Serial instrument. It uses the A16, D16 VME interface available on the backplane P1 connector and does not require any A24 or A32 address space. The Module is a D16 interrupter.

The VX4357 Module is neither a VXIbus commander nor a VMEbus master, and therefore it does not have a VXIbus signal register. The VX4357 is a VXIbus message based servant.

The module supports the Normal Transfer Mode of the VXIbus, using the Write Ready and Read Ready bits of the module's Response register.

A Normal Transfer Mode Read of the VX4357 Module proceeds as follows:

1. The commander reads the VX4357's Response register and checks if the Write Ready bit is true. If it is, the commander proceeds to the next step. If not, the commander continues to poll the Write Ready bit until it becomes true.

2. The commander writes the Byte Request command (0DEFFh) to the VX4357's Data Low register.

3. The commander reads the VX4357's Response register and checks if the Read Ready bit is true. If it is, the commander proceeds to the next step. If not, the commander continues to poll the Read Ready bit until it becomes true.

4. The commander reads the VX4357's Data Low register.

A Normal Transfer Mode Write to the VX4357 Module proceeds as follows:

1. The commander reads the VX4357's Response register and checks if the Write Ready bit is true. If it is, the commander proceeds to the next step. If not, the commander continues to poll the Write Ready bit until it becomes true.

2. The commander writes the Byte Available command which contains the data (0BCXX or 0BDXX depending on the state of the End bit) to the VX4357's Data Low register.

As with all VXIbus devices, the VX4357 Module has registers located within a 64 byte block in the A16 address space. The VX4357 Module has no registers beyond those defined for VXIbus message based devices. All communications with the module are through the data low register, the response register or the VXIbus interrupt cycle. Any

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

attempt by another module to read or write to any undefined location of the VX4357's address space may cause incorrect operation of the module.

The base address of the VX4357 device's registers is determined by the device's unique logical address and can be calculated as follows:

Base Address = V * 40H + C000H

where V is the device's logical address as set in the logical address switches.

VX4357 Configuration Registers

Below is a list of the VX4357's Configuration registers with a complete description of each. In this list, RO = Read Only, WO = Write Only, R = Read, W = Write, and X = varies with the state of the interface. The offset is relative to the module's base address.

REGISTER DEFINITIONS

Register	Address	Type	Value (Bits 15-0)
ID Register	0000H	RO	1011 1111 1111 1100 (BFFCh)
Device Type	0002H	RO	1111 0110 1001 1010 (F69Ah)
Status	0004H	R	0X11 1111 1111 XX11
Control	0004H	W	0111 1111 1111 11XX
Offset	0006H	WO	Not used
Protocol	0008H	RO	1110 1111 1111 1111 (EFFFh)
Response	000AH	RO	Defined by state of the interface
Data High	000CH		Not used
Data Low	000EH	W	16-bit arbitrary data
Data Low	000EH	R	16-bit arbitrary data

The VXI Word Serial command 'Read Protocol' returns information describing the communication protocols the device supports. This knowledge is required for proper device communication. For the VX4357 device, the Read Protocol command returns:

FF6Bh

This value indicates the device supports the VXI V1.3 Specification, that the device supports VXIbus Instrument protocol, and that the device supports the WSP Trigger command.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Appendix B
Input/Output Connections

Relay	Contact	VX4357 Connector
00	N.O.	P4-1
	Wiper	P4-2
	N.C.	P4-34
01	N.O.	P4-3
	Wiper	P4-4
	N.C.	P4-36
02	N.O.	P4-5
	Wiper	P4-6
	N.C.	P4-38
03	N.O.	P4-7
	Wiper	P4-8
	N.C.	P4-40
04	N.O.	P4-9
	Wiper	P4-10
	N.C.	P4-42
05	N.O.	P4-11
	Wiper	P4-12
	N.C.	P4-44
06	N.O.	P4-13
	Wiper	P4-14
	N.C.	P4-46
07	N.O.	P4-15
	Wiper	P4-16
	N.C.	P4-48
08	N.O.	P4-18
	Wiper	P4-19
	N.C.	P4-35
09	N.O.	P4-20
	Wiper	P4-21
	N.C.	P4-37

Relay	Contact	VX4357 Connector
10	N.O.	P4-22
	Wiper	P4-23
	N.C.	P4-39
11	N.O.	P4-24
	Wiper	P4-25
	N.C.	P4-41
12	N.O.	P4-26
	Wiper	P4-27
	N.C.	P4-43
13	N.O.	P4-28
	Wiper	P4-29
	N.C.	P4-45
14	N.O.	P4-30
	Wiper	P4-31
	N.C.	P4-47
15	N.O.	P4-32
	Wiper	P4-33
	N.C.	P4-49
16	N.O.	P5-1
	Wiper	P5-2
	N.C.	P5-34
17	N.O.	P5-3
	Wiper	P5-4
	N.C.	P5-36
18	N.O.	P5-5
	Wiper	P5-6
	N.C.	P5-38
19	N.O.	P5-7
	Wiper	P5-8
	N.C.	P5-40

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Relay	Contact	VX4357 Connector
20	N.O.	P5-9
	Wiper	P5-10
	N.C.	P5-42
21	N.O.	P5-11
	Wiper	P5-12
	N.C.	P5-44
22	N.O.	P5-13
	Wiper	P5-14
	N.C.	P5-46
23	N.O.	P5-15
	Wiper	P5-16
	N.C.	P5-48
24	N.O.	P5-18
	Wiper	P5-19
	N.C.	P5-35
25	N.O.	P5-20
	Wiper	P5-21
	N.C.	P5-37
26	N.O.	P5-22
	Wiper	P5-23
	N.C.	P5-39
27	N.O.	P5-24
	Wiper	P5-25
	N.C.	P5-41
28	N.O.	P5-26
	Wiper	P5-27
	N.C.	P5-43
29	N.O.	P5-28
	Wiper	P5-29
	N.C.	P5-45
30	N.O.	P5-30
	Wiper	P5-31
	N.C.	P5-47
31	N.O.	P5-32
	Wiper	P5-33
	N.C.	P5-49
Ground		P4-17,50
Ground		P5-17,50

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Appendix C
VXI Glossary

The terms in this glossary are defined as used in the VXIbus System. Although some of these terms may have different meanings in other systems, it is important to use these definitions in VXIbus applications. Terms which apply only to a particular instrument module are noted. Not all terms appear in every manual.

Term	Definition
Accessed Indicator	An amber LED indicator that lights when the module identity is selected by the Resource Manager module, and flashes during any I/O operation for the module.
ACFAIL*	A VMEbus backplane line that is asserted under these conditions: 1) by the mainframe Power Supply when a power failure has occurred (either ac line source or power supply malfunction), or 2) by the front panel ON/STANDBY switch when switched to STANDBY.
A-Size Card	A VXIbus instrument module that is 100.0 by 160 mm by 20.32 mm (3.9 by 6.3 in by 0.8 in), the same size as a VMEbus single-height short module.
Asynchronous Communication	Communications that occur outside the normal "command-response" cycle. Such communications have higher priority than synchronous communication.
Backplane	The printed circuit board that is mounted in a VXIbus mainframe to provide the interface between VXIbus modules and between those modules and the external system.
B-Size Card	A VXIbus instrument module that is 233.4 by 160 mm by 20.32 mm (9.2 by 6.3 in by 0.8 in), the same size as a VMEbus double-height short module.
Bus Arbitration	In the VMEbus interface, a system for resolving contention for service among VMEbus Master devices on the VMEbus.
Bus Timer	A functional module that measures the duration of each data transfer on the Data Transfer Bus (DTB) and terminates the DTB cycle if the duration is excessive. Without the termination capability of this module, a Bus Master attempt to transfer data to or from a non-

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

existent Slave location could result in an infinitely long wait for the Slave response.

Client — In shared memory protocol (SMP), that half of an SMP channel that does not control the shared memory buffers.

CLK10 — A 10 MHz, ±100 ppm, individually buffered (to each module slot), differential ECL system clock that is sourced from Slot 0 and distributed to Slots 1-12 on P2. It is distributed to each module slot as a single source, single destination signal with a matched delay of under 8 ns.

CLK100 — A 100 MHz, ±100 ppm, individually buffered (to each module slot), differential ECL system clock that is sourced from Slot 0 and distributed to Slots 1-12 on P3. It is distributed to each module slot in synchronous with CLK10 as a single source, single destination signal with a maximum system timing skew of 2 ns, and a maximum total delay of 8 ns.

Commander — In the VXIbus interface, a device that controls another device (a servant). A commander may be a servant of another commander.

Command — A directive to a device. There are three types of commands:

In Word Serial Protocol, a 16-bit imperative to a servant from its commander.

In Shared Memory Protocol, a 16-bit imperative from a client to a server, or vice versa.

In a Message, an ASCII-coded, multi-byte directive to any receiving device.

Communication Registers — In word serial protocol, a set of device registers that are accessible to the commander of the device. Such registers are used for inter-device communications, and are required on all VXIbus message-based devices.

Configuration Registers — A set of registers that allow the system to identify a (module) device type, model, manufacturer, address space, and memory requirements. In order to support automatic system and memory configuration, the VXIbus standard specifies that all VXIbus devices have a set of such registers, all accessible from P1 on the VMEbus.

C-Size Card — A VXIbus instrument module that is 340.0 by 233.4 mm by 30.48 mm (13.4 by 9.2 in by 1.2 in).

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Custom Device A special-purpose VXIbus device that has configuration registers so as to be identified by the system and to allow for definition of future device types to support further levels of compatibility.

Data Transfer Bus One of four buses on the VMEbus backplane. The Data Transfer Bus allows Bus Masters to direct the transfer of binary data between Masters and Slaves.

DC SUPPLIES Indicator A red LED indicator that illuminates when a DC power fault is detected on the backplane.

Device Specific Protocol A protocol for communication with a device that is not defined in the VXIbus specification.

D-Size Card A VXIbus instrument module that is 340.0 by 366.7 mm by 30.48 mm (13.4 x 14.4 in x 1.2 in).

DTB See Data Transfer Bus.

DTB Arbiter A functional module that accepts bus requests from Requester modules and grants control of the DTB to one Requester at a time.

DUT Device Under Test.

ECLTRG Six single-ended ECL trigger lines (two on P2 and four on P3) that function as inter-module timing resources, and that are bussed across the VXIbus subsystem backplane. Any module, including the Slot 0 module, may drive and receive information from these lines. These lines have an impedance of 50 ohms; the asserted state is logical High.

Embedded Address An address in a communications protocol in which the destination of the message is included in the message.

ESTST Extended STart/STop protocol; used to synchronize VXIbus modules.

Extended Self Test Any self test or diagnostic power-up routine that executes after the initial kernel self test program.

External System Controller The host computer or other external controller that exerts overall control over VXIbus operations.

Failed Indicator A red LED indicator that lights when a device on the VXIbus has detected an internal fault. This might result in the assertion of the SYSFAIL* line.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

IACK Daisy Chain Driver The circuit that drives the VMEbus Interrupt Acknowledge daisy chain line that runs continuously through all installed modules or through jumpers across the backplane.

ID-ROM An NVRAM storage area that provides for non-volatile storage of diagnostic data.

Instrument Module A plug-in printed circuit board, with associated components and shields, that may be installed in a VXIbus mainframe. An instrument module may contain more than one device. Also, one device may require more than one instrument module.

Interface Device A VXIbus device that provides one or more interfaces to external equipment.

Interrupt Handler A functional module that detects interrupt requests generated by Interrupters and responds to those requests by requesting status and identity information.

Interrupter A device capable of asserting VMEbus interrupts and performing the interrupt acknowledge sequence.

IRQ The Interrupt ReQuest signal, which is the VMEbus interrupt line that is asserted by an Interrupter to signify to the controller that a device on the bus requires service by the controller.

Local Bus A daisy-chained bus that connects adjacent VXIbus slots.

Local Controller The instrument module that performs system control and external interface functions for the instrument modules in a VXIbus mainframe or several mainframes. See Resource Manager.

Local Processor The processor on an instrument module.

Logical Address The smallest functional unit recognized by a VXIbus system. It is often used to identify a particular module.

Mainframe

Card Cage For example, the Tektronix VX1400 Mainframe, an operable housing that includes 13 C-size VXIbus instrument module slots.

Memory Device A storage element (such as bubble memory, RAM, and ROM) that has configuration registers and memory attributes (such as type and access time).

Message A series of data bytes that are treated as a single communication, with a well defined terminator and message body.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Message Based Device — A VXIbus device that supports VXI configuration and communication registers. Such devices support the word serial protocol, and possibly other message-based protocols.

MODID Lines — Module/system identity lines.

Physical Address — The address assigned to a backplane slot during an access.

Power Monitor — A device that monitors backplane power and reports fault conditions.

P1 — The top-most backplane connector for a given module slot in a vertical mainframe such as the Tektronix VX1400. The left-most backplane connector for a given slot in a horizontal mainframe.

P2 — The bottom backplane connector for a given module slot in a vertical C-size mainframe such as the VX1400; or the middle backplane connector for a given module slot in a vertical D-size mainframe such as the VX1500.

P3 — The bottom backplane connector for a given module slot in a vertical D-size mainframe such as the Tektronix VX1500.

Query — A form of command that allows for inquiry to obtain status or data.

READY Indicator — A green LED indicator that lights when the power-up diagnostic routines have been completed successfully. An internal failure or failure of +5-volt power will extinguish this indicator.

Register Based Device — A VXIbus device that supports VXI register maps, but not high level VXIbus communication protocols; includes devices that are register-based servant elements.

Requester — A functional module that resides on the same module as a Master or Interrupt Handler and requests use of the DTB whenever its Master or Interrupt Handler requires it.

Resource Manager — A VXIbus device that provides configuration management services such as address map configuration, determining system hierarchy, allocating shared system resources, performing system self test diagnostics, and initializing system commanders.

Self Calibration — A routine that verifies the basic calibration of the instrument module circuits, and adjusts this calibration to compensate for short- and long-term variables.

Self Test — A set of routines that determine if the instrument module circuits will perform according to a given set of standards. A self test routine is performed upon power-up.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Servant	A VXIbus message-based device that is controlled by a commander.
Server	A shared memory device that controls the shared memory buffers used in a given Shared Memory Protocol channel.
Shared Memory Protocol	A communications protocol that uses a block of memory that is accessible to both client and server. The memory block operates as a message buffer for communications.
Slot 0 Controller	See Slot 0 Module. Also see Resource Manager.
Slot 0 Module	A VXIbus device that provides the minimum VXIbus slot 0 services to slots 1 through 12 (CLK10 and the module identity lines), but that may provide other services such as CLK100, SYNC100, STARBUS, and trigger control.
SMP	See Shared Memory Protocol.
STARX	Two (2) bi-directional, 50 ohm, differential ECL lines that provide for inter-module asynchronous communication. These pairs of timed and matched delay lines connect slot 0 and each of slots 1 through 12 in a mainframe. The delay between slots is less than 5 nanoseconds, and the lines are well matched for timing skew.
STARY	Two (2) bi-directional, 50 ohm, differential ECL lines that provide for inter-module asynchronous communication. These pairs of timed and matched delay lines connect slot 0 and each of slots 1 through 12 in a mainframe. The delay between slots is less than 5 nanoseconds, and the lines are well matched for timing skew.
STST	STart/STop protocol; used to synchronize modules.
SYNC100	A Slot 0 signal that is used to synchronize multiple devices with respect to a given rising edge of CLK100. These signals are individually buffered and matched to less than 2ns of skew.
Synchronous Communications	A communications system that follows the "command-response" cycle model. In this model, a device issues a command to another device; the second device executes the command; then returns a response. Synchronous commands are executed in the order received.
SYSFAIL*	A signal line on the VMEbus that is used to indicate a failure by a device. The device that fails asserts this line.
System Clock Driver	A functional module that provides a 16 MHz timing signal on the Utility Bus.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

System Hierarchy The tree structure of the commander/servant relationships of all devices in the system at a given time. In the VXIbus structure, each servant has a commander. A commander may also have a commander.

Test Monitor An executive routine that is responsible for executing the self tests, storing any errors in the ID-ROM, and reporting such errors to the Resource Manager.

Test Program A program, executed on the system controller, that controls the execution of tests within the test system.

Test System A collection of hardware and software modules that operate in concert to test a target DUT.

TTLTRG Open collector TTL lines used for inter-module timing and communication.

VXIbus Subsystem One mainframe with modules installed. The installed modules include one module that performs slot 0 functions and a given complement of instrument modules. The subsystem may also include a Resource Manager.

Word Serial Protocol A VXIbus word oriented, bi-directional, serial protocol for communications between message-based devices (that is, devices that include communication registers in addition to configuration registers).

Word Serial Communications Inter-device communications using the Word Serial Protocol.

WSP See Word Serial Protocol.

10 MHz Clock A 10 MHz, ±100 ppm timing reference. Also see CLK10.

100 MHz Clock A 100 MHz, ±100 ppm clock synchronized with CLK10. Also see CLK100.

488-To-VXIbus Interface A message based device that provides for communication between the IEEE-488 bus and VXIbus instrument modules.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Appendix D
User Service

This appendix contains service-related information that covers the following topics:

- Preventive maintenance
- User-replaceable Parts

Preventive Maintenance

You should perform inspection and cleaning as preventive maintenance. Preventive maintenance, when done regularly, may prevent malfunction and enhance reliability. inspect and clean the module as often as conditions require by following these steps:

1. Turn off power and remove the module from the VXIbus mainframe.
2. Remove loose dust on the outside of the instrument with a lint-free cloth.
3. Remove any remaining dirt with lint-free cloth dampened in a general purpose detergent-and-water solution. Do not use abrasive cleaners.

User-Replaceable Parts

Replacement parts are available through your local Tektronix field office or representative.

Changes to Tektronix instruments are sometimes made to accommodate improved components as they become available. Therefore, when ordering parts, it is important to include the following information in your order.

- Part number
- Instrument type or model number
- Instrument serial number
- Instrument modification number, if applicable.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

User-Replaceable Parts

Part Description	Part Number
User Manual	070-9124-00
Label, Tek CDS	950-0804-00
Label, VXI	950-0977-00
Fuse, Micro 5 Amp 125 V Fast	159-0207-00
Collar Screw, Metric 2.5 × 11 Slotted	950-0952-00
Shield, Front	950-1322-00
Screw, Phillips Metric 2.5 × 4 FLHD SS	211-0867-00

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Appendix E: Performance Verification Procedure

The performance verification procedure for the VX4357 Relay Switching Module checks that the module is operating within specification.

Conventions Used In This Procedure

Please familiarize yourself with the following conventions which apply throughout this procedure:

- All control of the VX4357 Module will be accomplished through a VXI Slot 0 device. ASCII characters will form the commands sent to control the module and ASCII characters will be read from the module.
- Throughout this document writes to the VX4357 Module will be shown as: Send "Q1lf" Where Q1lf is the command (Query relay one) terminated with a linefeed character (lf). Commands must be sent exactly as shown.
- Reads from the module are shown as: Read "0 crlf" Where 0crlf is the ASCII string returned from the VX4357 Module, terminated with a carriage return and linefeed (crlf). The ASCII string returned from the module will be exactly as shown.
- Unless noted, all commands are sent to the VX4357 Module and all ASCII strings read are read from the VX4357 Module.
- Two characters are used throughout the communication sequences: "cr" is the carriage return character (character 13) and "lf" is the line feed character (character 10). These characters are the terminating characters for communication. They are shown throughout this document in the font shown here. Most reads from the VX4357 Module are terminated with both characters and are shown as "crlf". Writes to the module require only a "lf", but both characters may be used.
- An ASCII upper case alpha character "O" will be shown as "O", and an ASCII numeric zero will be shown as "0".

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Equipment Required

Table 1–1 lists the equipment required for the performance and verification procedure.

Table 1–1: Equipment Required

Required tools and equipment	Part number
VXI Mainframe (such as the Tektronix VX1410)	n/a
VXI Slot 0 with resource Manager (Tektronix VX4521) and appropriate cables and interface cards.	n/a
Connector, DD-50P	n/a
VX1785S connector	n/a
Talker/Listener (Send/Read)	n/a
4.5 digit Digital Multimeter with a 4-wire Ohms capability and capable of reading greater then 10 Gigohms.	n/a

Connector Wiring

Using the DD-50P connector wire the following pins together, leaving a pig tale, and label this N.O.:

1, 3, 5, 7, 9, 11, 13, 15, 18, 20, 22, 24, 26, 28, 30, and 32

Using the VX1785S connector wire the following pins together, leaving a pig tale, and label this N.C.:

34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, and 49

Default Conditions And LED Test

1. Apply power to the VXI system and wait 10 seconds.
   Only the green PWR LED will be lit.
2. Send "Slf" (Set all relays) to the VX4357.
3. Verify that all LEDs for CH00 through CH31 are lit.
4. Send "Rlf" (Reset all relays) to the VX4357.
5. Verify that all LEDs for Ch00 through CH31 are out.

DMM Connection And Set-Up

Connect the DMM signal high and input positive (+) side to the pigtail on the DD-50P connector that is called out in the testing section.

Connect the DMM signal low and input negative (–) side to the pigtail on the VX1780S connector that is called out in the testing section. Set the DMM into 4 wire Ohms mode and autorange.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Relay Resistance Test: Channel 00

1. Place the DD-50P connector onto P4.
2. Place the DMM + side to the pigtail labeled N.C., and place the DMM – side to DD-50P pin-2 (wiper Channel 00).
3. The DMM will read less then 400 milliohms.
4. Send "C0lf" (Close relay CH00) to the VX4357.
5. The DMM will read greater then 10 Gigohms.
6. Send "Q0lf" (Query relay CH00) to the VX4357.
7. Read "1 crlf" (Relay CH00 is closed).
8. Place the DMM + side to the pigtail labeled N.O .
9. The DMM will read less then 400 milliohms.
10. Send "O0lf" (Open relay CH00) to the VX4357.
11. The DMM will read greater then 10 Gigohms.

Repeat steps 1 through 11 for relays CH01 through CH15, substituting Cxlf and Oxlf for the appreciate relay, where x = relay to close or open. Use Table 1–2 for the channel to wiper pin-out.

Table 1–2: Channel to wiper pin-out

Channel	Wiper pin
01	4
02	6
03	8
04	10
05	12
06	14
07	16
08	19
09	21
10	23
11	25
12	27
13	29
14	31
15	33

12. After repeating the above steps for Ch00 through CH15, remove the DD–50P connector from P4 and place it on P5.
13. Add 16 to all relay references and repeat the above steps for relays CH16 through CH 31.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Delay Command Test

1. Send “Rlf” (Reset the VX4357) to the VX4357.
2. Send “D1000C0C1” (Delay, Close CH00 and CH01 on the VX4357) to the VX4357. Monitor the time difference between CH00 LED to lit and CH01 to lit. This time will be approximately 1 second.
3. Send “Tlf” (Delay Time of the VX4357) to the VX4357.
4. Read “1000 crlf” (Time Delay programmed to 1000 milliseconds).

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group is an independent supplier of quality pre-owned equipment

Gold-standard solutions

Extend the life of your critical industrial, commercial, and military systems with our superior service and support.

We buy equipment

Planning to upgrade your current equipment? Have surplus equipment taking up shelf space? We'll give it a new home.

Learn more!

Visit us at **artisantg.com** for more info on price quotes, drivers, technical specifications, manuals, and documentation.

Artisan Scientific Corporation dba Artisan Technology Group is not an affiliate, representative, or authorized distributor for any manufacturer listed herein.

We're here to make your life easier. How can we help you today?

(217) 352-9330 | sales@artisantg.com | artisantg.com

ARTISAN® TECHNOLOGY GROUP