ARTISAN®
TECHNOLOGY GROUP

Your **definitive** source for quality pre-owned equipment.

Artisan Technology Group
(217) 352-9330 | sales@artisantg.com | artisantg.com

Full-service, independent repair center
with experienced engineers and technicians on staff.

We buy your excess, underutilized, and idle equipment
along with credit for buybacks and trade-ins.

Custom engineering
so your equipment works exactly as you specify.

- Critical and expedited services
- In stock / Ready-to-ship
- Leasing / Rentals / Demos
- ITAR-certified secure asset solutions

Expert team | Trust guarantee | 100% satisfaction

All trademarks, brand names, and brands appearing herein are the property of their respective owners.

Find the *Tews Technologies TIP551-10* at our website: ***Click HERE***

The Embedded I/O Company

TEWS TECHNOLOGIES

TIP551

Optically Isolated

4 Channel 16 Bit D/A

Version 1.1

User Manual

Issue 1.1.4

December 2009

TEWS TECHNOLOGIES GmbH
Am Bahnhof 7 25469 Halstenbek, Germany
Phone: +49 (0) 4101 4058 0 Fax: +49 (0) 4101 4058 19
e-mail: info@tews.com www.tews.com

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

TIP551-10

Optically isolated 4 Channel 16 bit D/A,
0V to +10V or +/-10V Output Voltage Range

This document contains information, which is proprietary to TEWS TECHNOLOGIES GmbH. Any reproduction without written permission is forbidden.

TEWS TECHNOLOGIES GmbH has made any effort to ensure that this manual is accurate and complete. However TEWS TECHNOLOGIES GmbH reserves the right to change the product described in this document at any time without notice.

TEWS TECHNOLOGIES GmbH is not liable for any damage arising out of the application or use of the device described herein.

Style Conventions

Hexadecimal characters are specified with prefix 0x, i.e. 0x029E (that means hexadecimal value 029E).

For signals on hardware products, an ‘Active Low’ is represented by the signal name with # following, i.e. IP_RESET#.

©2009 by TEWS TECHNOLOGIES GmbH

All trademarks mentioned are property of their respective owners.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Issue	Description	Date
	Preliminary Issue	August 1997
1.0	First Issue	September 1997
1.1	General Update	July 2002
1.2	New Hardware Version	September 2006
1.3	General Revision	June 2008
1.1.4	New Notation for User Manual and Engineering Documentation	December 2009

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Table of Contents

1 PRODUCT DESCRIPTION 6

2 TECHNICAL SPECIFICATION 7

2.1 Analog Output 8

2.2 Data Correction 8

2.2.1 DAC Correction Formula for 0V to +10V Output Voltage Range 8

2.2.2 DAC Correction Formula for ±10V Output Voltage Range 8

3 ID PROM CONTENTS 9

3.1 ID PROM Contents TIP551-10 9

4 IP ADDRESSING 10

4.1 Channel Select Register (0x01) 11

4.2 Status Register (0x03) 12

4.3 Data Register (0x04) 13

4.4 Load Register (0x07) 13

5 DAC DATA CODING 14

5.1 Bipolar Output Mode 14

5.2 Unipolar Output Mode 14

6 JUMPER CONFIGURATION 15

7 IP I/O CONNECTOR 16

7.1 Analog Output Connections 16

7.2 Power Input Connections 16

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

List of Figures

FIGURE 1-1 : BLOCK DIAGRAM TIP551 6
FIGURE 6-1 : JUMPER CONFIGURATION FOR OUTPUT VOLTAGE RANGE TIP551 15

List of Tables

TABLE 2-1 : TECHNICAL SPECIFICATION FUNCTIONAL DESCRIPTION 7
TABLE 3-1 : ID PROM CONTENTS TIP551-10 9
TABLE 4-1 : ID PROM CONTENTS TIP551-10 10
TABLE 4-2 : CHANSEL DAC CHANNEL SELECT REGISTER 11
TABLE 4-3 : STATREG DAC STATUS REGISTER 12
TABLE 4-4 : DATAREG DAC DATA REGISTER 13
TABLE 4-5 : LOADREG DAC LOAD REGISTER 13
TABLE 7-1 : ANALOG OUTPUT CONNECTIONS TIP551 16
TABLE 7-2 : POWER INPUT CONNECTIONS TIP551 16

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

1 Product Description

The TIP551 is an IndustryPack® compatible module providing 4 channels of isolated 16 bit analog outputs. Settling time to 0.003%is typical 10µs. The programmable output voltage range is ±10V or 0 to +10V selectable by jumper configuration. The DAC resets to 0V output voltage in both unipolar and bipolar output voltage range. The isolated DACs and the output buffers are powered by an on board DC/DC converter. Optocouplers are used for the DACs digital interfaces.

Each TIP551 is factory calibrated. The calibration information is stored in the Identification-PROM unique to each IP and voltage range.




Figure 1-1 : Block Diagram TIP551

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2 Technical Specification

Logic Interface	IndustryPack® Logic Interface
Size	Single wide IP
I/O Interface	50-conductor flat cable
Analog Outputs	4 D/A channels
Isolation	All D/A channels are galvanically isolated from the IP interface
Output Voltage Range	±10V or 0V to 10V (selectable by jumper), common for all 4 channels
Settling Time of DAC	To 0.003% in 10µs typical
Calibration Data	In ID PROM for gain and offset correction for each channel
Output Current	±4 mA for each channel
Load Capacitance	1nF typical
Accuracy	INL ±4 LSB typical after calibration
Linearity	DNL ±0.5 LSB
Monotonicity	16 bit over the specified temperature range
Wait States	no wait states
Power Requirements	360 mA typical I@+5V with 4mA output current for each channel
Temperature Range	Operating -40°C to +85°C Storage -45°C to +125°C
MTBF	714000 h
Humidity	5 - 95% non-condensing
Weight	34 g

Table 2-1 : Technical Specification Functional Description

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

2.1 Analog Output

The TIP551 includes 4 channels of analog outputs with a resolution of 16 bits and a voltage range of ±10V or 0V to +10V. The maximum output current for each channel is ±4 mA. Each channel has a settling time to 0.003 % of typical 10 µs.

Two voltage ranges are jumper selectable: ±10V or 0V to +10V. Voltage range selection covers all 4 channels.

The 4 analog outputs of the TIP551 are galvanically isolated from the IndustryPack logic interface by optocoupler.

2.2 Data Correction

There are two errors which affect the DC accuracy of the DAC. The first is the zero error (offset). For the DAC this is the data value required to produce a zero voltage output signal. This error is corrected by subtracting the known error from all readings.

The second error is the gain error. Gain error is the difference between the ideal gain and the actual gain of the DAC. It is corrected by multiplying the data value by a correction factor.

The data correction values are obtained during factory calibration and are stored in the modules individual version of the ID PROM. The DAC has a pair of offset and gain correction values for each single output channel. The correction values are stored in the ID PROM as two's complement byte wide values in the range -32768 to 32767. For higher accuracy they are scaled to ¼ LSB.

Because offset and gain correction values are dependent on the selected output voltage range the TIP551 has 2 different sets of ID PROM data. Depending on the jumper settings for the voltage range the corresponding set of correction values is automatically selected.

2.2.1 DAC Correction Formula for 0V to +10V Output Voltage Range

The basic formula for correcting unipolar DAC output value is:

$$\mathbf{Data = Value * (1 - Gain_{corr} / 262144) - Offset_{corr} / 4}$$

Data is the (corrected) digital value that should be sent to the DAC, Value is the desired output value, $Gain_{corr}$ and $Offset_{corr}$ are the correction factors from the ID PROM.

2.2.2 DAC Correction Formula for ±10V Output Voltage Range

The basic formula for correcting bipolar DAC output value is:

$$\mathbf{Data = Value * (1 - Gain_{corr} / 131072) - Offset_{corr} / 4}$$

Data is the (corrected) digital value that should be sent to the DAC, Value is the desired output value, $Gain_{corr}$ and $Offset_{corr}$ are the correction factors from the ID PROM.

$Gain_{corr}$ and $Offset_{corr}$ correction factors are stored separately for each for the four DAC outputs.

Floating point arithmetic or scaled integer arithmetic is necessary to avoid rounding error while computing above formula.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

3 ID Prom Contents

The Voltage Range bit of the DAC Status Register is used to select the correct set of data correction values for the actual selected voltage range (transparent for the user).

3.1 ID PROM Contents TIP551-10

ADDRESS	FUNCTION	Content	
0x01	ASCII 'I'		0x49
0x03	ASCII 'P'		0x50
0x05	ASCII 'A'		0x41
0x07	ASCII 'C'		0x43
0x09	Manufacturer ID		0xB3
0x0B	Model Number		0x23
0x0D	Revision		0x10
0x0F	reserved		0x00
0x11	Driver-ID low-byte		0x00
0x13	Driver-ID high-byte		0x00
0x15	number of bytes used		0x1D
0x17	C R C		variable
0x19	Version -10		0x0A
0x1B	DAC1 Offset	Ch.1 Low Byte	board dependent
0x1D	DAC1 Offset	Ch.1 High Byte	board dependent
0x1F	DAC2 Offset	Ch.2 Low Byte	board dependent
0x21	DAC2 Offset	Ch.2 High Byte	board dependent
0x23	DAC3 Offset	Ch.3 Low Byte	board dependent
0x25	DAC3 Offset	Ch.3 High Byte	board dependent
0x27	DAC4 Offset	Ch.4 Low Byte	board dependent
0x29	DAC4 Offset	Ch.4 High Byte	board dependent
0x2B	DAC1 Gain	Ch.1 Low Byte	board dependent
0x2D	DAC1 Gain	Ch.1 High Byte	board dependent
0x2F	DAC2 Gain	Ch.2 Low Byte	board dependent
0x31	DAC2 Gain	Ch.2 High Byte	board dependent
0x33	DAC3 Gain	Ch.3 Low Byte	board dependent
0x35	DAC3 Gain	Ch.3 High Byte	board dependent
0x37	DAC4 Gain	Ch.4 Low Byte	board dependent
0x39	DAC4 Gain	Ch.4 High Byte	board dependent
0x3B…0x3F	not used	-	-

Table 3-1 : ID PROM Contents TIP551-10

The TIP551 requires 870us after reset before ID data is ready to be read (ID data is loaded from serial EEPROM after reset).

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4 IP Addressing

The TIP551 is controlled by a set of registers, which are directly accessible in the I/O address space of the IP.

All registers are cleared by assertion of IP_RESET#.

Address	Name	Function	Size
0x01	CHANSEL	DAC Channel Select Register	byte
0x03	STATUS	DAC Status Register	byte
0x04	DATAREG	DAC Data Register	word
0x07	LOADDAC	DAC Load Register	byte
0x09	IDWRENA	ID Write Enable Register	byte

Table 4-1 : ID PROM Contents TIP551-10

IDWRENA is for factory use only. Do not write to this register!

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4.1 Channel Select Register (0x01)

The DAC Channel Select Register is used to load conversion data to the DAC internal data register of a selected DAC channel.

The DAC Data Register must be set up with the conversion data, before the write to the DAC Channel Select Register is performed.

If Bit 7 is set to '0', the write access to the DAC Channel Select Register does only update the DAC internal data register of the selected DAC channel. The DAC outputs are not updated in this case.

If Bit 7 is set to '1', the write access to the DAC channel Select Register first updates the DAC internal data register of the selected channel. After that all 4 DAC outputs are updated according to the DAC internal data register of each channel.

Write access to the DAC Channel Select Register during active DACBUSY status is ignored and sets the ERROR flag in the DAC Status Register.

<table>
<tr><th>Bit Number</th><th>Symbol</th><th>Description</th><th>Access</th><th>Reset Value</th></tr>
<tr><td>7</td><td>AL</td><td>Automatic Load after Data Transfer
0 = No DAC output update. User can update all DAC outputs with a write access to the DAC Load Register or with the next channel selection write with AL bit set to ‘1’ after data transmission.
1 = All 4 DAC outputs are updated automatically after data transmission to the selected DAC channel</td><td>R/W</td><td>0</td></tr>
<tr><td>6:2</td><td>-</td><td>Always read as 0</td><td>-</td><td>-</td></tr>
<tr><td>1
0</td><td>CS1
CS0</td><td>Output Channel Selection
CS1 | CS0 | Channel
0 | 0 | 1
0 | 1 | 2
1 | 0 | 3
1 | 1 | 4</td><td>R/W</td><td>00</td></tr>
</table>

Table 4-2 : CHANSEL DAC Channel Select Register

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4.2 Status Register (0x03)

The DAC Status Register is used to signal status information of the TIP551 which are assisting to control the conversation of DAC Output.

The DAC Status Register is an 8 bit read only register.

Bit Number	Symbol	Description	Access	Reset Value
7:3	-	Always read as 0	-	-
2	ERR	Error flag Write access to the DAC Channel Select Register or DAC Load Register during active DACBUSY status is ignored and sets this flag to '1'. Any write access to the DAC Status Register clears the ERROR flag.	R	0
1	VR	Voltage Range flag Indicates the selected Voltage Range according to the jumper setting for the output voltage ranges. Reading as '0' means ±10V output range and binary two's complement as output code Reading as'1' means 0V to +10V output range and straight binary as output code	R	x
0	DAC BUSY	DAC Busy flag Reading as '1' indicates that a serial data transfer to the DAC is in progress. Write access to the DAC Channel Select Register or DAC Load Register during active DACBUSY status is ignored and sets the Error flag.	R	0

Table 4-3 : STATREG DAC Status Register

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

4.3 Data Register (0x04)

The DAC Data Register contains the DAC conversion data, used by the DAC Channel Select command.

A write access to the DAC Channel Select Register starts the serial data transfer to the DAC (and if selected the conversion into an analog value).

Immediately after a write to the DAC Channel Select register, the DAC Data Register may be written with the next conversion data value. However, before the next write to the DAC Channel Select Register, the DACBUSY status bit must be '0'.

The content of the DAC Data Register is valid until it is re-written by the user.

The DAC Data Register does not need to be updated if the DAC conversion data value for the next DAC Channel Select command should be the same.

Bit Number	Symbol	Description	Access	Reset Value
15:0	-	This register contains the desired DAC conversion data value used by the DAC Channel Select command.	R/W	0x0000

Table 4-4 : DATAREG DAC Data Register

For data coding see chapter “DAC Data Coding”.

4.4 Load Register (0x07)

Every write access to the DAC Load Register updates all 4 DAC outputs with the last value written into the DACs internal data register.

Write access to the DAC Load Register during active DACBUSY status is ignored and sets the ERROR flag in the DAC Status Register.

Bit Number	Symbol	Description	Access	Reset Value
7:0	-	Write access updates all 4 DAC outputs with the conversion data stored in the DACs internal data register. DACBUSY status must be '0' before are write to the DAC Load Register.	W	-

Table 4-5 : LOADREG DAC Load Register

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

5 DAC Data Coding

5.1 Bipolar Output Mode

If the DAC channels are configured for ±10V output voltage range by the corresponding jumper configuration the following DAC data coding applies:

DATAREG	OUTPUT
0x7FFF	+ Full-scale
0x8000	- Full-scale
0x0000	Midscale

5.2 Unipolar Output Mode

If the DAC channels are configured for 0V to +10V output voltage range by the corresponding jumper configuration the following DAC data coding applies:

DATAREG	OUTPUT
0xFFFF	+ Full-scale
0x8000	Midscale
0x0000	Zero-scale

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

6 Jumper Configuration

On the TIP551 the desired DAC output voltage range is configured by a 3 pin jumper field.

The configured DAC output voltage range applies to all four DAC channels.

Jumper Configuration :

Voltage range 0V to +10V : J1 1-2 installed

Voltage range ±10V : J1 2-3 installed




Figure 6-1 : Jumper Configuration for Output Voltage Range TIP551

Factory configuration is 0V to +10V output voltage range for all DAC channels.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

7 IP I/O connector

7.1 Analog Output Connections

Pin-Number	Signal
01	DAC_OUT1
02	AGND
03	DAC_OUT2
04	AGND
05	DAC_OUT3
06	AGND
07	DAC_OUT4
08	AGND

Table 7-1 : Analog Output Connections TIP551

7.2 Power Input Connections

Pin-Number	Function
44	AGND
45	-15V
46	AGND
47	+15V
48	AGND
49	+5V
50	AGND

Table 7-2 : Power Input Connections TIP551

The power input connections are reserved for special versions of the TIP551 without on board DC/DC converter. Do not supply any voltage to these pins for the TIP551-10 version.

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisantg.com

Artisan Technology Group is an independent supplier of quality pre-owned equipment

Gold-standard solutions

Extend the life of your critical industrial, commercial, and military systems with our superior service and support.

We buy equipment

Planning to upgrade your current equipment? Have surplus equipment taking up shelf space? We'll give it a new home.

Learn more!

Visit us at **artisantg.com** for more info on price quotes, drivers, technical specifications, manuals, and documentation.

Artisan Scientific Corporation dba Artisan Technology Group is not an affiliate, representative, or authorized distributor for any manufacturer listed herein.

We're here to make your life easier. How can we help you today?

(217) 352-9330 | sales@artisantg.com | artisantg.com

ARTISAN® TECHNOLOGY GROUP